



Inspection Report

City College/Medical School Of Cuny, The
Convent Ave & 138th St
Science Bldg Annex - Mr Annex
New York New York, NY 10031

Customer ID: 435

Certificate: 21-R-0078

Site: 001

CITY COLLEGE/ MEDICAL SCHOOL

Type: ROUTINE INSPECTION

Date: 17-MAR-2014

3.11(c)

CLEANING, SANITIZATION, HOUSEKEEPING, AND PEST CONTROL.

Item Housekeeping 3.11c

At the time of inspection it was noticed that the ceiling in clean side of the cage washer was peeling. This can cause clean cages to be contaminated by falling paint after they have cleaned.

Facility needs to repair surface so as insure clean cages are not contaminated and maintain good husbandry practices.

Correct by 4/17/14

An exit interview took place at the end of inspection

Prepared By: JOHN LOPINTO, D V M USDA, APHIS, Animal Care

Date:
17-MAR-2014

Title: VETERINARY MEDICAL OFFICER 1008

Received by Title: DIRECTOR

Date:
17-MAR-2014



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
435	21-R-0078	001	CITY COLLEGE/ MEDICAL SCHOOL	17-MAR-14

Count	Scientific Name	Common Name
000001	<i>Felis silvestris catus</i>	CAT ADULT
000001	Total	