



Inspection Report

Universidad Ana G. Méndez
School of Veterinary Medicine PO Box 3030
Gurabo, PR 00778

Customer ID: **502100**

Certificate: **94-R-0115**

Site: 001

UNIVERSIDAD ANA G MENDEZ
GURABO CAMPUS

Type: ROUTINE INSPECTION

Date: 17-AUG-2026

3.2(d)

Indoor housing facilities.

In the radiology room, APHIS Officials observed the following non-compliances:

On the ceiling right above the door when you come into the room, Officials observed a black and fuzzy substance which looked like black mold. The ceiling had water marks on the concrete (beige colored) covering an area of approximately 2.5ft by 2ft. The ceiling and walls of areas used by dogs and cats must be impervious to moisture or be replaceable. Furthermore, the presence of black mold is of health concern for dogs and cats.

On the floor next to the radiology machine an area of approximately 2.5 inches in diameter of the linoleum was peeled off and exposing the concrete beneath it. The floor of areas that come in contact with dogs and cats must be impervious to moisture to clean and sanitized properly.

The floors and walls of indoor housing facilities, and any other surfaces in contact with the animals, must be impervious to moisture. The ceilings of indoor housing facilities must be impervious to moisture or be replaceable (e.g., a suspended ceiling with replaceable panels).

To be corrected by December 1, 2026.

This inspection and exit interview were conducted with Facility Representative.

Additional Inspectors:

Lemnique Wafer, Assistant Director

Prepared By: PATRICIA LARACUENTE

USDA, APHIS, Animal Care

Title: VETERINARY MEDICAL
OFFICER

Date:

24-AUG-2026

Received by Title: Facility Representative

Date:

24-AUG-2026



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
502100	94-R-0115	001	UNIVERSIDAD ANA G MENDEZ GURABO CAMPUS	17-AUG-2026

Count	Scientific Name	Common Name
000000	NONE	NONE
000000	Total	