



Inspection Report

University of Puerto Rico
PO Box 365067 - Medical Science Campus
San Juan, PR 00936

Customer ID: **960**
Certificate: **94-R-0109**
Site: 003
SABANA SECA

Type: ROUTINE INSPECTION
Date: 19-AUG-2026

3.75(a) Repeat

Housing facilities, general.

During the inspection, APHIS officials observed multiple rusted-through bottom beams in several primary enclosures. In other enclosures, multiple floor tiles were missing pieces and had sharp edges. These damaged tiles could cause injury if the animals' feet or hands were to become entrapped in the gaps.

Housing facilities for nonhuman primates must be designed and constructed so that they are structurally sound for the species of nonhuman primates housed in them. They must be kept in good repair, and they must protect the animals from injury, contain the animals securely, and restrict other animals from entering.

3.78(d)

Outdoor housing facilities.

While APHIS Officials walked the perimeter fence of the facility multiple areas were leaning and bent, reducing their height to under 6 feet. The areas that were leaning allow for unauthorized access to the facility by animals or people. Two areas were of concern, the first one behind the SPF corrals close to C104, this area was bent on top with unraveled barb wire. The second area of concern, located behind the retirement pens was leaning and was bent at the top as well. The perimeter fence when leaning or bent provide points of access for outside unauthorized animals and people. On and after February 15, 1994, an outdoor housing facility must be enclosed by a fence that is of sufficient height to keep unwanted species out. Fences less than 6 feet high must be approved by the Administrator. The fence must be constructed so that it protects nonhuman primates by restricting unauthorized humans, and animals the size of dogs, skunks, and raccoons from going through it or under it and having contact with the nonhuman primates. It must be of sufficient distance from the outside wall or fence of the primary enclosure to prevent physical contact between animals inside the enclosure and outside the perimeter fence.

To be corrected by December 1, 2026.

This inspection and exit interview were conducted with Attending Veterinarian.

Prepared By: PATRICIA LARACUENTE
USDA, APHIS, Animal Care
Title: VETERINARY MEDICAL OFFICER

Date:
24-AUG-2026

Received by Title: Attending Veterinarian

Date:
24-AUG-2026



Inspection Report

Additional Inspectors:

Lemnique Wafer, Assistant Director

Prepared By: PATRICIA LARACUENTE
USDA, APHIS, Animal Care

Title: VETERINARY MEDICAL
OFFICER

Date:
24-AUG-2026

Received by Title: Attending Veterinarian

Date:
24-AUG-2026



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
960	94-R-0109	003	SABANA SECA	19-AUG-2026

Count	Scientific Name	Common Name
002300	<i>Macaca mulatta</i>	RHESUS MACAQUE
002300	Total	