



Inspection Report

Long Island University

Customer ID: **319**

Long Island Univ Of Sponsored Research, University Center 700 Northern
Blvd
UNIVERSITY CENTER 700 NORTHERN BLVD.
Greenvale, NY 11548

Certificate: **21-R-0058**

Site: 003

Long Island University

Type: ROUTINE INSPECTION

Date: 27-JUL-2026

2.31(d)(1)(ix)

Institutional Animal Care and Use Committee (IACUC).

Two dedicated surgical rooms used for the trap neuter release (TNR) program for cats have porous ceiling tiles. At the time of inspection there was one cat undergoing a surgical procedure.

Porous ceiling tiles may be difficult to clean and sanitize as required. Dirt and other debris may collect within the porous surfaces and contaminate the surgical fields. All survival surgery should be performed using aseptic procedures... major operative procedures on non-rodents should be conducted only in facilities intended for that purpose which shall be operated and maintained under aseptic conditions.

To be corrected by September 15, 2026

This inspection and exit interview were conducted with the facility representatives.

Prepared By: ALEXANDRA ANDRICOS

USDA, APHIS, Animal Care

Date:

29-JUL-2026

Title: VETERINARY MEDICAL
OFFICER

Received by Title: Facility Representative

Date:

29-JUL-2026



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
319	21-R-0058	003	Long Island University	27-JUL-2026

Count	Scientific Name	Common Name
000003	<i>Capra hircus</i>	DOMESTIC GOAT
000002	<i>Felis catus</i>	CAT ADULT
000005	Total	