



Inspection Report

University of Puerto Rico
PO Box 365067 - Medical Science Campus
San Juan, PR 00936

Customer ID: **960**

Certificate: **94-R-0109**

Site: 001

UNIVERSITY OF PUERTO RICO -
MEDICAL SCIENCE

Type: ROUTINE INSPECTION

Date: 17-AUG-2026

3.75(a)

Repeat

Housing facilities, general.

While inspecting the outside cage wash room, APHIS Officials observed multiple holes in the aluminum ceiling approximately 3-6 inches in the center of the ceiling where sunlight was coming through. Officials also observed too numerous to count holes approximately 0.5 inch to 2 inches in diameter throughout the ceiling. The supporting beam was also severely rusted. The holes in the ceiling have gotten bigger since the last routine inspection on July 22, 2025. The holes on the roof are big enough where pests have an entrance point and have access to animals, equipment, and rooms. Housing facilities for non-human primates must be designed and constructed so that they are structurally sound for the species of non-human primates housed in them. They must be kept in good repair, and they must protect the animals from injury, contain the animals securely, and restrict other animals from entering.

This inspection and exit interview were conducted with Facility Representative.

Additional Inspectors:

Lemnique Wafer, Assistant Director

Prepared By: PATRICIA LARACUENTE

USDA, APHIS, Animal Care

Date:

24-AUG-2026

Title: VETERINARY MEDICAL
OFFICER

Received by Title: Attending Veterinarian

Date:

24-AUG-2026



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
960	94-R-0109	001	UNIVERSITY OF PUERTO RICO - MEDICAL SCIENCE	17-AUG-2026

Count	Scientific Name	Common Name
000020	<i>Macaca mulatta</i>	RHESUS MACAQUE
000020	Total	