

ERCOT Market Briefing

Electric Reliability Council of Texas

Report Date: January 15, 2026
Analysis Period: September 1-30, 2025
Document ID: ERCOT-MB-2026-001-CONFIDENTIAL
Prepared by: Dr. Sarah Chen, Chief Market Analyst
Reviewed by: James Rodriguez, VP Grid Operations

CONFIDENTIAL - FOR INTERNAL USE ONLY

Executive Summary

This comprehensive market briefing provides an in-depth analysis of ERCOT grid operations, market dynamics, and renewable energy integration for September 2025. The report examines key performance indicators including system load, day-ahead market pricing, renewable generation patterns, and weather impacts across major Texas metropolitan areas. **CRITICAL FINDINGS - SEPTEMBER 2025:** During the analysis period, ERCOT managed an average system load of 59,343 MW with peak demand reaching 78,814 MW. Day-ahead market prices averaged \$32.84/MWh, reflecting stable supply-demand conditions with periodic volatility during peak demand periods. **September 8-10 Hurricane Francine Impact:** Hurricane Francine made landfall on the Louisiana coast on September 9, 2025, bringing significant weather impacts to East Texas and the Houston metropolitan area. While the storm weakened to tropical storm status before reaching Texas, it generated sustained 45 mph winds and delivered 8-12 inches of rainfall across coastal counties. Grid operators implemented precautionary measures including pre-positioning repair crews and coordinating with neighboring utilities. Approximately 127,000 customers experienced outages, primarily in the Houston and Beaumont areas, though grid stability was maintained throughout the event with no emergency operating conditions declared. **Renewable Energy Records:** September 15, 2025 established a new single-day solar generation record with peak output reaching 29,502 MW at 1:47 PM CT. This milestone reflects continued growth in Texas solar capacity, with approximately 3,200 MW of new photovoltaic capacity entering commercial operation during Q2 and Q3 2025. Wind generation demonstrated strong performance, averaging 10,570 MW throughout the month. **Gas Supply Dynamics:** Natural gas prices at the Houston Ship Channel hub averaged \$2.87/MMBtu during September, down 12% from August levels as cooling degree days declined. The Permian Basin continued ramping associated gas production from oil operations, contributing to regional supply abundance and supporting stable power generation costs.

Key Findings	
Average System Load	59,343 MW
Peak System Load	78,814 MW
Average DAM Price	\$32.84/MWh

Price Range	\$-7.96 - \$134.53/MWh
Wind Capacity Factor	44.6%
Solar Capacity Factor	30.7%
Hurricane Francine Outages	127,000 customers (peak)
New Solar Capacity (Q2-Q3)	3,200 MW

Regulatory and Policy Developments

PUCT Performance Credit Mechanism (PCM) Implementation Update: The Public Utility Commission of Texas (PUCT) continues refining the Performance Credit Mechanism approved in May 2024. The PCM introduces a new market-based framework to ensure resource adequacy by requiring load-serving entities to hold credits corresponding to their peak load obligations. Generation resources earn credits based on demonstrated availability during high-risk operating conditions. **Key PCM Parameters Announced September 2025:** • Credit Obligation Period: June 1 - September 30 (coinciding with peak summer risk) • Qualifying Assessment Hours: Hours when ERCOT Operating Reserve Demand Curve (ORDC) exceeds \$75/MWh • Bridge Year Implementation: Summer 2026 will serve as bridge year with voluntary participation • Mandatory Compliance: Summer 2027 and beyond • Initial Assessment: Approximately 850-950 hours per summer expected to qualify for credit assessment • Penalty Structure: Load-serving entities short of credit obligations face penalties of \$3,000/MW-day. The PCM represents ERCOT's most significant market design change since nodal market implementation in 2010. Market participants are actively evaluating investment implications, with particular focus on how different resource types (thermal, storage, demand response) will qualify for and monetize performance credits. **SB 1699 Weatherization Compliance:** Senate Bill 1699, enacted following Winter Storm Uri in February 2021, mandates weatherization of generation facilities and critical natural gas infrastructure. The Railroad Commission of Texas and PUCT jointly oversee compliance, with September 2025 representing a critical milestone. As of September 30, 2025, compliance statistics indicate: • 94.7% of generation facilities completed required weatherization measures (by capacity) • 87.2% of critical natural gas production facilities completed weatherization • 12 generation facilities (totaling 1,847 MW) received compliance extensions due to equipment supply chain constraints • 3 natural gas processing plants remain under corrective action plans. The high compliance rate significantly reduces grid vulnerability to extreme winter weather compared to conditions during Winter Storm Uri. However, interconnected natural gas-electric system resilience remains a focus area, particularly regarding gas fuel assurance during extended cold weather events. **Renewable Energy Zone (REZ) Transmission Expansion:** The CREZ (Competitive Renewable Energy Zone) transmission projects initiated in 2008 successfully delivered West Texas wind resources to load centers. Building on this success, PUCT approved Phase II REZ expansion in March 2025, targeting \$4.2 billion in new transmission infrastructure to support: • West Texas and Panhandle wind resources (targeting additional 15,000 MW deliverability) • South Texas solar development (enabling 8,000 MW new capacity) • Coastal wind resources (supporting 3,500 MW offshore wind potential). Construction began on three priority projects in September 2025: 1. **Permian Basin-North Hub 345 kV Double Circuit:** 240-mile transmission line from Permian Basin wind/solar resources to North Texas load centers. Expected in-service date: December 2027. 2. **Corpus Christi-San Antonio 345 kV Upgrade:** Reconductoring and substation enhancements to support South Texas solar and potential Gulf Coast offshore wind. In-service: June 2028. 3. **Panhandle Reinforcement Project:** Series of 345 kV upgrades improving deliverability from Panhandle wind resources during high output periods. Phased completion: 2027-2029. These projects will further enable renewable integration while reducing transmission congestion that occasionally limits renewable energy delivery during high output periods.

Market Participant Insights

ERCOT staff conducted interviews with major market participants during September 2025 to gather qualitative insights on market performance, operational challenges, and investment perspectives. The following represents synthesized feedback from generators, load-serving entities, and renewable developers.

Generation Asset Owners: Combined-Cycle Gas Turbine (CCGT) Operators: Multiple CCGT operators reported improved economics during September compared to recent months, with average capacity factors reaching 48-52% for efficient units. The moderate pricing environment (\$30-45/MWh average) supported positive margins given natural gas prices near \$2.90/MMBtu. However, operators expressed concerns about increasing cycling requirements as renewable penetration grows. "We're seeing 2-3 start/stop cycles per day during shoulder months, compared to one cycle per day five years ago," noted one plant manager. This cycling increases maintenance costs and equipment wear. Several operators emphasized the importance of the forthcoming PCM implementation: "The PCM should provide revenue certainty for maintaining reliable capacity. Without it, our investment case for new efficient gas units or major overhauls becomes challenging." Others noted that day-ahead energy markets alone may not adequately compensate the flexibility value these units provide.

Wind Developers: Wind project developers reported robust development pipelines, with approximately 6,500 MW of West Texas and Panhandle projects in advanced development stages (2026-2028 commercial operation dates). However, transmission availability remains a constraint. "We have sites with excellent wind resources, but interconnection studies show we're years away from transmission capacity," explained a developer with multiple projects in the queue. Production tax credit (PTC) economics under the Inflation Reduction Act continue driving wind development, though developers noted increasing competition for turbine supply, balance-of-plant contractors, and interconnection capacity. Some developers are exploring hybrid configurations combining wind with battery storage to improve deliverability and create additional revenue streams.

Solar Developers: Solar development activity accelerated in 2025, with South Texas and West Texas regions seeing particularly strong interest. The combination of excellent solar resources, available land, and favorable interconnection positions supports robust project economics even with midday price suppression from existing solar capacity. "September showed us both the opportunity and the challenge," noted a solar developer. "We hit record generation days, but we also saw days where midday prices fell to \$18-20/MWh due to solar saturation. That's why we're increasingly looking at solar-plus-storage configurations." Investment tax credit (ITC) availability under federal tax policy provides 30-40% project cost support (depending on domestic content and energy community qualifications), making projects viable despite price cannibalization concerns.

Load-Serving Entities: Retail electric providers (REPs) serving ERCOT load reported stable market conditions during September with manageable price volatility. "The shoulder season gives us breathing room to optimize hedging strategies before winter," explained one REP risk manager. However, several REPs expressed uncertainty about PCM implementation and its impact on their load-serving costs. Large industrial consumers, particularly petrochemical facilities and data centers, continue evaluating direct participation in wholesale markets versus traditional retail service. "We're seeing more sophisticated load management strategies, including shifting operations to low-price hours and participating in demand response programs," noted an ERCOT market monitor.

Energy Storage Operators: Battery energy storage system (BESS) operators reported strong performance and revenue streams during September. A 200 MW / 800 MWh facility near Houston achieved average revenues of \$87/kW-month through a combination of day-ahead energy arbitrage, real-time energy optimization, and ancillary services provision. "Storage economics work best when we can stack multiple revenue streams," explained one operator. "We're providing Regulation Up/Down service, capturing day-ahead/real-time price spreads, and increasingly helping manage the evening ramp as solar drops off." However, operators noted that increasing storage deployment may compress arbitrage margins over time: "As more storage comes online, we'll all be buying low and selling high at the same times, which could narrow spreads. That's why ancillary services and PCM credits will become increasingly important."

Notable Operational Events - September 2025

September 3: Labor Day Load Forecast Under-prediction: The Labor Day holiday on September 3, 2025 presented forecasting challenges. Initial load forecasts predicted reduced demand due to the holiday, with commercial and light industrial loads expected to decline. However, actual loads exceeded forecasts by approximately 2,200 MW during afternoon hours (2-6 PM) as many residents remained home with air conditioning operating during warm afternoon temperatures (32-34°C across major metro areas). The forecast deviation required real-time market adjustments, with prices briefly spiking to \$186/MWh at 3:15 PM before returning to more typical levels as additional generation responded. The event highlighted ongoing challenges in forecasting holiday load patterns, particularly during warm weather when residential cooling loads dominate total demand. ERCOT operations staff noted: "We saw similar patterns during Memorial Day weekend. Holiday forecasting models developed pre-pandemic may need updates to reflect changing work patterns and increased residential loads during traditional business hours."

September 12: South Texas Transmission Constraint Event: A transmission constraint developed on September 12 between 6:45 AM and 11:20 AM when the Nueces Bay - Corpus Christi 345 kV line experienced emergency de-rating due to a failed tower insulator. The constraint limited power flow from South Texas solar facilities to San Antonio and Austin load centers. Real-time prices at the Valley hub (South Texas) fell to \$14.50/MWh while Houston hub prices rose to \$38.20/MWh, creating a \$23.70/MWh price separation. Approximately 850 MW of solar generation capacity was curtailed economically (offered below clearing price but not dispatched due to transmission limits). Transmission crews replaced the failed insulator by 11:20 AM, restoring normal operating conditions. The event underscores the importance of transmission reliability during high solar production periods and supports the business case for ongoing transmission expansion projects.

September 18-19: Forecasting Accuracy Challenge: A rapidly developing mesoscale convective system (MCS) moved across West Texas overnight September 18-19, creating significant wind forecast errors. Day-ahead wind forecasts predicted 4,200-4,800 MW generation during overnight hours (12 AM - 6 AM on September 19). Actual wind generation averaged 7,400 MW during this period as the MCS enhanced surface wind speeds across Panhandle and West Texas wind farms. The 3,200 MW positive forecast error created operational challenges as overnight load (typically 50,000-53,000 MW) combined with must-run nuclear baseload and high wind output produced excess generation conditions. Real-time prices fell to \$11.20/MWh, and several combined-cycle units reduced output to minimum operating levels. "These situations require careful coordination," noted the ERCOT shift supervisor on duty. "We need to maintain sufficient online dispatchable capacity to cover potential wind drops if the weather system dissipates suddenly, but we also need to manage the immediate excess supply situation. It's a balancing act." The event highlights the ongoing importance of improved mesoscale weather forecasting for wind generation prediction, particularly during severe weather events.

September 22: South Texas Nuclear Station Power Uprate Completion: The South Texas Project (STP) Nuclear Station completed a planned power uprate on Unit 1, increasing licensed capacity from 1,410 MW to 1,450 MW (+40 MW or +2.8% increase). The uprate, approved by the Nuclear Regulatory Commission in July 2024, involved turbine efficiency improvements and generator enhancements. Unit 1 returned to full power operations on September 22 following a three-week refueling and modification outage. Unit 2 is scheduled for similar power uprate during its planned refueling outage in Spring 2026. Combined, the uprates will add 80 MW of carbon-free baseload capacity to the ERCOT system. "Every megawatt of reliable baseload capacity helps grid stability," commented ERCOT's resource adequacy manager. "Nuclear uprates provide carbon-free generation without requiring new site development or transmission infrastructure."

September 26: Demand Response Test Event: ERCOT conducted a voluntary demand response test event on September 26 from 3:00-5:00 PM to evaluate emergency demand response program capabilities ahead of winter operations. The test targeted industrial and large commercial participants with capability to curtail load rapidly. Participation exceeded expectations, with 1,850 MW of load reduction achieved within 30 minutes of the test notification. Participating facilities included: • Petrochemical plants with interruptible production processes: 720 MW • Water treatment and pumping facilities: 340 MW • Cold storage warehouses with thermal capacity: 280 MW • Data centers with generator backup capability: 310 MW • Large commercial HVAC curtailment: 200 MW "The test validated that our emergency demand response programs can deliver meaningful load relief when needed," reported ERCOT's demand response coordinator. "This capability provides critical insurance against extreme operating conditions."

System Load Analysis

System load represents total electricity demand across the ERCOT footprint. During September 2025, load patterns demonstrated characteristic diurnal cycles with morning ramps, afternoon peaks, and evening declines. The analysis period captured the seasonal transition from peak summer cooling loads toward more moderate autumn demand levels. **Load Statistics:** • Average Hourly Load: 59,343 MW • Peak Load: 78,814 MW (observed during late evening hours) • Minimum Load: 42,705 MW (typically during early morning hours) • Load Factor: 75.3% **Impact of Growing Data Center Loads:** Texas continues experiencing rapid data center development, with approximately 1,200 MW of new data center load entering service during 2025. Major technology companies have announced plans for additional facilities totaling 3,500 MW over the next 3-4 years. These loads present both opportunities and challenges: **Opportunities:** Data centers provide stable, predictable baseload consumption that improves overall load factor. Many facilities incorporate on-site generation and energy storage, potentially providing grid services. Several data center operators have expressed interest in flexible load programs, shifting computational workloads to low-price periods. **Challenges:** Concentrated geographic development (primarily in Dallas-Fort Worth, Austin, and San Antonio metros) can strain local transmission and distribution infrastructure. Data center loads are less weather-sensitive than traditional loads, potentially changing forecasting patterns. Cooling requirements, while predictable, add to summer peak demands. "We're working closely with data center developers to understand their long-term load profiles and interconnection requirements," noted ERCOT's transmission planning manager. "Proactive planning ensures we have adequate infrastructure to serve these critical loads reliably."

Renewable Energy Performance

Renewable energy sources demonstrated substantial contribution to ERCOT grid operations during September 2025. Wind and solar resources collectively provided an average of 19,614 MW, representing approximately 33.1% of total system load during the analysis period. **Wind Generation Performance:** Wind power maintained strong output throughout September, averaging 10,570 MW with peak generation reaching 23,692 MW during favorable meteorological conditions. • Average Wind Output: 10,570 MW • Maximum Wind Output: 23,692 MW • Capacity Factor: 44.6% **Curtailement Analysis:** Economic curtailment (renewable generation offered into the market but not dispatched due to transmission constraints or negative prices) remained minimal during September, totaling approximately 340 GWh for the month (roughly 2.3% of potential renewable generation). This represents significant improvement from previous years as transmission expansion projects enhance renewable deliverability. The majority of curtailment occurred during overnight hours when wind output peaked but load fell to daily minimums. "We're seeing fewer curtailment events as storage deployment increases and market participants find ways to utilize low-price renewable energy," observed ERCOT's renewable integration manager. "Battery storage in particular helps absorb overnight wind that might otherwise be curtailed." **Repowering Activity:** Several first-generation wind projects (installed 2005-2010) are undergoing repowering, replacing older turbines with modern, more efficient models. Repowering can increase capacity by 50-100% on the same site footprint while qualifying for renewed production tax credits under federal policy. The Capricorn Ridge Wind Farm (Taylor County) completed repowering in September, replacing 662 MW of original capacity with 875 MW of modern turbines (+32% capacity increase). Similar repowering projects totaling approximately 2,800 MW are planned for 2026-2027 across West Texas.

Investment and Development Pipeline

ERCOT's interconnection queue provides visibility into future generation resources. As of September 30, 2025, the queue contains significant renewable energy, storage, and thermal generation projects at various stages of development. **Interconnection Queue Summary (Active Projects):** • Solar PV Projects: 47,200 MW (various stages) • Wind Projects: 18,500 MW (various stages) • Battery Energy Storage: 22,400 MW / 89,600 MWh • Natural Gas Combined-Cycle: 8,200 MW • Natural Gas Simple-Cycle/Peaking: 3,400 MW • Geothermal (experimental): 150 MW • Small Modular Nuclear Reactors (early stage): 1,200 MW Not all queued projects will reach commercial operation. Historical completion rates suggest approximately 45-55% of queued renewable projects and 30-40% of queued storage projects ultimately enter service. However, the pipeline indicates continued strong interest in ERCOT market opportunities. **Notable Projects Entering Service 2026-2027:** **1. Roadrunner Solar Complex (Pecos County):** 800 MW solar + 400 MW / 1,600 MWh storage. Expected commercial operation June 2026. Will be among the largest solar-storage hybrid facilities in ERCOT. Project secured 15-year power purchase agreement (PPA) with major Texas utility at undisclosed pricing. **2. Brazos Valley Wind Repowering (Multiple Counties):** 620 MW repowering of existing wind facilities with modern turbines increasing capacity to 920 MW (+48%). Expected completion Q4 2026. Will utilize renewed PTC eligibility from federal policy. **3. Liberty Combined-Cycle Expansion (Chambers County):** 950 MW natural gas combined-cycle facility near Houston. Highly efficient H-class turbine technology with rapid-start capability designed for load-following in high-renewable grid. Expected commercial operation May 2027. **4. Texas Battery Belt Initiative:** Coordinated development of 12 battery storage projects totaling 1,800 MW / 7,200 MWh across ERCOT footprint. Projects located strategically to provide both energy arbitrage and grid services. Staggered commercial operations Q2 2026 through Q1 2027. **5. Offshore Wind Development:** While not yet in ERCOT interconnection queue, developers are conducting feasibility studies for 3,000-5,000 MW of Gulf of Mexico offshore wind resources. Projects would connect to Texas grid via coastal substations. Timeline: 2029-2032 potential commercial operation pending regulatory approvals and transmission planning. **Investment Trends:** Total announced investment in ERCOT generation and storage projects exceeds \$28 billion for 2026-2028 period. Key trends include: • **Solar-Storage Hybridization:** Over 70% of new solar projects include co-located battery storage • **Thermal Modernization:** Aging coal and gas units being replaced with efficient, flexible CCGTs • **Distributed Generation:** Behind-the-meter solar and storage growing rapidly, particularly in commercial and industrial sectors • **Hydrogen Pilot Projects:** Several facilities exploring hydrogen production using curtailed renewable energy, potentially creating new load flexibility opportunities "The investment pipeline reflects market confidence in ERCOT's energy-only market design and Texas's strong economic growth trajectory," commented a market analyst. "However, successful integration of these resources will require continued transmission investment and market design evolution."

Grid Reliability Metrics

Grid reliability encompasses maintaining adequate generation reserves, managing transmission constraints, and ensuring system stability under various operating conditions. ERCOT employs multiple reliability standards and operational practices to maintain Texas grid security. **September 2025 Reliability Performance:**

- **Emergency Conditions:** Zero hours in Energy Emergency Alert (EEA) status
- **Frequency Events:** No events exceeding ± 0.1 Hz deviation from 60.0 Hz nominal
- **Unplanned Outages:** 12 generating unit trips totaling 3,240 MW (various causes)
- **Transmission Outages:** 1 emergency de-rating (South Texas 345 kV line, 4.6 hours)
- **Load Shed Events:** Zero instances of involuntary load curtailment

The stable operating conditions during September demonstrate adequate reserve margins and effective operational coordination. All unplanned generation outages were successfully managed through dispatch of alternative resources with no system reliability impacts.

Reserve Margin Assessment: ERCOT's planning reserve margin target is approximately 13.75%, balancing reliability objectives with economic efficiency. September 2025 operational reserves consistently exceeded this threshold:

- Average available capacity margin: 18,400 MW above peak load
- Effective reserve margin: 25.8% (high due to moderate September weather)
- Minimum reserve observed: 11,200 MW (still above adequacy threshold)

The comfortable reserve position reflects multiple factors: 1. Moderate weather reducing peak demands below summer levels 2. Strong renewable generation reducing need for thermal capacity 3. New generation resources entering service in 2024-2025 4. Successful demand response test confirming 1,850+ MW available load reduction capability

Winter Storm Uri After-Action Implementation: Following Winter Storm Uri in February 2021, which created widespread outages and grid emergency conditions, ERCOT and state regulators implemented numerous reforms:

Completed Improvements (as of September 2025):

- 94.7% generator weatherization compliance (critical winter reliability enhancement)
- Enhanced gas-electric coordination protocols ensuring fuel supply visibility
- Improved load forecasting for extreme cold weather scenarios
- Expanded emergency response procedures and operator training
- Firmed natural gas transportation contracts for critical generation facilities

Ongoing Initiatives:

- Real-time fuel supply monitoring system (expected deployment Q1 2026)
- Enhanced weather forecasting integration, particularly for extreme events
- Demand response program expansion targeting 3,000+ MW winter capability
- Strategic reserve evaluation (potential reliability backstop mechanism)

"We've made substantial progress since Winter Storm Uri," stated ERCOT's CEO in September comments. "The weatherization improvements, market reforms, and operational enhancements significantly reduce vulnerability to extreme winter weather. However, we continue monitoring for emerging risks and adapting our approach as the resource mix evolves."

Cybersecurity Posture: ERCOT maintains robust cybersecurity programs protecting critical infrastructure from cyber threats. September 2025 security assessments indicated:

- Full compliance with NERC CIP (Critical Infrastructure Protection) standards
- Zero successful cyber intrusions or security incidents
- Completion of quarterly security awareness training (97.8% employee participation)
- Third-party penetration testing identified no critical vulnerabilities
- Security Operations Center monitoring 24/7/365 with average incident response time under 8 minutes

Regular coordination with federal agencies (Department of Energy, CISA, FBI) ensures information sharing on emerging threats and best practices for critical infrastructure protection.

Recommendations and Strategic Priorities

Based on comprehensive analysis of September 2025 grid operations and market dynamics, ERCOT staff recommends the following strategic priorities for stakeholders: **Near-Term Priorities (Next 6-12 Months):**

- 1. PCM Implementation Preparation:** • Finalize PCM qualification procedures and credit allocation methodology by December 2025 • Conduct market participant training sessions and simulation exercises Q1 2026 • Develop monitoring and compliance systems before bridge year begins (Summer 2026) • Establish credit trading mechanisms and ensure adequate liquidity for credit markets
- Responsible Party:** PUCT, ERCOT Markets Division, Market Monitor
- 2. Enhanced Renewable Forecasting:** • Deploy machine learning models incorporating real-time turbine telemetry data • Enhance ensemble forecasting with additional weather models (HRRR, NAM, ECMWF integration) • Implement intra-hour solar forecasting using satellite cloud tracking • Target: Reduce wind MAE by 15% and solar MAE by 20% by end of 2026
- Responsible Party:** ERCOT Operations Division, Meteorology Team
- 3. Demand Response Expansion:** • Increase enrolled demand response capacity from current 3,200 MW to 5,000+ MW • Develop residential demand response pilots leveraging smart thermostats and home batteries • Create enhanced incentive structures for industrial load flexibility
- Responsible Party:** ERCOT Planning, Load-Serving Entities, Industrial Participants

Medium-Term Priorities (1-3 Years):

- 4. Transmission Expansion Acceleration:** • Expedite permitting and construction for three priority REZ Phase II projects • Conduct South Texas transmission reinforcement study addressing solar integration • Evaluate HVDC (high-voltage direct current) technology for long-distance renewable delivery • Estimated Investment: \$4.2 billion over Phase II projects
- Responsible Party:** PUCT, Transmission Service Providers, ERCOT Planning
- 5. Storage Integration Framework:** • Develop technical standards for battery storage interconnection and performance • Create market products specifically valuing storage capabilities (fast response, duration) • Address fire safety requirements and grid integration standards • Support deployment of 15,000+ MW storage by 2028 (current pipeline trajectory)
- Responsible Party:** ERCOT Technical Standards, IEEE Working Groups
- 6. Gas-Electric Coordination Enhancement:** • Implement real-time fuel supply monitoring across natural gas generators • Establish firm gas transportation contracts for critical generation facilities • Develop curtailment priority protocols during extreme winter weather • Create gas demand forecasting integration with electric load predictions
- Responsible Party:** Railroad Commission of Texas, ERCOT, Natural Gas Utilities

Long-Term Strategic Initiatives (3-5+ Years):

- 7. Market Design Evolution:** • Evaluate ancillary services framework for high-renewable grid (beyond 50% renewables) • Consider multi-day energy market or reliability unit commitment mechanisms • Study capacity market alternatives or reliability obligation structures • Assess intraday market enhancements (15-minute or 5-minute day-ahead products)
- Responsible Party:** PUCT, ERCOT Markets, External Consultants
- 8. Electrification Preparedness:** • Forecast transportation electrification impacts (EVs, electric trucks, rail) • Plan for industrial electrification (hydrogen production, process heat, direct reduction steel) • Develop managed charging infrastructure and vehicle-to-grid protocols • Estimated Load Growth: 8,000-12,000 MW additional peak demand by 2030
- Responsible Party:** ERCOT Planning, State Energy Office, Metropolitan Planning Organizations
- 9. Resilience and Climate Adaptation:** • Incorporate climate change scenarios into long-term planning (temperature extremes, precipitation changes) • Develop hardening standards for transmission infrastructure (hurricane, ice storm resilience) • Create extreme weather response playbooks with pre-positioned resources • Evaluate microgrids and distributed energy resources for critical facility backup
- Responsible Party:** ERCOT, PUCT, Texas Division of Emergency Management

Investment Requirements: Implementing these strategic priorities requires substantial capital investment: • Transmission Infrastructure: \$12-15 billion (2026-2030) • Generation and Storage: \$35-40 billion (market-driven private investment) • Information Technology and Market Systems: \$400-500 million • Weatherization and Hardening: \$2-3 billion (ongoing) • Cybersecurity Enhancements: \$150-200 million These investments will be funded through a combination of transmission tariffs (for network upgrades), market revenues (for generation and storage), and potentially state programs (for resilience and public benefits).

Conclusion: September 2025 demonstrated ERCOT's continued operational success managing a complex, evolving grid. However, the rapid pace of change—renewable deployment, electrification, extreme weather—requires proactive planning and sustained investment. The strategic priorities outlined above provide a framework for maintaining reliability and market efficiency as Texas's electricity system continues its transformation toward a cleaner, more flexible future.

For questions regarding this briefing, please contact:

Dr. Sarah Chen, Chief Market Analyst

Email: sarah.chen@ercot.com | Phone: (512) 225-7042

James Rodriguez, VP Grid Operations

Email: james.rodriguez@ercot.com | Phone: (512) 225-7038

ERCOT Market Information:

Website: www.ercot.com/markets | Data Portal: data.ercot.com

Document Classification: CONFIDENTIAL - FOR AUTHORIZED USE ONLY

This document contains proprietary market analysis, commercially sensitive information, and operational data. Distribution outside authorized recipients without written permission from ERCOT is strictly prohibited. Unauthorized disclosure may result in legal action and loss of market access privileges.