



Water Well Drilling Report

[View in Metric](#) [Export to Excel](#)

GIC Well ID 1022214
GoA Well Tag No.
Drilling Company Well ID #6167
Date Report Received 2011/12/22

GOWN ID

The driller supplies the data contained in this report. The Province disclaims responsibility for its accuracy. The information on this report will be retained in a public database.

Well Identification and Location										Measurement in Imperial	
Owner Name		Address			Town		Province		Country	Postal Code	
WATERLINE RESOURCES INC		531 24 AVE NW			CALGARY		ALBERTA		CANADA	T2M 1X4	
Location		1/4 or LSD	SEC	TWP	RGE	W of MER	Lot	Block	Plan	Additional Description	
1		24	24	2	5				P.W. 1		
Measured from Boundary of					GPS Coordinates in Decimal Degrees (NAD 83)						
ft from					Latitude 51.054120 Longitude -114.143540					Elevation ft	
ft from					How Location Obtained					How Elevation Obtained	
					Hand held autonomous GPS 20-30m					Not Obtained	

Drilling Information	
Method of Drilling	Type of Work
Rotary - Air	New Well
Proposed Well Use	
Dewatering	

Formation Log			Measurement in Imperial	
Depth from ground level (ft)	Water Bearing	Lithology Description		
2.00		Clay & Gravel		
23.00		Gravel		
36.00	Yes	Brown Sandstone		
51.00		Gray Shale		

Yield Test Summary			Measurement in Imperial	
Recommended Pump Rate			2.50 igpm	
Test Date	Water Removal Rate (igpm)	Static Water Level (ft)		
2006/10/28	0.50	32.70		

Well Completion				Measurement in Imperial	
Total Depth Drilled	Finished Well Depth	Start Date	End Date		
51.00 ft	51.00 ft	2006/10/27	2006/10/28		
Borehole					
Diameter (in)	From (ft)	To (ft)			
7.88	0.00	25.00			
6.13	25.00	51.00			
Surface Casing (if applicable)			Well Casing/Liner		
Steel			Plastic		
Size OD : 8.63 in			Size OD : 6.00 in		
Wall Thickness : 0.312 in			Wall Thickness : 0.500 in		
Bottom at : 25.00 ft			Top at : 19.00 ft		
			Bottom at : 51.00 ft		
Perforations					
From (ft)	To (ft)	Diameter or Slot Width(in)	Slot Length (in)	Hole or Slot Interval(in)	
Perforated by					
Annular Seal Cement/Grout					
Placed from 0.00 ft to 25.00 ft					
Amount 80.00 Gallons					
Other Seals					
Type			At (ft)		
Screen Type Plastic					
Size OD : 6.00 in					
From (ft)	To (ft)	Slot Size (in)			
26.00	46.00	0.020			
Attachment Attached To Riser					
Top Fittings Riser Pipe		Bottom Fittings Tail Pipe			
Pack					
Type Sand		Grain Size SIL 9			
Amount 10.00 Bags					

Contractor Certification			
Name of Journeyman responsible for drilling/construction of well		Certification No	
CHRIS QUINLAN		48135A	
Company Name		Copy of Well report provided to owner	
AARON DRILLING INC.		Yes	
		Date approval holder signed	
		2011/12/22	



Water Well Drilling Report

[View in Metric](#) [Export to Excel](#)

GIC Well ID 1022214
GoA Well Tag No.
Drilling Company Well ID #6167
Date Report Received 2011/12/22

GOWN ID

The driller supplies the data contained in this report. The Province disclaims responsibility for its accuracy. The information on this report will be retained in a public database.

Well Identification and Location										Measurement in Imperial	
Owner Name		Address			Town		Province		Country	Postal Code	
WATERLINE RESOURCES INC		531 24 AVE NW			CALGARY		ALBERTA		CANADA	T2M 1X4	
Location	1/4 or LSD	SEC	TWP	RGE	W of MER	Lot	Block	Plan	Additional Description		
1		24	24	2	5				P.W. 1		
Measured from Boundary of					GPS Coordinates in Decimal Degrees (NAD 83)						
ft from					Latitude 51.054120 Longitude -114.143540					Elevation ft	
ft from					How Location Obtained					How Elevation Obtained	
					Hand held autonomous GPS 20-30m					Not Obtained	

Additional Information										Measurement in Imperial
Distance From Top of Casing to Ground Level 0.00 in										
Is Artesian Flow										Is Flow Control Installed
Rate igpm										Describe
Recommended Pump Rate 2.50 igpm										Pump Installed
Recommended Pump Intake Depth (From TOC) 39.00 ft										Depth ft
										Type
										Make
										H.P.
										Model (Output Rating)
Did you Encounter Saline Water (>4000 ppm TDS)										Depth ft
Gas										Well Disinfected Upon Completion Yes
Remedial Action Taken										Depth ft
										Geophysical Log Taken
										Submitted to ESRD
Additional Comments on Well										Sample Collected for Potability
WELL IS IN MANHOLE IN THE CENTER OF THE ROAD WITH A SANITARY WELL SEAL.										Submitted to ESRD

Yield Test			Taken From Ground Level	Measurement in Imperial
			Depth to water level	
Test Date	Start Time	Static Water Level	Pumping (ft)	Elapsed Time
2006/10/28	11:00 AM	32.70 ft		Minutes:Sec
				Recovery (ft)
Method of Water Removal				
Type Air				
Removal Rate 0.50 igpm				
Depth Withdrawn From 50.00 ft				
If water removal period was < 2 hours, explain why				
LONG TERM WELL YIELD HAS BEEN DETERMINED BY THE SYSTEM DESIGN. THE PUMP IS SET TO PUMP ONLY WHAT THE WELL WILL PRODUCE, REGULATED BY A PRESSURE TRANSDUCER. RANDOM METER READINGS HAVE DETERMINED THE YIELD TO BE 2.5IGPM				

Water Diverted for Drilling		
Water Source	Amount Taken	Diversion Date & Time
	ig	

Contractor Certification			
Name of Journeyman responsible for drilling/construction of well		Certification No	
CHRIS QUINLAN		48135A	
Company Name		Copy of Well report provided to owner	Date approval holder signed
AARON DRILLING INC.		Yes	2011/12/22