

Guidelines for Canadian Drinking Water Quality

Summary Tables

March 2025

This document may be cited as follows:

Health Canada (2025). Guidelines for Canadian Drinking Water Quality—Summary Tables. Water and Air Quality Bureau, Healthy Environments and Consumer Safety Branch, Health Canada, Ottawa, Ontario.

The document was prepared by Health Canada in collaboration with the Federal-Provincial-Territorial Committee on Drinking Water of the Federal-Provincial-Territorial Committee on Health and the Environment.

Any questions or comments on this document may be directed to the following

Water and Air Quality Bureau
Healthy Environments and Consumer Safety Branch
Health Canada
Tel.: 1-833-223-1014 (toll free)
Fax: 613-952-2574
E-mail: hc.water-eau.sc@canada.ca

Other documents for the Guidelines for Canadian Drinking Water Quality can be found on the following web page:

<https://www.canada.ca/en/health-canada/services/environmental-workplace-health/reports-publications/water-quality.html>

Table of Contents

Introduction	1
Abbreviations	2
Tables	3
Table 1. Microbiological Parameters.....	3
Table 2. Chemical and Physical Parameters	7
Table 3. Radiological Parameters.....	33
Table 4. Guidance Documents	35
Table 5. Withdrawn Guidelines.....	38
Table 6. Guidelines and Guidance in Progress.....	41

Introduction

The Guidelines for Canadian Drinking Water Quality are established by Health Canada in collaboration with the [Federal-Provincial-Territorial Committee on Drinking Water](#) (CDW) and other federal government departments. Health Canada publishes the guidelines and other information on the website [Drinking water quality in Canada](#). The tables in this document summarize the values and key information from each of the guidelines. **Health Canada updates this document regularly, but you should always consult individual guideline technical documents and guidance documents on the website [Water Quality—Reports and Publications](#) for the most current information.**

Each guideline was established based on current, published scientific research related to health effects, aesthetic effects, and operational considerations. Guidelines (maximum acceptable concentrations or treatment goals) are based on a comprehensive review of the known health effects associated with each contaminant, on exposure levels and on the availability of treatment and analytical technologies. Aesthetic objectives (e.g., for taste or odour) are provided when they play a role in determining whether consumers will consider the water drinkable. Operational guidance values are provided when a substance may interfere with or impair a treatment process or technology (e.g., turbidity interfering with chlorination or UV disinfection) or adversely affect drinking water infrastructure (e.g., corrosion of pipes).

Guidelines for Canadian Drinking Water Quality are established specifically for contaminants that meet all of the following criteria:

1. Exposure to the contaminant could lead to adverse health effects in humans;
2. The contaminant is frequently detected or could be expected to be found in a large number of drinking water supplies throughout Canada; and
3. The contaminant is detected, or could be expected to be detected, in drinking water at a level that is of possible human health significance.

If a contaminant or issue of interest does not meet all these criteria, Health Canada and CDW may choose not to establish a numerical guideline or develop a guideline technical document. In that case, advice may be provided through a guidance document in order to convey operational or management information related to a contaminant or issue of concern.

Guidelines are [systematically reviewed](#) to assess the need to update them. When a guideline is reaffirmed, both the year of the original publication and the year of reaffirmation are shown below after the name of the parameter.

Abbreviations

A	acceptability (parameter type)
ALARA	as low as reasonably achievable
AO	aesthetic objective
CDW	Federal-Provincial-Territorial Committee on Drinking Water
D	disinfectant (parameter type)
DBP	disinfectant by-product (parameter type)
HPC	heterotrophic plate count
I	inorganic chemical (parameter type)
MAC	maximum acceptable concentration
NTU	nephelometric turbidity units
O	organic chemical (parameter type)
OG	operational guidance value
P	pesticide (parameter type)
QMRA	quantitative microbial risk assessment
T	treatment-related (parameter type)
TCU	true colour units

Tables

Table 1. Microbiological Parameters

In general, the highest priority guidelines are those dealing with microbiological contaminants, such as bacteria, protozoa and viruses. Since it is difficult to perform routine analysis of harmful microorganisms that might be present in inadequately treated drinking water, the microbiological guidelines focus on indicator organisms, such as E.coli and total coliforms, and treatment goals for pathogens. The use of a source-to-tap approach that includes source water protection, adequate treatment, and a well-maintained distribution system helps to reduce microorganisms to levels that have not been associated with illness and meet the guidelines outlined below.

Parameter (published, reaffirmed)	Guideline	Common Sources	Health Considerations	Applying the Guideline and Comments
Enteric protozoa: <i>Giardia</i> and <i>Cryptosporidium</i> (2019)	Treatment goal: Minimum 3 log removal and/or inactivation of cysts and oocysts	Human and animal feces	<i>Giardia</i> and <i>Cryptosporidium</i> are commonly associated with gastrointestinal upset (nausea, vomiting, and diarrhoea). Less common health effects vary. <i>Giardia</i> infections may include prolonged gastrointestinal upset, malaise and malabsorption. <i>Cryptosporidium</i> infections, in immunocompromised individuals, can occur outside the gastrointestinal tract.	Monitoring for <i>Cryptosporidium</i> and <i>Giardia</i> in source waters will provide valuable information for a risk-based assessment of treatment requirements. Depending on the source water quality, a greater log removal and/or inactivation may be required.
Enteric viruses (2019)	Treatment goal: Minimum 4 log reduction (removal and/or inactivation) of enteric viruses	Human feces	Commonly associated with gastrointestinal upset (nausea, vomiting, diarrhoea); less common health effects can include respiratory symptoms, central nervous system infections, liver	Enteric viruses have been detected in surface and groundwater sources. Routine monitoring for viruses is not practical, and assessing the vulnerability of source waters to

Parameter (published, reaffirmed)	Guideline	Common Sources	Health Considerations	Applying the Guideline and Comments
			infections and muscular syndromes.	viral contamination is difficult; thus, treatment is a way to reduce risk. Disinfection is a critical barrier.
<u><i>Escherichia coli</i></u> (<i>E. coli</i>) (2020)	MAC: None detectable per 100 mL	Human and animal feces	<i>E. coli</i> is an indicator of fecal contamination that is used as a tool to verify the quality of the drinking water. Its detection indicates recent fecal contamination and that microorganisms capable of causing gastrointestinal illnesses may also be present. Pathogens in human and animal feces pose the greatest immediate danger to public health.	In <u>water leaving a treatment plant</u> , the presence of <i>E. coli</i> indicates a serious breach in treatment. In a <u>distribution or storage system</u> , detection of <i>E. coli</i> can indicate that the water has become contaminated during distribution. In <u>non-disinfected groundwater</u> , the presence of <i>E. coli</i> indicates that the groundwater has been affected by fecal contamination. <i>E. coli</i> should be monitored in conjunction with other indicators, as part of a source-to-tap approach to producing drinking water of an acceptable quality.
<u>Total coliforms</u> (2020)	MAC of none detectable/100 mL in water leaving a treatment plant and in non- disinfected groundwater leaving the well	Human and animal feces; naturally occurring in water, soil and vegetation	Total coliforms are not used as indicators of potential health effects from pathogenic microorganisms; they are used as a tool to determine how well the drinking water treatment system is operating and to indicate water quality changes in the distribution system.	Total coliforms should be monitored in the distribution system because they are used to indicate changes in water quality. In <u>water leaving a treatment plant</u> , total coliforms should be measured in conjunction with other indicators to assess water quality; the presence of total coliforms

Parameter (published, reaffirmed)	Guideline	Common Sources	Health Considerations	Applying the Guideline and Comments
				<p>indicates a serious breach in treatment.</p> <p>In a <u>distribution and storage system</u>, detection of total coliforms can indicate regrowth of the bacteria in biofilms or intrusion of untreated water.</p> <p>Detection of total coliforms from consecutive samples from the same site or from more than 10% of the samples collected in a given sampling period should be investigated.</p> <p>In <u>non-disinfected groundwater</u>, the presence of total coliforms may indicate that the system is vulnerable to contamination, or it may be a sign of bacterial regrowth.</p>
<u>Turbidity</u> (2012)	<p>Treatment limits for individual filters or units:</p> <ul style="list-style-type: none"> - Conventional and direct filtration: ≤ 0.3 NTU¹ - slow sand and diatomaceous 	<p>Naturally occurring particles:</p> <p><i>Inorganic</i>: clays, silts, metal precipitates</p> <p><i>Organic</i>: decomposed plant & animal debris, microorganisms</p>	<p>Particles can harbour microorganisms, protecting them from disinfection, and can entrap heavy metals and biocides; elevated or fluctuating turbidity in filtered water can indicate a problem with the water treatment process and a potential increased risk of pathogens in treated water.</p>	<p>Guidelines apply to individual filter turbidity for systems using surface water or groundwater under the direct influence of surface water. The decision to exempt a waterworks from filtration should be made by the appropriate authority based on site-specific considerations, including historical</p>

Parameter (published, reaffirmed)	Guideline	Common Sources	Health Considerations	Applying the Guideline and Comments
	earth filtration: $\leq 1.0 \text{ NTU}^2$ - membrane filtration: $\leq 0.1 \text{ NTU}^3$			and ongoing monitoring data. To ensure effectiveness of disinfection and for good operation of the distribution system, it is recommended that water entering the distribution system have turbidity levels of 1.0 NTU or less. For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU.

¹ in at least 95% of measurements either per filter cycle or per month; never to exceed 1.0 NTU.

² in at least 95% of measurements either per filter cycle or per month; never to exceed 3.0 NTU.

³ in at least 99% of measurements per operational filter period or per month. Measurements greater than 0.1 NTU for a period greater than 15 minutes from an individual membrane unit should immediately trigger an investigation of the membrane unit integrity.

Table 2. Chemical Parameters

Guidelines for chemical parameters are the following:

1. health based and listed as maximum acceptable concentrations (MAC);
2. based on aesthetic considerations and listed as aesthetic objectives (AO);
3. established based on operational considerations and listed as operational guidance values (OG); or
4. established taking into account available treatment technology and analytical methods in order to reduce exposure through drinking water, and listed as objective (Objective).

In general, the highest priority guidelines are those dealing with microbiological contaminants. Any measure taken to reduce concentrations of chemical contaminants should not compromise the effectiveness of disinfection.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
T	Aluminum (2021)	2.9	OG: 0.1	Naturally occurring; aluminum salts used as coagulants in drinking water treatment; leaching from cement-based materials; dissolution of activated alumina media (where applicable)	Health basis of MAC: Neuromuscular effects (hind- and fore-limb grip strength, foot splay), urinary tract effects and general toxicity.	The MAC and OG apply to all drinking water supplies (including groundwater) and are to be applied as locational running annual averages. The OG value is established to minimize the potential for the accumulation and release of metals in the distribution system and to avoid other operational and aesthetic issues. It takes treatment achievability into consideration.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
I	Ammonia (2013)	None required		Naturally occurring; released from agricultural or industrial wastes; added as part of chloramination for drinking water disinfection	Levels of ammonia, either naturally present in the source water or added as part of a disinfection strategy, can affect water quality in the distribution system (e.g., nitrification) and should be monitored. A guideline value is not necessary as it is produced in the body and efficiently metabolized in healthy people; no adverse effects at levels found in drinking water.	To help prevent nitrification, limit excess free ammonia entering the distribution system to below 0.1 mg/L, and preferably below 0.05 mg/L, measured as nitrogen. Nitrification can lead to the formation of nitrite/nitrate, decreased chloramine residual and increased bacterial count.
I	Antimony (2024)	0.006		Naturally occurring (erosion); soil runoff; industrial effluents; leaching from plumbing materials and solder	Health basis of MAC: Changes in liver histology (anisokaryosis) along with the changes in serum biochemistry (which together are indicative of a change in liver function)	MAC takes into consideration anticipated treatment challenges for private wells and small systems.
I	Arsenic (2006)	0.010 ALARA		Naturally occurring (erosion and weathering of soils, minerals, ores); releases from mining; industrial effluent	Health basis of MAC: Cancer (lung, bladder, liver, skin) (classified as human carcinogen)	MAC based on treatment achievability; elevated levels associated with certain groundwaters; levels should be kept as

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
					Other: Skin, vascular and neurological effects (numbness and tingling of extremities)	low as reasonably achievable.
I	Asbestos (1989, 2005)	None required		Naturally occurring (erosion of asbestos minerals and ores); decay of asbestos-cement pipes		Guideline value not necessary; no evidence of adverse health effects from exposure through drinking water.
P	Atrazine (1993)	0.005		Leaching and/or runoff from agricultural use	Health basis of MAC: Developmental effects (reduced body weight of offspring) Other: Potential increased risk of ovarian cancer or lymphomas (classified as possible carcinogen)	MAC applies to sum of atrazine and its <i>N</i> -dealkylated metabolites - diethylatrazine, deisopropylatrazine, hydroxyatrazine, diaminochlorotriazine; Persistent in source waters.
I	Barium (2020)	2.0		Naturally occurring; releases or spills from industrial uses	Health basis of MAC: Kidney effects	MAC is for total barium and takes into consideration exposure estimates from all sources.
O	Benzene (2009)	0.005		Releases or spills from industrial uses	Health basis of MAC: Bone marrow (red and white blood cell) changes	MAC takes into consideration all exposures from drinking water, which include

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
					and cancer (classified as human carcinogen) Other: Blood system and immunological responses	ingestion, as well as inhalation and dermal absorption during showering and bathing.
O	Benzo[a]pyrene (2016)	0.000 04		Leaching from liners in water distribution systems	Health basis of MAC: Stomach tumours (classified as human carcinogen)	
I	Boron (2023)	5		Naturally occurring; leaching or runoff from industrial use	Health basis of MAC: Reproductive effects in males (testicular atrophy, decreased testes to body weight ratio, spermatogenic arrest) Other: Developmental effects	MAC based on treatment achievability.
DBP	Bromate (2018)	0.01		Contaminant in hypochlorite solution; by-product of drinking water disinfection with ozone	Health basis of MAC: Tumours of the testicular mesothelium (classified as a possible human carcinogen)	Efforts to reduce bromate concentrations must not compromise the effectiveness of disinfection. Bromate is difficult to remove from drinking water once formed. The recommended strategy is controlling the ozonation process; use of certified treatment chemicals and;

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
						appropriate handling and storage of hypochlorite. Quarterly monitoring of raw water bromide is recommended to allow correlation to bromate or brominated DBPs.
P	Bromoxynil (2022)	0.03		Leaching and/or runoff from agricultural use	Health basis of MAC: Increased clinical signs (panting, salivation, liquid feces, pale gums) and liver weight, as well as both decreases in body weight and body weight gain	None
I	Cadmium (2020)	0.007		Leaching from galvanized pipes and solders; industrial and municipal waste	Health basis of MAC: Kidney damage. Other: Bone effects (decreased bone density)	MAC is for total cadmium and takes into consideration exposure estimates from all sources. Sampling should be done at the tap to reflect average exposure similar to sampling done for lead. The contribution of cadmium in drinking water is generally from the galvanized steel used in pipes and well

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
						components. The best approach to minimize exposure to cadmium from drinking water is to replace galvanized steel and components. Drinking water treatment devices are also an effective option.
I	Calcium (1987, 2005)	None required		Naturally occurring (erosion and weathering of soils, minerals, ores)	No evidence of adverse health effects from calcium in drinking water.	Guideline value not necessary; calcium contributes to hardness.
O	Carbon tetrachloride (2010)	0.002		Industrial effluents and leaching from hazardous waste sites	Health basis of MAC: Liver toxicity Other: Kidney damage; liver tumours (classified as probable carcinogen)	MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing.
D	Chloramines (2020)	None required		Monochloramine is used as a secondary disinfectant; formed in drinking water when chlorine is added in the presence of ammonia	Guideline value not necessary due to low toxicity at concentrations found in drinking water	Chloramine residuals in most Canadian drinking water distribution systems are typically below 4 mg/L.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
DBP	Chlorate (2008)	1		By-product of drinking water disinfection with chlorine dioxide; possible contaminant in hypochlorite solution	Health basis of MAC: Thyroid gland effects (colloid depletion)	As chlorate is difficult to remove once formed, its formation should be controlled by respecting the maximum feed dose of 1.2 mg/L of chlorine dioxide and managing /monitoring formation in hypochlorite solutions.
I	Chloride (1979, 2005)		AO: ≤ 250	Naturally occurring (seawater intrusion); dissolved salt deposits, highway salt, industrial effluents, oil well operations, sewage, irrigation drainage, refuse leachates	A guideline value is not necessary as health effects are not of concern at levels found in drinking water.	Based on taste and potential for corrosion in the distribution system.
D	Chlorine (2009)	None required		Used as drinking water disinfectant	A guideline value is not necessary due to low toxicity at concentrations found in drinking water	Free chlorine concentrations in most Canadian drinking water distribution systems range from 0.04 to 2.0 mg/L.
D	Chlorine dioxide (2008)	None required		Used as drinking water disinfectant (primary disinfection only)	A guideline value for chlorine dioxide is not required because of its rapid reduction to chlorite in drinking water	A maximum feed dose of 1.2 mg/L of chlorine dioxide should not be exceeded to control the formation of chlorite and chlorate.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
DBP	Chlorite (2008)	1		By-product of drinking water disinfection with chlorine dioxide	Health basis of MAC: Neurobehavioural effects (lowered auditory startle amplitude, decreased exploratory activity), decreased absolute brain weight, altered liver weights	Chlorite formation should be controlled by respecting the maximum feed dose of 1.2 mg/L of chlorine dioxide and managing /monitoring formation in hypochlorite solutions.
P	Chlorpyrifos (1986)	0.09	None	Leaching and/or runoff from agricultural or other uses	Health basis of MAC: Nervous system effects (cholinesterase inhibition)	Not expected to leach significantly into groundwater.
I	Chromium (2018)	0.05		Naturally occurring (erosion of minerals); releases or spills from industrial uses	Health basis of MAC: Hyperplasia of the small intestine from chromium (VI). Other: No definitive evidence of toxicity to Chromium (III).	MAC protects against both cancer and non-cancer effects from Chromium (VI) and is established for total chromium.
T	Colour (1979, 2005)		AO: ≤ 15 TCU	Naturally occurring organic substances, metals; industrial wastes	A guideline value is not necessary as health effects are not of concern at levels found in drinking water.	May interfere with disinfection; removal is important to ensure effective treatment.
I	Copper (2019)	2	AO: 1	Naturally occurring; leaching from copper piping	Health basis of MAC: Gastrointestinal effects	Water samples should be taken at the tap. MAC is for total copper and

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
					(short-term), liver and kidney effects (long-term).	protects against both short term and long term exposures. AO is based on taste and water discolouration (resulting in staining of laundry and plumbing fixtures).
I	Cyanide (1979, 1991)	0.2		Industrial and mining effluents; release from organic compounds	Health basis of MAC: No clinical or other changes at the highest dose tested	At the levels seen in Canadian waters, cyanide is not a concern as it can be detoxified to a certain extent in the human body.
O	Cyanobacterial toxins (2018)	0.0015		Naturally occurring - released from populations of cyanobacteria (planktonic blooms and benthic mats)	Health basis of MAC: Liver effects	MAC is for total microcystins (intra- and extra-cellular) Note that infants can ingest a significantly larger volume of water per body weight. As a precautionary measure, where levels of total microcystins in treated water are detected above a reference value of 0.4 µg/L, the public in the affected area should use an alternate suitable source of drinking water

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
						(such as bottled water) to reconstitute infant formula.
P	Dicamba (2022)	0.11		Leaching or runoff from agricultural or other uses	Health basis of MAC: Clinical chemistry and inflammation of the prostate	Readily leaches into groundwater.
O	1,4-Dichlorobenzene <small>Table 2 footnote2</small> (1987)	0.005	AO: ≤ 0.001	Releases or spills from industrial effluents; use of urinal deodorants	Health basis of MAC: Benign liver tumours and adrenal gland tumours (classified as probable carcinogen)	AO based on odour; levels above the AO would render drinking water unpalatable.
O	1,2-Dichloroethane (2014)	0.005		Releases or spills from industrial effluents; leachate from waste disposal	Health basis of MAC: Cancer of the mammary gland (classified as probable carcinogen)	The MAC protects against both cancer and non-cancer effects and takes into consideration all exposures from drinking water, which include ingestion as well as inhalation and dermal absorption during showering and bathing.
O	Dichloromethane (2011)	0.05		Industrial and municipal wastewater discharges	Health basis of MAC: Liver effects (liver foci and areas of cellular alteration).	The MAC protects against both cancer and non-cancer effects and takes into consideration all exposures from drinking

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
					Other: Classified as probable carcinogen	water, which include ingestion as well as inhalation and dermal absorption during showering and bathing.
P	2,4-Dichlorophenoxy acetic acid (2,4-D) (2022)	0.1		Leaching and/or runoff from agricultural and non- cropland use	Health basis of MAC: Kidney effects	High potential to leach into groundwater.
P	Dimethoate and omethoate (2022)	0.02		Leaching and/or runoff from agricultural and non-agricultural use	Health basis of MAC: Nervous system effects (cholinesterase inhibition)	MAC is for dimethoate. An additive approach should be taken in which the sum of the detected concentrations of dimethoate and omethoate (expressed as a dimethoate equivalent value) does not exceed the MAC for dimethoate.
O	1,4-Dioxane (2021)	0.050		Generally not detected in Canadian water supplies, but there have been contaminations of drinking water supplies near landfills and industrial sites	Health basis of MAC: liver effects that occur before the development of cancer	1,4 Dioxane is difficult to remove using conventional drinking water treatment. Treatment technologies such as advanced oxidation processes and synthetic adsorbents

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
						need to be considered. Reverse osmosis membranes may be capable of removing 1,4- dioxane at both the municipal and residential scale.
P	Diquat (2022)	0.05		Leaching and/or runoff from agricultural use; added directly to water to control aquatic weeds	Health basis of MAC: Cataract formation	Unlikely to leach into groundwater.
O	Ethylbenzene (2014)	0.14	AO: 0.0016	Emissions, effluents or spills from petroleum and chemical industries	Health basis of MAC: Effects on the liver and pituitary gland. Other: Tumour formation at various sites in animals, including kidney, lung, liver and testes.	MAC protects against both cancer and non- cancer health effects. MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing. AO is based on odour.
I	Fluoride (2010)	1.5		Naturally occurring (rock and soil erosion); may be added to promote dental health	Basis of MAC: Moderate dental fluorosis (based on cosmetic effect, not health)	Beneficial in preventing dental caries.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
DBP	Formaldehyde (1997)	None required		By-product of disinfection with ozone; releases from industrial effluents	A guideline value is not necessary as health effects are not of concern at levels found in drinking water.	A guideline value is not necessary, as levels in drinking water are below the level at which adverse health effects may occur.
P	Glyphosate (1987, 2005)	0.28		Leaching and/or runoff from various uses in weed control	Health basis of MAC: Reduced body weight gain	Not expected to migrate to groundwater.
DBP	Haloacetic acids - Total (HAAs) <small>Table 2</small> <small>footnote3</small> (2008)	0.08 ALARA		By-product of drinking water disinfection with chlorine	Health basis of MAC: Liver cancer (DCA); DCA is classified as probably carcinogenic to humans Other: Other organ cancers (DCA, DBA, TCA); liver and other organ effects (kidney and testes weights) (MCA)	Refers to the total of monochloroacetic acid (MCA), dichloroacetic acid (DCA), trichloroacetic acid (TCA), monobromoacetic acid (MBA) and dibromoacetic acid (DBA); MAC is based on ability to achieve HAA levels in distribution systems without compromising disinfection; precursor removal limits formation.
T	Hardness (1979)	None required		Naturally occurring (sedimentary rock erosion and seepage, runoff from soils); levels generally higher in groundwater	Although hardness may have significant aesthetic effects, a guideline has not been established because public	Hardness levels between 80 and 100 mg/L (as CaCO ₃) provide acceptable balance between corrosion and

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
					acceptance of hardness may vary considerably according to the local conditions; major contributors to hardness (calcium and magnesium) are not of direct public health concern	incrustation; where a water softener is used, a separate unsoftened supply for cooking and drinking purposes is recommended.
I	Iron (1978, 2005, 2024)		AO: ≤ 0.1	Naturally occurring (erosion and weathering of rocks and minerals and in groundwater due to geological processes); Released from iron-based drinking water materials or as iron corrosion by-products and in water treatment processes. Human activities such as mine drainage water, acid mine effluents and agricultural runoff.	A guideline value is not necessary as health effects are not of concern at levels found in drinking water and at the level at which the AO is set.	AO is for total iron and is based on minimizing the occurrence of discoloured water and to improve consumer confidence in drinking water quality. Removal of iron also improves the removal of manganese, reducing the health risk associated with this metal.
I	Lead (2019)	0.005 ALARA		Leaching from plumbing (lead service lines, lead solder and brass fittings)	Health basis of MAC: Reduced intelligence in children measured as decreases in IQ is the most sensitive and well established health effect of lead exposure. There is	MAC is for total lead. Lead levels should be kept as low as reasonably achievable. Sampling should be done at the tap to reflect average exposure. The most

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
					no known safe exposure level to lead. Other: Possible effects include behavioral effects in children. Reduced cognition, increased blood pressure, and renal dysfunction in adults are also possible; classified as probably carcinogenic to humans	significant contribution of lead in drinking water is generally from the lead service line that supplies drinking water to the home. The best approach to minimize exposure to lead from drinking water is to remove the full lead service line. Drinking water treatment devices are also an effective option.
I	Magnesium (1978)	None required		Naturally occurring (erosion and weathering of rocks and minerals)	No evidence of adverse health effects from magnesium in drinking water, therefore a guideline value is not necessary.	No additional comments.
P	Malathion (2023)	0.29		Leaching and/or runoff from agricultural and other uses	Health basis of MAC: Kidney effects (increase in severity of chronic progressive nephropathy) Other: Nervous system effects	Unlikely to leach into groundwater. When using oxidation or advanced oxidation processes for malathion removal, water utilities should be aware of the potential for formation of degradation by products.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
I	Manganese (2019)	0.12	AO: ≤ 0.02	Dissolution of naturally occurring minerals commonly found in soil and rock. Other sources include industrial discharge, mining activities and leaching from landfills.	Health Basis of MAC: Effects on neurological development and behaviour; deficits in memory, attention, and motor skills. Other: Formula-fed infants (where water containing manganese at levels above the MAC is used to prepare formula) may be especially at risk.	AO based on minimizing the occurrence of discoloured water, consumer complaints and staining of laundry.
I	Mercury (1986)	0.001		Releases or spills from industrial effluents; waste disposal; irrigation or drainage of areas where agricultural pesticides are used	Health basis of MAC: Irreversible neurological symptoms	Applies to all forms of mercury; mercury generally not found in drinking water, as it binds to sediments and soil.
P	2-Methyl-4-chlorophenoxyacetic acid (MCPA) (2022)	0.35		Leaching and/or runoff from agricultural and other uses	Health basis of MAC: Kidney effects (increased absolute and relative weights, urinary bilirubin, crystals and pH) Other: Systemic, liver, testicular, reproductive/developmental and nervous system effects	Can potentially leach into groundwater.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
O	Methyl tertiary-butyl ether (MTBE) (2006)		AO: ≤ 0.015	Spills from gasoline refineries, filling stations and gasoline-powered boats; seepage into groundwater from leaking storage tanks	The AO is lower than levels associated with potential toxicological effects, it is considered protective of human health. Studies on toxic effects remain inconclusive.	AO based on odour; levels above the AO would render water unpalatable.
P	Metribuzin (2021)	0.08		Leaching and/or runoff from agricultural use	Health basis of MAC: Liver effects (increased ornithine carboxytransferase, increased incidence and severity of mucopolysaccharide droplets, hepatic necrobiosis)	Leaching into groundwater depends on topography, precipitation and site-specific soil characteristic such as organic matter content and soil pH.
I	Nitrate (2013)	45 as nitrate; 10 as nitrate-nitrogen		Naturally occurring; leaching or runoff from agricultural fertilizer use, manure and domestic sewage; may be produced from excess ammonia or nitrification in the distribution system	Health basis of MAC: Methaemoglobinaemia (blue baby syndrome) and effects on thyroid gland function in bottle-fed infants Other: Classified as possible carcinogen under conditions that result in endogenous nitrosation	Systems using chloramine disinfection or that have naturally occurring ammonia should monitor the level of nitrate in the distribution system. Homeowners with a well should test concentration of nitrate in their water supply.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
I	Nitrilotriacetic acid (NTA) (1990)	0.4		Sewage contamination	Health basis of MAC: Kidney effects (nephritis and nephrosis) Other: Classified as possible carcinogen	MAC is based upon exposure mainly attributable (80%) to drinking water with 20% of exposure attributable to food.
I	Nitrite (2013)	3 as nitrite; 1 as nitrite-nitrogen		Naturally occurring; leaching or runoff from agricultural fertilizer use, manure and domestic sewage; may be produced from excess ammonia or nitrification in the distribution system	Health basis of MAC: Methaemoglobinaemia (blue baby syndrome) in bottle-fed infants less than 6 months of age Other: Classified as possible carcinogen under conditions that result in endogenous nitrosation	Systems using chloramine disinfection or that have naturally occurring ammonia should monitor the level of nitrite in the distribution system. Homeowners with a well should test concentration of nitrite in their water supply.
DBP	N-Nitroso dimethylamine (NDMA) (2010)	0.000 04		By-product of drinking water disinfection with chlorine or chloramines; industrial and sewage treatment plant effluents	Health basis of MAC: Liver cancer (classified as probable carcinogen)	MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing.; levels should be kept low by preventing formation during treatment.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
A	Odour (1979, 2005)		Inoffensive	Biological or industrial sources	Not applicable	Important to provide drinking water with no offensive odour, as consumers may seek alternative sources that are less safe.
O	Pentachlorophenol (1987, 2005)	0.06	AO: ≤ 0.03	By-product of drinking water disinfection with chlorine; industrial effluents	Health basis of MAC: Reduced body weight, changes in clinical parameters, histological changes in kidney and liver, reproductive effects (decreased neonatal survival and growth)	AO based on odour; levels above the AO would render drinking water unpalatable.
O	Per-and polyfluoroalkyl substances (PFAS) (2024)	None	Objective : 0.00003 ALARA	Synthetic chemicals used in consumer products and fire-fighting foams for their water and oil repellent properties.	Certain PFAS may have effects on the liver, immune system, kidney, reproduction, development, endocrine system (thyroid), the nervous system, and metabolism (lipids, glucose homeostasis, body weight). The lower the levels of exposure to PFAS, the	The objective is based on analytical and treatment achievability and applies to the sum of 25 specified PFAS. If measurements of PFAS in drinking water are approaching or exceed the 30 ng/L objective, it may be useful to examine the types of PFAS that are

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
					lower the risk to public health.	present in the greatest concentrations. When treatment is required, it is also recommended that treatment plants strive to maintain PFAS concentrations in drinking water as low as reasonably achievable (ALARA).
T	pH (2015)		7.0–10.5 ⁴	Not applicable	Not applicable	The control of pH is important to maximize treatment effectiveness, control corrosion and reduce leaching from distribution system and plumbing components.
I	Selenium (2014)	0.05		Naturally occurring (erosion and weathering of rocks and soils) and release from coal ash from coal-fired power plants and mining, refining of copper and other metals.	Health basis of MAC: chronic selenosis symptoms in humans following exposure to high levels Other: Hair loss, tooth decay, weakened nails and nervous system	Selenium is an essential nutrient. Most exposure is from food; little information on toxicity of selenium from drinking water. Selenium can be found in non-leaded brass alloy where it is added to replace lead.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
					disturbances at extremely high levels of exposure	
I	Silver (1986, 2005)	None required		Naturally occurring (erosion and weathering of rocks and soils)	Not applicable	Guideline value not required as drinking water contributes negligibly to an individual's daily intake.
I	Sodium (1979)		AO: ≤ 200	Naturally occurring (erosion and weathering of salt deposits and contact with igneous rock, seawater intrusion); sewage and industrial effluents; sodium-based water softeners	For persons on strict sodium-reduced diets applying to all sources, levels in drinking water should be below 20 mg/L	Based on taste; where a sodium-based water softener is used, a separate unsoftened supply for cooking and drinking purposes is recommended.
I	Strontium (2019)	7.0		Naturally occurring (erosion and weathering of rocks); effluents from mining or other industries	Health basis of MAC: Bone effects (adverse effects on bone formation in infants as well as rickets, osteomalacia)	MAC is protective of the most sensitive sub-population, infants.
I	Sulphate (1994)		AO: ≤ 500	Industrial wastes	High levels (above 500 mg/L) can cause physiological effects such as diarrhoea or dehydration	Based on taste; it is recommended that health authorities be notified of drinking water sources containing sulphate concentrations above 500 mg/L.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
I	Sulphide (1992)		AO: ≤ 0.05	Can occur in the distribution system from the reduction of sulphates by sulphate-reducing bacteria; industrial wastes	Not applicable	Based on taste and odour; levels above the AO would render water unpalatable.
A	Taste (1979, 2005)		Inoffensive	Biological or industrial sources	Not applicable	Important to provide drinking water with no offensive taste, as consumers may seek alternative sources that are less safe.
O	Tetrachloroethylene (2015)	0.01		Spill or other point source of contamination	Health basis of MAC: Neurological effects (colour confusion) in humans Other: Classified as probably carcinogenic to humans, based on sufficient evidence in experimental animals and limited evidence in humans	Primarily a concern in groundwater, as it volatilizes easily from surface water; MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing.
O	Toluene (2014)	0.06	AO: 0.024	Emissions, effluents or spills from petroleum and chemical industries	Health basis of MAC: Adverse neurological effects, including vibration thresholds, colour discrimination, auditory thresholds, attention,	MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
					memory and psychomotor functions Other: Insufficient information to determine whether toluene is carcinogenic to humans.	absorption during showering and bathing. AO is based on odour.
A	Total dissolved solids (TDS) (1991)		AO: ≤ 500	Naturally occurring; sewage, urban and agricultural runoff, industrial wastewater	Not applicable	Based on taste; TDS above 500 mg/L results in excessive scaling in water pipes, water heaters, boilers and appliances; TDS is composed of calcium, magnesium, sodium, potassium, carbonate, bicarbonate, chloride, sulphate and nitrate.
O	Trichloroethylene (2005)	0.005		Industrial effluents and spills from improper disposal	Health basis of MAC: Developmental effects (heart malformations) Other: Classified as probable carcinogen	MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
O	2,4,6-Trichlorophenol (1987, 2005)	0.005	AO: ≤ 0.002	By-product of drinking water disinfection with chlorine; industrial effluents and spills	Health basis of MAC: Liver cancer (classified as probable carcinogen)	AO based on odour; levels above the AO would render drinking water unpalatable.
DBP	Trihalomethanes) <small>Table 2</small> <small>footnote3</small> (THMs) (2006)	0.1		By-product of drinking water disinfection with chlorine; industrial effluents	Health basis of MAC: Liver effects (fatty cysts) (chloroform classified as possible carcinogen) Other: Kidney and colorectal cancers	Refers to the total of chlorodibromomethane, chloroform, bromodichloromethane and bromoform; MAC based on health effects of chloroform. MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing. Utilities should make every effort to maintain concentrations as low as reasonably achievable without compromising the effectiveness of disinfection. Recommended strategy is precursor removal. The separate MAC for BDCM

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
						was rescinded in April 2009.
I	Uranium (2019)	0.02		Naturally occurring (erosion and weathering of rocks and soils); mill tailings; emissions from nuclear industry and combustion of coal and other fuels; phosphate fertilizers	Health basis of MAC: Kidney effects	Based on challenges and operational cost impacts for some private wells and small systems; MAC is for total uranium and is protective in relation to both chemical and radiological hazards.
O	Vinyl chloride (2013)	0.002 ALARA		Industrial effluents; degradation product from organic solvents in groundwater; leaching from polyvinyl chloride pipes	Health basis of MAC: Liver cancer (classified as human carcinogen) Other: Raynaud's disease, effects on bone, circulatory system, thyroid, spleen, central nervous system	Based on analytical achievability. MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing. Leaching from polyvinyl chloride pipe is not expected to be significant.
O	Xylenes (total) (2014)	0.09	AO: 0.02	Emissions, effluents or spills from petroleum and chemical industries	Health basis of MAC: Adverse neuromuscular effects Other: Insufficient information to determine	MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
					whether xylenes are carcinogenic to humans	absorption during showering and bathing. AO is based on odour.
I	Zinc (1979, 2005)		AO: ≤ 5.0	Naturally occurring; industrial and domestic emissions; leaching may occur from galvanized pipes, hot water tanks and brass fittings	Zinc is an essential element and is generally considered to be non- toxic, however levels above the AO in water would render it unpalatable.	AO based on taste; water with zinc levels above the AO tends to be opalescent and develops a greasy film when boiled; plumbing should be thoroughly flushed before water is consumed.

¹ Parameter types: **A** – Acceptability; **D** – Disinfectant; **DBP** – Disinfection by-product; **P** – Pesticide; **I** – Inorganic chemical; **O** – Organic chemical; **T** – Treatment related parameter.

In cases where total dichlorobenzenes are measured and concentrations exceed the most stringent value (0.005 mg/L), the concentrations of the individual isomers should be established.

³ Expressed as a locational running annual average of quarterly samples.

⁴ No units.

Table 3. Radiological Parameters

Guidelines for radiological parameters focus on routine operational conditions of existing and new water supplies and do not apply in the event of contamination during an emergency involving a large release of radionuclides into the environment. MACs have been established for the most commonly detected natural and artificial radionuclides in Canadian drinking water sources, using internationally accepted equations and principles and based solely on health considerations.

The MACs are based on exposure solely to a specific radionuclide. The radiological effects of two or more radionuclides in the same drinking water source are considered to be additive. Thus, the sum of the ratios of the observed concentration to the MAC for each contributing radionuclide should not exceed 1.

Water samples may be initially analysed for the presence of radioactivity using gross alpha and gross beta screening rather than measurements of individual radionuclides. If screening levels are exceeded (0.5 Bq/L for gross alpha and 1.0 Bq/L for gross beta), then concentrations of specific radionuclides should be analysed. A guideline for radon in drinking water is not deemed necessary and has not been established. Information on radon is presented because of its significance for indoor air quality in certain situations.

Parameter (published, reaffirmed)	MAC (Bq/L)	Common sources	Health basis of MAC	Comments
<u>Cesium-137</u> (2009)	10	Nuclear weapons fallout and emissions from nuclear reactors	Cancer of the lung, breast, thyroid, bone, digestive organs and skin; leukaemia	Fixation by sediments in aquatic environments reduces its concentration in water bodies. Ingested ¹³⁷ Cs is readily absorbed into soft tissues, but is eliminated relatively quickly.
<u>Iodine-131</u> (2009)	6	Sewage effluent	Cancer of the lung, breast, thyroid, bone, digestive organs and skin; leukaemia	No additional comments
<u>Lead-210</u> (2009)	0.2	Naturally occurring (decay product of radon)	Cancer of the lung, breast, thyroid, bone, digestive organs and skin; leukaemia	Corresponds to total lead concentration of 7×10^{-8} µg/L

Parameter (published, reaffirmed)	MAC (Bq/L)	Common sources	Health basis of MAC	Comments
<u>Radium-226</u> (2009)	0.5	Naturally occurring	Cancer of the lung, breast, thyroid, bone, digestive organs and skin; leukaemia	No additional comments
<u>Radon</u> (2009)	None required	Naturally occurring (leaching from radium-bearing rocks and soils; decay product of radium-226)	Health risk from ingestion considered negligible due to high volatility	Mainly a groundwater concern; if concentrations in drinking water exceed 2000 Bq/L actions should be taken to reduce release into indoor air (e.g. proper venting of drinking water supply)
<u>Strontium-90</u> (2009)	5	Nuclear weapons fallout	Cancer of the lung, breast, thyroid, bone, digestive organs and skin; leukaemia	Has a long residence time in bone and its beta particles have high energy. Radioactive strontium (90Sr) should not be confused with stable strontium. The two species of strontium have quite different origins, and their concentrations in drinking water are not correlated.
<u>Tritium</u> (2009)	7000	Naturally occurring (cosmogenic radiation); releases from nuclear reactors	Cancer of the lung, breast, thyroid, bone, digestive organs and skin; leukaemia	Not removed by drinking water treatment
<u>Uranium</u> (1999)	N/A		MAC based on chemical properties	See information provided in Table 2

Table 4. Guidance Documents

In certain situations, Health Canada, in collaboration with the Federal-Provincial-Territorial Committee on Drinking Water, may choose to develop guidance documents for issues that do not meet the criteria for guideline development and for specific issues for which operational or management guidance is warranted. These documents are offered as information for drinking water authorities and help provide guidance relating to contaminants, drinking water management issues or emergency situations.

Parameter/subject (published)	Comments
Chloral hydrate in drinking water (2008)	Exposure levels in Canada far below concentration that would cause health effects; levels above 0.2 mg/L may indicate a concern for health effects and should be investigated.
Controlling corrosion in drinking water distribution systems (2009, 2025)	Addresses sampling and mitigation measures to address lead leaching and release from materials in the distribution system; sampling protocols can be used to assess corrosion and the effectiveness of mitigation/control measures to reduce lead levels in drinking water; corrective measures are outlined to address lead sources to minimize exposure to lead.
Issuing and rescinding boil water advisories in Canadian drinking water supplies (2015)	Summarizes factors for consideration when responsible authorities issue or rescind boil water advisories. Provides trend information on reasons boil water advisories are issued in Canada.
Issuing and rescinding drinking water avoidance advisories in emergency situations (2009)	Summarizes factors for consideration when responsible authorities issue or rescind drinking water avoidance advisories in emergency situations.
Monitoring the Biological Stability of Drinking Water in Distribution Systems (2022)	Distribution systems represent a complex and dynamic environment. Monitoring changes in biological stability in these systems is important to minimize potential risks to consumers. This guidance document discusses (1) the concept of biological stability, (2) causes of water quality deterioration in the distribution system, (3) health risks (e.g., waterborne outbreaks) and aesthetic issues (e.g., colour) associated with this deterioration, (4) monitoring tools and parameters that can be used to assess biological stability, and (5) distribution system management strategies to minimize public health risks. This guidance document replaces the Guidance on the Use of Heterotrophic Plate Counts in Canadian Drinking Water Supplies.

Parameter/subject (published)	Comments
Natural organic matter in drinking water (NOM) (2020)	The presence and characteristics of natural organic matter (NOM) can have significant impacts on drinking water treatment processes, and consequently the safety of drinking water. Seasonal and weather-related events can significantly affect the concentration and character of NOM. This guidance document reviews and assesses: 1) the impacts of NOM and the associated indirect health risks; 2) source-specific treatability study requirements to ensure the most appropriate process is selected to meet treated water quality goals; 3) treatment options and their effectiveness; 4) tools available to monitor raw, treated and distribution system water quality.
Overview of the Microbiological Aspects of Drinking Water Quality (2021)	Provides an overview of the microbiological considerations to ensure drinking water quality, integrating key content of the relevant guideline technical documents and guidance documents to illustrate how they fit into the source-to-tap approach.
Potassium from water softeners (2008)	Not a concern for general population; those with kidney disease or other conditions, such as heart disease, coronary artery disease, hypertension or diabetes, and those who are taking medications that interfere with normal body potassium handling should avoid the consumption of water treated by water softeners using potassium chloride.
Temperature aspects of drinking water (2021)	Water temperature affects all physical, chemical, microbiological, and biochemical processes to some extent from the source through treatment and distribution to in-building plumbing. In turn, this affects water quality and can result in issues related to health-based contaminants and aesthetics. This document summarizes how temperature is discussed in the Guidelines for Canadian Drinking Water Quality and highlights aspects that may be relevant to drinking water utilities when developing and implementing management strategies.
Use of Enterococci as an indicator in Canadian drinking water supplies (2020)	Enterococci are a bacteriological indicator of fecal contamination. This indicator can supplement E. coli and total coliforms monitoring programs to provide additional information into fecal contamination issues. The document provides information on how enterococci can be used in a drinking water monitoring program.
Use of Quantitative Microbial Risk Assessment (QMRA) in Drinking Water (2019)	Provides guidance on the use of QMRA to assist in understanding microbiological risks in Canadian water systems.

Parameter/subject (published)	Comments
Waterborne pathogens (2022)	Numerous types of pathogenic microorganisms can spread through drinking water to cause human illness. Some are present in human or animal feces and can cause gastrointestinal illness when fecally contaminated water is consumed. Others are naturally found in aquatic environments and can cause opportunistic infections when the conditions in engineered water systems (e.g., drinking water distribution systems and building/premise plumbing) allow them to multiply and spread. This guidance document discusses sources of these pathogens, associated health effects, (pathogen) detection methods, treatment considerations, and management strategies to minimize public health risks.

Table 5. Withdrawn Guidelines

Health Canada, in collaboration with the Federal-Provincial-Territorial Committee on Drinking Water, has established a science-based process to systematically review older guidelines and withdraw those that are no longer required. Guidelines are withdrawn for parameters that are no longer found in Canadian drinking water supplies at levels that could pose a risk to human health. This includes pesticides that are no longer registered for use in Canada and mixtures of contaminants that are addressed individually.

Type	Parameter	Year withdrawn	Type	Parameter	Year withdrawn
P	Aldicarb	2012	P	Mirex	1978
P	Aldrin + dieldrin	1994	O	Monochlorobenzene	2022
P	Azinphos-methyl	2022	P	Paraquat	2022
P	Bendiocarb	2012	P	Parathion	2012
P	Carbaryl	2022	P	Pesticides (total)	1989
P	Carbofuran	2022	O	Phenols (total)	1989
P	Chlordane (total isomers)	1996	P	Phorate	2022
P	Cyanazine	2012	O	Phthalic acid esters (PAE)	1978

P	Diazinon	2022	P	Picloram	2022
O	1,2-dichlorobenzene	2022	O	Polychlorinated biphenyls (PCBs)	1978
O	1,1-Dichloroethylene	2024	O	Polycyclic aromatic hydrocarbons (PAHs) (excluding benzo[a]pyrene)	1978
P	Dichlorodiphenyltrichloroethane (DDT) + metabolites	1996	O	Resin acids	1978
O	2,4-dichlorophenol	2022	P	Simazine	2022
P	Diclofop-methyl	2022	O	Tannin	1978
P	Dinoseb	2012	P	Temephos	1996
P	Diuron	2022	P	Terbufos	2022
P	Endrin	1987	O	2,3,4,6-tetrachlorophenol	2022
O	Gasoline and its organic constituents	2012	O	Total organic carbon	2005
P	Heptachlor + heptachlor epoxide	1996	P	Toxaphene	1989

O	Lignin	1978	P	Triallate	1996
P	Lindane	1996	P	2,4,5-Trichlorophenoxyacetic acid (2,4,5-T)	1996
P	Methoxychlor	2012	P	2,4,5-Trichlorophenoxypropionic acid (2,4,5-TP)	1987
P	Methyl-parathion	1989	P	Trifluralin	2022
P	Metolachlor	2022			

Table 6. Guidelines and Guidance in Progress

The following are parameters for which Health Canada is developing or updating guidelines and guidance over the next few years.

- Acrylamide
- Arsenic
- Asbestos
- Chlorate/chlorite
- Fluoride
- Haloacetic acids
- Operational guidance for drinking water utilities
- Per- and polyfluoroalkyl substances (PFAS)
- Premise plumbing and biofilm-associated microorganisms
- Protozoa
- Radiological parameters
- Trichloroethylene
- Trihalomethanes
- Turbidity