

User Inputs
Max LV connection power [kVA]
Grid connection capacity (G) [kVA]
Transformer present on premises?
Number of chargers (n)
Available MV/LV transformer capacity [kVA]
Load Power Factor (pf)
Simultaneity factor (f)
Power per charger (P) [kW]
Transformer safety margin [%]
Project Type
Project Type Classification (Type 1/2/3/4)
Sizing Calculations
Transformer
S_T = (S–G)·(1+m)
S [kVA]
Cost Functions
x
y
Transformer Cost
S [kVA] → €
€ Transformer