

User Inputs
Load Power Factor (pf)
MV level (V_MV) [kV]
Max LV connection power [kVA]
Simultaneity factor (f)
Number of chargers (n)
Available MV/LV transformer capacity [kVA]
Power per charger (P) [kW]
Transformer present on premises?
Grid connection capacity (G) [kVA]
Project Type
Project Type Classification (Type 1/2/3/4)
Sizing Calculations
MV Switchgear
I = (S–G)/(√3·V_MV)
I [A], V [kV]
Cost Functions
Switchgear Cost
I [A], V [kV] → €
€ Switchgear