

ISO/IEC DIS 30134-6(en) Information technology — Data centres — Key performance indicators — Part 6: Energy Reuse Factor (ERF)

BUY

☐ FOLLOW

i

☰

Table of contents

FOREWORD

INTRODUCTION

1 Scope

2 Normative references

▼ 3 Terms, definitions, abbreviations and symbols

3.1 Terms and definitions

3.2 Abbreviations

3.3 Symbols

4 Applicable area of the data centre

5 Determination of Energy Reuse Factor (ERF)

6 Measurement of EReuse and EDC

7 Application of Energy Reuse Factor (ERF)

▼ 8 Reporting of Energy Reuse Factor (ERF)

▶ 8.1 Requirements

▶ 8.2 Recommendations

8.3 ERF derivatives, interim ERF

▼ Annex A Examples of Use

▶ A.1 Examples of ERF usage

▼ Annex B Energy Conversion Factors

B.1 Energy Measurement at the Data Centre

Bibliography

◀

Q

×

FOREWORD

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO’s adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: Foreword - Supplementary information.

The committee responsible for this document is ISO/IEC JTC 1, Information technology, SC 39, Sustainability for and by Information Technology.

ISO/IEC 30134 consists of the following parts, under general title *Information technology — Data centres — Key performance indicators*:

— Part 1: Overview and general requirements

— Part 2: Power usage effectiveness (PUE)<sup>1)</sup>

— Part 3: *Renewable energy factor (REF)*

The following parts are under preparation:

— Part 4: *IT equipment energy efficiency for servers (ITEE\_SV)*

— Part 5: *IT equipment utilization for servers (ITEU\_SV)*

— Part 6: *Energy Reuse Factor (ERF)*

Additional parts will be developed, each describing a specific KPI for resource usage effectiveness or efficiency.

INTRODUCTION

The global economy is now reliant on information and communication technologies and the associated generation, transmission, dissemination, computation and storage of digital data. All markets have experienced exponential growth in that data, for social, educational and business sectors and, while the internet backbone carries the traffic, there are a wide variety of data centres at nodes and hubs within both private enterprise and shared/collocation facilities.

The historical data generation growth rate exceeds the capacity growth rate of the information and communications technology hardware and, with less than half (in 2014) of the world’s population having access to an internet connection, that growth in data can only accelerate. In addition, with many governments having “digital agendas” to provide both citizens and businesses with ever-faster broadband access, the very increase in network speed and capacity will, by itself, generate ever more usage (Jevons Paradox). Data generation and the consequential increase in data manipulation and storage are directly linked to increasing power consumption.

With this background, data centre growth, and power consumption in particular, is an inevitable consequence and that growth will demand increasing power consumption despite the most stringent energy efficiency strategies. This makes the need for key performance indicators (KPIs) that cover the effective use of resources (including but not limited to energy) and the reduction of CO2 emissions essential.

Within the ISO/IEC 30134- series, the term “resource usage effectiveness” is more generally used for KPIs in preference to “resource usage efficiency”, which is restricted to situations where the input and output parameters used to define the KPI have the same units.

Energy Reuse Factor (ERF) will provide the data centre practitioner with greater visibility into energy efficiency in data centres that make beneficial use of any reused energy from the data centre.

In order to determine the overall resource efficiency of a data centre, a holistic suite of metrics is required. This International Standard is

Figures

Tables

Parts