

Drinking Water Quality Report

Sample Site: Well #4, North Distribution Zone

Collected: 15-Aug-2026 08:30

Lab ID: WQ-08154

Parameter	Result	Unit	Regulatory Limit (MCL)
Lead	0.0021	mg/L	0.015
Copper	0.18	mg/L	1.3
Nitrate (as N)	1.4	mg/L	10
Fluoride	0.7	mg/L	4.0
Total Coliform	Absent	CFU/100mL	Absent
Turbidity	0.09	NTU	1.0
pH	7.6	-	6.5 - 8.5
Chlorine Residual	0.9	mg/L	4.0
Total Dissolved Solids	212	mg/L	500

All parameters within regulatory limits.