Spiral Systems Incorporated

DOUBLE WALL

Submittal

Nashville, TN • Nesbit, MS
Toll Free: (877) 280-2663 • Fax: (877) 429-3373

Project	
Date	
Tag	
Engineer	
Representative	

PRESSURE CLASS

☐ +2" - 1995 SMACNA ☐ +4" - 1995 SMACNA ☐ +10" - 1995 SMACNA

MATERIAL

Pipe **inner** liner shall be manufactured from:

☐ Perforated - Galvanized
3/32" Dia. Holes on 3/16 Stagger

☐ Solid Galvanized
Solid Sheet Steel

☐ Stainless 316-2B
☐ Aluminum H14-3003

Pipe **OUTER SHELL** shall be manufactured from:

☐ Galvanized
G-90 ASTM A-653

☐ Paint Grade / Galvanneal
A-40/60 ASTM A-653

☐ Stainless 316-2B
☐ Aluminum H14-3003

*Note: Fittings shall have a solid inner liner.
Fittings shall be manufactured from the same material as pipe.

INSULATION

Fiberous glass blank - UL 732 Class. Flame Spread 25, Smoke Dev. 50,

☐ 1" - 1-1/2 lb. density R=4.2
☐ 2" - 1-1/2 lb. density R=8.4
☐ Material Faced
☐ Mylar Faced
☐ Anti-microbial Coated Insulation

Closed cell, flexible elastomeric foam; Flame Spread 25, Smoke Dev. 50,

☐ 1" - 3 lb. density R=4.2
☐ PSA - Adhesive

CONNECTORS / TRANSVERSE JOINTS

☐ Inner/Outer Slip Couplings
☐ Accuflange Installed
☐ Spiralmate Installed

TEES / LATERALS / SADDLES

☐ Tees / Laterals- Full Body Branch Fittings -
☐ Installed (Manifold) Taps
☐ Loose Saddle Taps

TAP TYPE / CONFIGURATION

☐ 90 Degree Straight Taps
☐ 90 Degree Conical Taps
☐ 45 Degree Lateral Taps

GRILLE TAP TYPE / CONFIGURATION

☐ Installed
☐ Loose - Saddled
☐ Flange IN
☐ Flange OUT
☐ Hole Cut - (Direct Mount Grille)

NOTES / COMMENTS