```
tspan = linspace(0,60*60*60*24, 10*60*60*24);
%t = linspace(0,7*60*60*24,7*60*60*24);
%Q_in_sun = -361*cos((pi*t)/(12 * 3600)) + 224*cos((pi*t)/(6 * 3600)) + 210;
%plot(t, Q_in_sun)

day_start = 45*60*60*24/6;
day_end = 46*60*60*24/6;


y_0= 17; %start temp of air
T_a = -3; %temp of air constant
m = 3000 * 5 * 5 * .2; %kg thermal mass of floor
c = 800; % j/kgK


h_inside = 15; %
h_outside = 30;
A_win = 2.6*2.6; %m^2
A_wall = 25*2 + 15*4 - A_win; % m^2
A_f = 25; %m^2
L_wall = .07; %m
K_wall = .04; % w/mk
h_eq_win = .7;

R_FtoA = 1/(h_inside * A_f);
R_AirtoWall_in = 1/(h_inside * A_wall);
R_W  = L_wall/(K_wall * A_wall);
R_AtoWin_in = 1/(h_inside*A_win);
R_win   = 1/(h_eq_win*A_win);
R_AtoWin_out = 1/(h_outside*A_win);
R_AirtoWall_out = 1/(h_outside * A_wall);




R_tot = R_FtoA + 1/((1/(R_AirtoWall_in + R_W + R_AirtoWall_out)) + (1/(R_AtoWin_in +↙
R_win + R_AtoWin_out))); %thermal resistance

[t, y] = ode45(@(t,y) A_win*(-361*cos((pi*t)/(12 * 3600)) + 224*cos((pi*t)/(6 * 3600)) +↙
210)/(m*c) - (y - T_a)/(R_tot*m*c), tspan, y_0);
%dT_f/dt = Q_in_sun/(m*c) - (T_f - T_a)/(R_tot*m*c);

temp_inside_air = ((-R_FtoA.*(y - T_a))./R_tot) + y;

sec_2_day = 60*60*24;
sec_2_hour = 60*60;

plot(t/sec_2_day,y)
hold on
plot(t/sec_2_day,temp_inside_air, 'red')
xlabel("Time (days)")
```

```
ylabel("Temp (C)")
legend('Thermal Mass Temp', 'Indoor Air Temp')


hold off
figure
plot((t(day_start:day_end)-t(day_start))/sec_2_hour, temp_inside_air(day_start:day_end))
xlabel("Time (hour)")
ylabel("Temp (C)")


% making the figures with small changes in the insulation thickness and
% thermal mass thi
figure
lst = .05:((.2-.05)/4):.2;
for L_wall = .05:((.2-.05)/4):.2
    R_W  = L_wall/(K_wall * A_wall);
    R_tot = R_FtoA + 1/((1/(R_AirtoWall_in + R_W + R_AirtoWall_out)) + (1/(R_AtoWin_in +↙
R_win + R_AtoWin_out))); %thermal resistance

    [t, y] = ode45(@(t,y) A_win*(-361*cos((pi*t)/(12 * 3600)) + 224*cos((pi*t)/(6 *↙
3600)) + 210)/(m*c) - (y - T_a)/(R_tot*m*c), tspan, y_0);
    %dT_f/dt = Q_in_sun/(m*c) - (T_f - T_a)/(R_tot*m*c);

    temp_inside_air = ((-R_FtoA.*(y - T_a))./R_tot) + y;
    plot((t(day_start:day_end)-t(day_start))/sec_2_hour, temp_inside_air(day_start:↙
day_end))
    hold on
    xlabel("Time (hour)")
    ylabel("Temp (C)")
    legend(num2str(lst(1)),num2str(lst(2)),num2str(lst(3)),num2str(lst(4)),num2str(lst↙
(5)))
    %title("Indoor Air Temp Over the Course of a Day after Equilibrium is Reached with↙
Varying Values of Insulation Thickness")
end

figure
lst = .05:((.3-.05)/4):.3;
for m = ((3000 * 5 * 5 * .05):(((3000 * 5 * 5 * .3)-(3000 * 5 * 5 * .05))/4):(3000 * 5 *↙
5 * .3))
    [t, y] = ode45(@(t,y) A_win*(-361*cos((pi*t)/(12 * 3600)) + 224*cos((pi*t)/(6 *↙
3600)) + 210)/(m*c) - (y - T_a)/(R_tot*m*c), tspan, y_0);
    %dT_f/dt = Q_in_sun/(m*c) - (T_f - T_a)/(R_tot*m*c);

    temp_inside_air = ((-R_FtoA.*(y - T_a))./R_tot) + y;
    plot((t(day_start:day_end)-t(day_start))/sec_2_hour, temp_inside_air(day_start:↙
day_end))
    hold on
    xlabel("Time (day)")
    ylabel("Temp (C)")
    legend(num2str(lst(1)),num2str(lst(2)),num2str(lst(3)),num2str(lst(4)),num2str(lst↙
```

```
(5)))
    %title("Indoor Air Temp Over the Course of a Day after Equilibrium is Reached with↙
Varying Values of Insulation Thickness")
end
```