



BAGMANE

Bagmane Developers Pvt. Ltd.

Integrated Management System

Fire Shaft Daily Checklist

Document Number: BDPL OCP 02 F-21

Revision Date: January 16, 2024

Rev. No.: 02

Building:		Wing:		Month:																												
Sl. No.	Description	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Fire Extinguishers																																
1	Check pressure gauges to ensure they are in the optimal range																															
2	Inspect for visible damage or corrosion																															
3	Verify if inspection tags are up to date																															
Fire Hose Reels																																
1	Inspect hoses for signs of wear, cracks, or leaks																															
2	Check that the reel operates smoothly without obstruction																															
3	Check if the nozzle is in good condition and free from blockages																															
Fire Alarm Systems																																
1	Test the alarm system to ensure it's functional																															
2	Inspect control panels for any fault indicators or errors																															
3	Verify that all detectors and sensors are operational																															
Emergency Lighting																																
1	Check and test emergency lighting to ensure proper functionality																															
2	Replace any malfunctioning or dim lights immediately																															
Smoke Detectors and Sprinkler Systems																																
1	Test smoke detectors and replace batteries if needed																															
2	Inspect sprinkler heads for damage or blockages																															
Access to Equipment																																
1	Ensure that fire equipment is easily accessible and not obstructed by objects																															
Fire Technician Sign.																																
Maintenance Sup. Sign.																																
Remarks:																																