

		Bagmane Developers Pvt. Ltd. Integrated Management System Water Cooled Chiller Log																				Document Number: BDPL OCP 13 F-05					
																						Revision Date: January 16, 2024					
																						Rev. No.: 02					
Building:					Chiller No.:					Chiller Rating:					Date:					Run Hours:							
Time	Cooler						Condenser												Winding Temp.	Discharge Temp.	Actual Guide vane (Position)	Voltage in Volts	Total load in Amps.	Percentage of load in %	Evaporator approach (Temp.)	Condenser approach (Temp.)	A/C Tech Sign.
	Refrigerant		Water				Refrigerant		Water				Oil			Motor Load in Amps.	Bearing Temp.										
	Pressure in psig	Temp.	Pressure		Temp.		Pressure	Temp.	Pressure		Temp.		Pressure Diff.	Temp. (Reservoir)	Level												
			In	Out	In	Out			In	Out																	
Spec	130 to 240				< 54°C	< 45°C	130 to 240					< 54°C	< 45°C									< 100 %					
0:00																											
2:00																											
4:00																											
6:00																											
8:00																											
10:00																											
12:00																											
14:00																											
16:00																											
18:00																											
20:00																											
22:00																											
Remarks:																		Supervisor Sign:				BIC / AFM Sign.					