



Bagmane Developers Pvt. Ltd.
Integrated Management System
WTP Operational Log

Document Number: BDPL OCP 10 F-03
Revision Date: December 31, 2024
Rev. No.: 03

Campus / Building:																															
Date	Plumber Name	Power supply availability in PHE Panel (Yes / No)	Pumps in Auto / Manual mode				Chlorine level in Chlorine tank (>25% & <75%)	Raw water pump outlet line valves (Open / Closed)	Raw Water		Operating Pressure (kg/cm2)	PSF Backwash (Min. 20 mins)		PSF Rinse (Min. 10 mins)		ACF Backwash (Min. 20 mins)		ACF Rinse (Min. 10 mins)		Softener Regeneration		Softener Rinse		Treated Water pH	Treated Water Hardness (in ppm)		Treated Water Chlorination Level (mg/litres)	Water quality (Pure/ Impure)	Salt used (in Kg)	Salt Stock Balance (in Kg)	Signature of TL
			Borewell Pumps	Raw Water Pumps	Treated Water Pumps	Chlorine Dosing Pump			pH	Hardness (in ppm)		Start Time	End Time	Start Time	End Time	Start Time	End Time	Start Time	End Time	Start Time	End Time	Start Time	End Time		Softener Outlet	UG Treated Tank					
					</																										