

 BAGMANE		Bagmane Developers Pvt. Ltd. Integrated Management System AHU Parameter Readings													Document Number: BDPL OCP 12 F-03			
															Revision Date: January 16, 2024			
															Rev. No.: 02			
Building:				FLOOR				AHU NO				DATE:						
Time On:								Time Off :										
TIME	Ambient Air		Chilled Water				Dehumidified Air				% of Two way Valve opening	Actuator position Status (On/Off)	Fire Damper (ON or OFF)	HRW Unit Status			VFD running Frequency	Reading Taken By
	Temp	Relative Humidity	Entering water Temp T1	Leaving water Temp T2	Chilled water Pressure IN	Chilled water Pressure OUT	Supply Air Temp	Return Air Temp	Relative Humidity	CO2				Heat Recovery Wheel	Supply air Fans	Exhaust air Fans		
	° C	Rh	° C	° C	Kg/cm <sup>2</sup>	Kg/cm <sup>2</sup>	° C	° C	Rh	ppm				ON or OFF	ON or OFF	ON or OFF	Hz	
Spec.			> 7.2	< 14	> 2 & < 4	> 6 & < 10	< 14	< 24	< 65	< 1000							> 25 & < 45	
0:00																		
2:00																		
4:00																		
6:00																		
8:00																		
10:00																		
12:00																		
14:00																		
16:00																		
18:00																		
20:00																		
22:00																		
Supervisor Sign.															BIC / AFM Sign.			