


<div><div>Bagmane Developers Pvt. Ltd. Integrated Management System DG Running Log</div></div>																				Document Number: BDPL OCP 11 F-03								
																				Revision Date: January 16, 2024								
																				Rev. No.: 02								
Building				DG No:				DG Capacity:				DG Make:																
DATE	Time		Run. Hours	Mechanical Parameters			Cooling Tower			Electrical Parameters								KWH Meter		KWH Cons.	Fuel Level			Fuel Cons.	Battery Voltage in Volts	Reading Taken by	Verified By	
	Start	Stop		Speed in RPM	Water Temp. in °C	Oil Press. in Kg/cm ²	Basin Level	Water Temp. inlet °C	Water Temp. out let °C	Voltage in Volts			HZ	KW	PF	Current in Amps			Initial Reading		Final Reading	Initial Level	Fuel Added					Final Level
										RY	YB	BR				R	Y	B										
			1500 RPM	<90	>4.5 <7.5	>80%	+ - 90	+ - 40	< 440V			(=50 Hz)	<80% of Full load current						Fuel Level >60%			> 24 V & < 26 V						
Observation / Remarks:																							BIC / AFM sign.					