

 BAGMANE		Bagmane Developers Pvt. Ltd. Integrated Management System Weekly Inspection & Testing of Fire Detection and Alarm System						Document Number: BDPL OCP 02 F-18
								Revision Date: January 16, 2024
								Rev. No.: 02
Building:				Date:				
Loop Number	Device Number	Location of device	Alarm Indication on zonal panel received with correct address of devise (Yes/No)	Alarm Indication on main panel received with correct address of devise (Yes/No)	Hooter / Flasher Cum Sounder working & audible (Yes/No)	Integration of Associated subsystems work (Hooters worked/ Fireman lift switch operated / Deactivation of Turnstile and Access control doors/ /Pressurization fan, & Ventilation Fan started) (Yes/No)	Trouble signal received on Main Panel after Battery lead disconnection	Observations / Action
Battery Condition:								
Fire Technician (Name & Signature):						Building incharge (Name & Signature):		