

		Bagmane Developers Pvt. Ltd. Integrated Management System Air Cooled Chiller Log																				Document Number: BDPL OCP 13 F-04 Revision Date: January 16, 2024 Rev. No.: 02											
		Building:				Chiller No.:				Chiller Rating:				Date:				Run Hours:															
		General Information				EVAPORATOR						CONDENSOR					COMPRESSOR																
Time	Circuit	Total Capacity in %	CKT. Capacity in %	Ambient Temperature (WBT/DBT)	Evaporator leaving water temp	Evaporator Entry water temp	Active Chilled Water set point	Active current Set Point.	Chilled Water inlet pressure	Chilled Water Outlet pressure	Condenser Rfght Pressure	Sat.Cond.Rfght Temp.	Evap Rfght Pressure	Sat.Evap.Rfght Temp.	Evaporator liquid level	Economizer	Oil Level	Oil Pressure	Differential Oil Pressure	Oil Temperature	Suction Pressure	Suction Temperature	Discharge Pressure	Discharge Temperature	Discharge Superheat	% FLA	Expansion Valve Opening	Load Solenoid Valve (Load SOL1)	Unload Solenoid Valve (Unld SOL1)	Liquid Injection (LIQInjct)	Tech. Sign		
Spec.					7 °C	13 °C	7 °C	90%	3.5 (Kg/cm²)	3 (Kg/cm²)	psig	> 45 °C	psig	°C / °F	ON / OFF	< High level	psig	psig	°C / °F	psig	°C / °F	psig	°C / °F	°C / °F	Amps	ON / OFF	ON / OFF	ON / OFF	ON / OFF				
0:00	A																																
	B																																
	C																																
2:00	A																																
	B																																
	C																																
4:00	A																																
	B																																
	C																																
6:00	A																																
	B																																
	C																																
8:00	A																																
	B																																
	C																																
10:00	A																																
	B																																
	C																																
12:00	A																																
	B																																
	C																																
14:00	A																																
	B																																
	C																																
16:00	A																																
	B																																
	C																																
18:00	A																																
	B																																
	C																																
20:00	A																																
	B																																
	C																																
22:00	A																																
	B																																
	C																																
Remarks:																										Supervisor Sign:				BIC / AFM Sign.			