OTProof Remediation Assurance Report

Generated 2026-10-26 · Fictional Cedar Valley Water Utility (synthetic demonstration data)

Assets	Advisories	Findings	Applicable	Manual review	Verified	Overdue
80	3	13	4	6	0	0

Finding register

Asset / version	Advisory	Applicability	Workflow	Reason / evidence	Source
CV-HMI-001 Rockwell Automation FactoryTalk View Site Edition 13.0.0	ICSA-24-226-06 CVE-2024-7513 Published: 2024-08-13 Updated: 2024-08-29 Imported: 2026-10-26	applicable	requires_review Decision: pending	13.0.0 matches FactoryTalk View SE: version 13.0.	ICSA-24-226-06
CV-HMI-002 Rockwell Automation FactoryTalk View Site Edition 14.0	ICSA-24-226-06 CVE-2024-7513 Published: 2024-08-13 Updated: 2024-08-29 Imported: 2026-10-26	not applicable	not_applicable Decision: pending	14.0 does not match FactoryTalk View SE: version 13.0.	ICSA-24-226-06
CV-HMI-003 Rockwel Automation FactoryTalk View SE 13.0	ICSA-24-226-06 CVE-2024-7513 Published: 2024-08-13 Updated: 2024-08-29 Imported: 2026-10-26	applicable	requires_review Decision: pending	13.0 matches FactoryTalk View SE: version 13.0.	ICSA-24-226-06
CV-HMI-005 Rockwell Automation FactoryTalk View Site Edition	ICSA-24-226-06 CVE-2024-7513 Published: 2024-08-13 Updated: 2024-08-29 Imported: 2026-10-26	requires manual verification	requires_review Decision: pending	Firmware/software version is missing; a product match alone cannot establish applicability.	ICSA-24-226-06
CV-HMI-006 Rockwell Automation FactoryTalk View Site Edition 13.0	ICSA-24-226-06 CVE-2024-7513 Published: 2024-08-13 Updated: 2024-08-29 Imported: 2026-10-26	requires manual verification	requires_review Decision: pending	Asset model is explicitly marked unknown; confirm the installed equipment identity before relying on this result.	ICSA-24-226-06

Asset / version	Advisory	Applicability	Workflow	Reason / evidence	Source
CV-HMI-007 Rockwell Automation FactoryTalk View Site Edition 13.0	ICSA-24-226-06 CVE-2024-7513 Published: 2024-08-13 Updated: 2024-08-29 Imported: 2026-10-26	requires manual verification	requires_review Decision: pending	Inventory was last verified 816 days ago; confirm the installed version before relying on this result.	ICSA-24-226-06
CV-HMI-008 Rockwell Automation FactoryTalk View Site Edition 13.0	ICSA-24-226-06 CVE-2024-7513 Published: 2024-08-13 Updated: 2024-08-29 Imported: 2026-10-26	requires manual verification	requires_review Decision: pending	Possible duplicate inventory identity detected; confirm whether this is a separate physical asset.	ICSA-24-226-06
CV-HMI-009 Rockwell Automation FactoryTalk View Site Edition 13.0	ICSA-24-226-06 CVE-2024-7513 Published: 2024-08-13 Updated: 2024-08-29 Imported: 2026-10-26	requires manual verification	requires_review Decision: pending	Possible duplicate inventory identity detected; confirm whether this is a separate physical asset.	ICSA-24-226-06
CV-OPT-010 Rockwell Automation Pavilion8 5.19	ICSA-24-256-24 CVE-2024-7960, CVE-2024-7961 Published: 2024-09-12 Updated: 2024-09-12 Imported: 2026-10-26	applicable	requires_review Decision: pending	5.19 matches All versions prior to V5.20.	ICSA-24-256-24
CV-OPT-011 Rockwell Automation Pavilion8 5.20	ICSA-24-256-24 CVE-2024-7960, CVE-2024-7961 Published: 2024-09-12 Updated: 2024-09-12 Imported: 2026-10-26	not applicable	not_applicable Decision: pending	5.20 does not match All versions prior to V5.20.	ICSA-24-256-24
CV-APP-012 Rockwell Automation DataMosaix Private Cloud 7.07	ICSA-24-284-15 CVE-2024-7952 Published: 2024-10-10 Updated: 2024-10-10 Imported: 2026-10-26	applicable	requires_review Decision: pending	7.07 matches Versions 7.07 and prior.	ICSA-24-284-15
CV-APP-013 Rockwell Automation DataMosaix Private Cloud 7.08	ICSA-24-284-15 CVE-2024-7952 Published: 2024-10-10 Updated: 2024-10-10 Imported: 2026-10-26	not applicable	not_applicable Decision: pending	7.08 does not match Versions 7.07 and prior.	ICSA-24-284-15
CV-OPT-014 Rockwell Automation Pavilion8 release-5.19-hotfix	ICSA-24-256-24 CVE-2024-7960, CVE-2024-7961 Published: 2024-09-12 Updated: 2024-09-12 Imported: 2026-10-26	requires manual verification	requires_review Decision: pending	Version format is not supported by the deterministic parser.; At least one version constraint could not be interpreted; engineering verification is required.	ICSA-24-256-24

Audit trail (most recent 1,000 events)

Time	Actor / role	Action	Record	Details
2026-10-26 12:54:19	reviewer:demo-user	applicability.analyze	analysis 80x3	{'assets': 80, 'advisories': 3, 'created': 13, 'updated': 0, 'skipped_clear_nonmatches': 227, 'method': 'deterministic curated aliases and numeric dotted version constraints'}

Assurance scope and limits

- Applicability results are deterministic screening outputs, not proof of exploitation or safety impact.
- Only an authorized engineering decision changes a candidate into a reviewed applicability decision.
- A remediation ticket, narrative, or evidence attachment does not by itself mark a finding remediated.
- Verified remediation requires an approver decision referencing evidence and rationale.
- All demonstration assets and operational workflow records are fictional.

Source snapshot register

Cached public-source records used by this application database. Payloads are excluded; source URLs, timestamps, validators, status, and hashes are retained.

No network source snapshot is stored in this database. Offline fixture records retain their public source URLs, publication/update dates, and import times.