
COL
2' - 11"
STEEL ROOF DECK- SEE GEN NOTES
12
4
16GAX4X6 (LLH) ANGLE CONT
WORK POINT
6"
TRUSS BRG SEE PLAN
1" GAP
PREFABRICATED LIGHT GAUGE TRUSS @48"
MISC. STUD FRAMING - SEE ARCH DWGS
TRUSS MANUF TO DESIGN BLOCKING BETWEEN TRUSSES TO TRANSFER A LATERAL WIND LOAD OF 174 PLF FROM ROOF DIAPHRAGM TO STEEL BEAM
DEFLECTION CLIP @EA STUD - TYPE SLB1200 OR EQUAL. LOCATE TOP OF CLIP 3" (MAX) BELOW BOT OF BEAM FLANGE.
HOLDDOWN BY TRUSS MANUF
BEAM- SEE PLAN
VENEER- SEE ARCH DWGS
6" - 18GA METAL STUD (600S162-43 OR EQUAL) @16"
LGT GA HEADER- BY LGT GA DESIGNER
T.O. OPNG SEE ARCH DWGS
LOOSE LAID LINTEL- SEE SCHEDULE
WINDOW-SEE ARCH DWGS
SEE ARCH
1' - 1"

1 S3.02 SECTION 3/4" = 1'-0"


COL
2' - 11"
STEEL ROOF DECK- SEE GEN NOTES
12
4
16GAX4X6 (LLH) ANGLE CONT
WORK POINT
6"
TRUSS BRG SEE PLAN
1" GAP
PREFABRICATED LIGHT GAUGE TRUSS @48"
MISC. STUD FRAMING - SEE ARCH DWGS
TRUSS MANUF TO DESIGN BLOCKING BETWEEN TRUSSES TO TRANSFER A LATERAL WIND LOAD OF 174 PLF FROM ROOF DIAPHRAGM TO STEEL BEAM
DEFLECTION CLIP @EA STUD - TYPE SLB1200 OR EQUAL. LOCATE TOP OF CLIP 3" (MAX) BELOW BOT OF BEAM FLANGE.
HOLDDOWN BY TRUSS MANUF
BEAM- SEE PLAN
T.O.S. +10'-8" AFF SEE ARCH DWGS
LOUVER - SEE MECH DWGS
10"
LGT GA HEADER- BY LGT GA DESIGNER
HSS BEAM - SEE PLAN. SEE SHEET S1.05 FOR CONN. TO COLUMN
VENEER- SEE ARCH DWGS
6" - 18GA METAL STUD (600S162-43 OR EQUAL) @16"
LGT GA HEADER- BY LGT GA DESIGNER
T.O. OPNG SEE ARCH DWGS
LOOSE LAID LINTEL- SEE SCHEDULE
WINDOW-SEE ARCH DWGS
SEE ARCH
1' - 1"

1A S3.02 SECTION 3/4" = 1'-0"


COL
2' - 11"
STEEL ROOF DECK- SEE GEN NOTES
12
4
16GAX4X6 (LLH) ANGLE CONT
WORK POINT
6"
TRUSS BRG SEE PLAN
1" GAP
PREFABRICATED LIGHT GAUGE TRUSS @48"
MISC. STUD FRAMING - SEE ARCH DWGS
TRUSS MANUF TO DESIGN BLOCKING BETWEEN TRUSSES TO TRANSFER A LATERAL WIND LOAD OF 174 PLF FROM ROOF DIAPHRAGM TO STEEL BEAM
DEFLECTION CLIP @EA STUD - TYPE SLB1200 OR EQUAL. LOCATE TOP OF CLIP 3" (MAX) BELOW BOT OF BEAM FLANGE.
HOLDDOWN BY TRUSS MANUF
BEAM- SEE PLAN
VENEER- SEE ARCH DWGS
6" - 18GA METAL STUD (600S162-43 OR EQUAL) @16"
SEE ARCH
1' - 1"

2 S3.02 SECTION 3/4" = 1'-0"


COL
2' - 11"
STEEL ROOF DECK- SEE GEN NOTES
12
4
16GAX4X6 (LLH) ANGLE CONT
WORK POINT
6"
TRUSS BRG SEE PLAN
1" GAP
PREFABRICATED LIGHT GAUGE TRUSS @48"
MISC. STUD FRAMING - SEE ARCH DWGS
TRUSS MANUF TO DESIGN BLOCKING BETWEEN TRUSSES TO TRANSFER A LATERAL WIND LOAD OF 174 PLF FROM ROOF DIAPHRAGM TO STEEL BEAM
DEFLECTION CLIP @EA STUD - TYPE SLB1200 OR EQUAL. LOCATE TOP OF CLIP 3" (MAX) BELOW BOT OF BEAM FLANGE.
HOLDDOWN BY TRUSS MANUF
BEAM- SEE PLAN
T.O.S. +10'-8" AFF SEE ARCH DWGS
10"
LGT GA HEADER- BY LGT GA DESIGNER
LOUVER - SEE MECH DWGS
HSS BEAM - SEE PLAN. SEE SHEET S1.05 FOR CONN. TO COLUMN
VENEER- SEE ARCH DWGS
6" - 18GA METAL STUD (600S162-43 OR EQUAL) @16"
SEE ARCH
1' - 1"

2A S3.02 SECTION 3/4" = 1'-0"


A
B
2' - 10"
3' - 5"
STUD BLOCKING B/W OUTRIGGERS
16GAX4X6 (LLH) ANGLE CONT.
STEEL ROOF DECK-SEE GEN NOTES
PREFABRICATED LIGHT GAUGE TRUSS @48"
GABLE TRUSS
6" - 18GA METAL STUD OUTRIGGER (600S162-43 OR EQUAL) @16"
STEEL ROOF DECK- SEE GEN NOTES
2' - 11"
12
4
6" - 18 GA STUD FRAMING @16"
16GAX4X6 (LLH) ANGLE CONT
WORK POINT
HOLDDOWN BY TRUSS MANUF
TOS/TRUSS BRG SEE PLAN
TRUSS BRG SEE PLAN
PREFABRICATED LIGHT GAUGE TRUSS @48"
TRUSS MANUF TO DESIGN BLOCKING BETWEEN TRUSSES TO TRANSFER A LATERAL WIND LOAD OF 174 PLF FROM ROOF DIAPHRAGM TO STEEL BEAM
T.O. STOREFRONT SEE ARCH DWGS
BEAM- SEE PLAN
HOLDDOWN BY TRUSS MANUF
VENEER- SEE ARCH DWGS
BEAM- SEE PLAN
LOOSE LINTEL-SEE SCHEDULE
DEFLECTION CLIP @EA STUD - TYPE SLB1200 OR EQUAL
6" - 16GA METAL STUD (600S200-54 OR EQUAL) @12"
STOREFRONT- SEE ARCH DWGS
HSS12X6X5/8 - SEE SHEET S1.05 FOR CONN. TO COLUMN
1' - 9"

3 S3.02 SECTION 3/4" = 1'-0"


0.5
1
2' - 6"
9' - 3"
LGT GA BENT PLATE 16GAX6"X6" AT ALL HIPS AND VALLEYS
STEEL ROOF DECK- SEE GEN NOTES
STEEL ROOF DECK- SEE GEN NOTES
12
6
2' - 11"
STEEL ROOF DECK- SEE GEN NOTES
16GAX4X6 (LLH) ANGLE CONT
16GAX4X6 (LLH) ANGLE CONT
12
4
WORK POINT
WORK POINT
TRUSS BRG SEE PLAN
6"
6"
TRUSS BRG SEE PLAN
1" GAP
PREFABRICATED LIGHT GAUGE JACK TRUSS @48"
HOLDDOWN BY TRUSS MANUF
BEAM- SEE PLAN
MISC. STUD FRAMING - SEE ARCH DWGS
DEFLECTION CLIP @EA STUD - TYPE SLB1200 OR EQUAL. LOCATE TOP OF CLIP 3" (MAX) BELOW BOT OF BEAM FLANGE.
PREFABRICATED LIGHT GAUGE TRUSS @48"
TRUSS MANUF TO DESIGN BLOCKING BETWEEN TRUSSES TO TRANSFER A LATERAL WIND LOAD OF 174 PLF FROM ROOF DIAPHRAGM TO STEEL BEAM
HOLDDOWN BY TRUSS MANUF
BEAM- SEE PLAN
VENEER- SEE ARCH DWGS
6" - 18GA METAL STUD (600S162-43 OR EQUAL) @16"
SEE ARCH
1' - 1"

4 S3.02 SECTION 3/4" = 1'-0"


COL
STEEL ROOF DECK- SEE GEN NOTES
PREFABRICATED LIGHT GAUGE TRUSS @48"
PREFABRICATED LIGHT GAUGE TRUSS - TRUSS MANUF TO DESIGN TRUSS TO TRANSFER A LATERAL LOAD OF 174 PLF FROM ROOF DIAPHRAGM TO STEEL BEAM
TRUSS BRG SEE PLAN
BLOCKING BY TRUSS MANUF. @4'-0" MAX
TRUSS TO BEAM CONNECTION BY TRUSS MANUF
BEAM- SEE PLAN

5 S3.02 SECTION 3/4" = 1'-0"


COL
STEEL ROOF DECK- SEE GEN NOTES
DECK BRNG VARIES
16GAX4X6 (LLH) ANGLE CONT. WHERE DECK DECK SPAN CHANGES DIRECTION.
TRUSS TO TRUSS CONNECTION BY TRUSS MANUF
TRUSS BRNG SEE PLAN
TRUSS MANUF TO DESIGN BLOCKING/TRUSS MEMBER/BRACING B/W TRUSSES TO TRANSFER A LATERAL WIND LOAD OF 174 PLF FROM ROOF DIAPHRAGM TO STEEL BEAM
HOLDDOWN BY TRUSS MANUF
PREFABRICATED LIGHT GAUGE TRUSS @48"
BEAM- SEE PLAN

6 S3.02 SECTION 3/4" = 1'-0"

TUCKER·JONES
ENGINEERS ASSOCIATED, P.C.
3300 CAHABA ROAD, SUITE 210
BIRMINGHAM, ALABAMA 35223
PHONE: 205.879.5660
FAX: 205.879.5606
PROJECT #22076

GMC

2400 5th Avenue South, Suite 200
Birmingham, AL 35233
T 205.879.4462
GMCNETWORK.COM

ISSUE	DATE
BID SET	09/09/2024

DRAWN BY: CSS
CHECKED BY: CSS

TUSCALOOSA COUNTY DHR
Tuscaloosa, Alabama

GMC # ABHM220021

CHRISTOPHER S. STOREY
No. 31254
09/09/2024

SECTIONS

S3.02
sheet of

9/7/2024 12:36:31 PM