

Block Parameters: PID Controller

▼ Compensator formula

$$P + I \frac{1}{s} + D \frac{N}{1 + N \frac{1}{s}}$$

Main Initialization Saturation Data Types State Attributes

Controller parameters

Source: internal

Proportional (P): 564.07358955857

Integral (I): 13492.8531425784 ☐ Use I*Ts (optimal for codegen)

Derivative (D): -1.24837012884727 ☐ Use externally sourced derivative

Filter coefficient (N): 451.84803490887 ☒ Use filtered derivative

Automated tuning

Select tuning method: Transfer Function Based (PID Tuner App)

Tune...

☒ Enable zero-crossing detection

OK

Cancel

Help

Apply