



**CONTROL PERALATAN HYDRANT**

Nomor : SMK3L-En/ISP/FR-22-08

Revisi : 02

Tanggal :

14 Maret 2019

BULAN Januari 2023

SL No	HYDRANT	LOKASI	PIPE HYDRANT	VALVE HYDRANT	MACHINO	HOSE HYDRANT	BOX HYDRANT	NOZZLE	PRESSURE	TANGGAL	PETUGAS
1	1	Rolling Mill Line B	✓	✓	✓	✓	✓	✓	5kg/cm <sup>2</sup>		
2	2	Rolling Mill Line B	✓	✓	✓	✓	✓	✓	5kg/cm <sup>2</sup>		
3	3	Rolling Mill Line B	✓	✓	✓	✓	✓	✓	5kg/cm <sup>2</sup>		
4	4	Rolling Mill Line A Alas	✓	✓	✓	✓	✓	✓	5kg/cm <sup>2</sup>		
5	5	Rolling Mill Line A	✓	✓	✓	✓	✓	✓	5kg/cm <sup>2</sup>		
6	6	Rolling Mill / BRF	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
7	7	Billet Bay / Ido Tank	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
8	8	Clay P House RML	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
9	9	Clay P House RML	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
10	10	LRF Atlas	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
11	11	SMS Ladle Burner	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
12	12	CCM Bawah	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
13	13	Charging Pit Sebelah Utara	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
14	14	CCM Bawah	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
15	15	Charging Pit Sebelah Selatan	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
16	16	Gudang Kapur Sebelah Timur	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
17	17	Store Permanent	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
18	18	Store Permanent	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
19	19	Store Permanent	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
20	20	Lubricant Store	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
21	21	Billet Bay	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
22	22	Billet Bay	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
23	23	Billet Bay	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
24	24	Dengan PLN Sub Station	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
25	25	SMS Atas	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
26	26	SMS/Pintu Masuk Hopper	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
27	27	WTP RML	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
28	28	Belakang Kantin	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
29	29	Belakang Main Office	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
30	30	Belakang Main Office	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
31	31	Control Room SMS Atas	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
32	32	Pulpit CCM	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
33	33	CCM Atas	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
34	34	Motor Room TRML	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
35	35	R Mill Line A, St 13-14	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
36	36	Finishing Area RML	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
37	37	Finishing / Dengan PNL	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
38	38	Finishing / Dengan PNL	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
39	39	Oxygen plant	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
40	40	Oxygen plant	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
41	41	Lubricant Store II	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
42	42	Vehicle	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
43	43	Billing Press	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
44	44	Dispatch / Timbangan	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
45	45	SMS New Building (depan)	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
46	46	SMS New Building It 2 (sblh timur)	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
47	47	SMS New Building (belakang)	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
48	48	SMS New Building (barat)	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
49	49	Dengan Work Office	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
50	50	Dengan Main Office	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
51	51	Dengan Substation PLN	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
52	52	Dengan Substation PLN	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
53	53	Motor Room II RML	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
54	54	RGS RML	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
55	55	Rolling Mill Line B	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
56	56	Dengan Colling Tower SMS	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
57	57	Samping Colling Tower SMS	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		
58	58	Balakang Colling Tower SMS	✓	✓	✓	✓	✓	✓	04/10 <sup>2</sup>		

No	EQUIPMENT	LOKASI	BENSIN		OLIE		TOTAL JAM PEMAKAIAN		PETUGAS	
			Week 2	Week 4	Week 2	Week 4	Week 2	Week 4	Week 2	Week 4
1	POMPA HONDA G200	Office SHE	BANK	BANK	BANK	BANK	6 jam		Wawan	

No	EQUIPMENT	LOKASI	VALVE IN LET		VALVE OUT LET		PETUGAS	
			Week 2	Week 4	Week 2	Week 4	Week 2	Week 4
1	POMPA 37 Kw	Pump House SMS	BANK	BANK	BANK	BANK	Wawan	
2	POMPA DISEI	Pump House SMS	"	"	"	"	"	"
3	POMPA 110 KW	Pump House SMS	"	"	"	"	"	"

Sidomo,  
AK3 Kebakaran

(.....)

	CONTROL PERALATAN HYDRANT	Nomor : SMK3L-En/ISP/FR-22-08 Revisi : 02 Tanggal : 14 Maret 2019
---	---------------------------	---

BULAN Februari 2023

SL No	HYDRANT	LOKASI	PIPE HYDRANT	VALVE HYDRANT	MACHINO	HOSE HYDRANT	BOX HYDRANT	NOZZLE	PRESSURE	TANGGL	PETUGAS
1	1	Rolling Mill Line B	✓	✓	✓	✓	✓	✓	SV4/L2		
2	2	Rolling Mill Line B	✓	✓	✓	✓	✓	✓	SV4/L2		
3	3	Rolling Mill Line B	✓	✓	✓	✓	✓	✓	SV4/L2		
4	4	Rolling Mill Line A Alas	✓	✓	✓	✓	✓	✓	SV4/L2		
5	5	Rolling Mill Line A	✓	✓	✓	✓	✓	✓	SV4/L2		
6	6	Rolling Mill / BRF	✓	✓	✓	✓	✓	✓	SV4/L2		
7	7	Billet Bay / Ido Tank	✓	✓	✓	✓	✓	✓	SV4/L2		
8	8	Crary P.House RML	✓	✓	✓	✓	✓	✓	SV4/L2		
9	9	Crary P.House RML	✓	✓	✓	✓	✓	✓	SV4/L2		
10	10	LRF Atak	✓	✓	✓	✓	✓	✓	SV4/L2		
11	11	SMS Ladle Burner	✓	✓	✓	✓	✓	✓	SV4/L2		
12	12	CCM Bawah	✓	✓	✓	✓	✓	✓	SV4/L2		
13	13	Charging Pit Sebelah Utara	✓	✓	✓	✓	✓	✓	SV4/L2		
14	14	SMS Bawah	✓	✓	✓	✓	✓	✓	SV4/L2		
15	15	Charging Pit Sebelah Selatan	✓	✓	✓	✓	✓	✓	SV4/L2		
16	16	Gudang Kapur Sebelah Timur	✓	✓	✓	✓	✓	✓	SV4/L2		
17	17	Store Permanent	✓	✓	✓	✓	✓	✓	SV4/L2		
18	18	Store Permanent	✓	✓	✓	✓	✓	✓	SV4/L2		
19	19	Store Permanent	✓	✓	✓	✓	✓	✓	SV4/L2		
20	20	Lubricant Store	✓	✓	✓	✓	✓	✓	SV4/L2		
21	21	Billet Bay	✓	✓	✓	✓	✓	✓	SV4/L2		
22	22	Billet Bay	✓	✓	✓	✓	✓	✓	SV4/L2		
23	23	Billet Bay	✓	✓	✓	✓	✓	✓	SV4/L2		
24	24	Depan PLN Sub Station	✓	✓	✓	✓	✓	✓	SV4/L2		
25	25	SMS Atas	✓	✓	✓	✓	✓	✓	SV4/L2		
26	26	SMS/Pintu Masuk Hopper	✓	✓	✓	✓	✓	✓	SV4/L2		
27	27	WTP RML	✓	✓	✓	✓	✓	✓	SV4/L2		
28	28	Belakang Kantin	✓	✓	✓	✓	✓	✓	SV4/L2		
29	29	Belakang Main Office	✓	✓	✓	✓	✓	✓	SV4/L2		
30	30	Belakang Main Office	✓	✓	✓	✓	✓	✓	SV4/L2		
31	31	Control Room SMS Atas	✓	✓	✓	✓	✓	✓	SV4/L2		
32	32	Pulpit CCM	✓	✓	✓	✓	✓	✓	SV4/L2		
33	33	CCM Atas	✓	✓	✓	✓	✓	✓	SV4/L2		
34	34	Motor Room IRML	✓	✓	✓	✓	✓	✓	SV4/L2		
35	35	R.Mill Line A, St. 13-14	✓	✓	✓	✓	✓	✓	SV4/L2		
36	36	Finishing Area RML	✓	✓	✓	✓	✓	✓	SV4/L2		
37	37	Finishing / Depan PLN	✓	✓	✓	✓	✓	✓	SV4/L2		
38	38	Finishing / Depan PLN	✓	✓	✓	✓	✓	✓	SV4/L2		
39	39	Oxygen plant	✓	✓	✓	✓	✓	✓	SV4/L2		
40	40	Oxygen plant	✓	✓	✓	✓	✓	✓	SV4/L2		
41	41	Lubricant Store II	✓	✓	✓	✓	✓	✓	SV4/L2		
42	42	Vehicle	✓	✓	✓	✓	✓	✓	SV4/L2		
43	43	Billing Press	✓	✓	✓	✓	✓	✓	SV4/L2		
44	44	Dishetch / Timbangan	✓	✓	✓	✓	✓	✓	SV4/L2		
45	45	SMS New Building (depan)	✓	✓	✓	✓	✓	✓	SV4/L2		
46	46	SMS New Building II (sblm timur)	✓	✓	✓	✓	✓	✓	SV4/L2		
47	47	SMS New Building (belakang)	✓	✓	✓	✓	✓	✓	SV4/L2		
48	48	SMS New Building (barat)	✓	✓	✓	✓	✓	✓	SV4/L2		
49	49	Depan Work Office	✓	✓	✓	✓	✓	✓	SV4/L2		
50	50	Depan Main Office	✓	✓	✓	✓	✓	✓	SV4/L2		
51	51	Depan Substation PLN	✓	✓	✓	✓	✓	✓	SV4/L2		
52	52	Depan Substation PLN	✓	✓	✓	✓	✓	✓	SV4/L2		
53	53	Motor Room II RML	✓	✓	✓	✓	✓	✓	SV4/L2		
54	54	RCS RML	✓	✓	✓	✓	✓	✓	SV4/L2		
55	55	Rolling Mill Line B	✓	✓	✓	✓	✓	✓	SV4/L2		
56	56	Depan Cooling Tower SMS	✓	✓	✓	✓	✓	✓	SV4/L2		
57	57	Samping Cooling Tower SMS	✓	✓	✓	✓	✓	✓	SV4/L2		
58	58	Belakang Cooling Tower SMS	✓	✓	✓	✓	✓	✓	SV4/L2		

No	EQUIPMENT	LOKASI	BENSIN		OLIE		TOTAL JAM PEMAKAIAN		PETUGAS
			Week 2	Week 4	Week 2	Week 4	Week 2	Week 4	
1	POMPA HONDA G200	Office SHE	Bank	Bank	Bank	Bank	6 jam		wawan

No	EQUIPMENT	LOKASI	VALVE IN LET		VALVE OUT LET		PETUGAS	
			Week 2	Week 4	Week 2	Week 4	Week 2	Week 4
1	POMPA 37 Kw	Pump House SMS	Bank	Bank	Bank	Bank	wawan	wawan
2	POMPA DISEL	Pump House SMS	"	"	"	"	"	"
3	POMPA 110 KW	Pump House SMS	"	"	"	"	"	"

Sidoarjo,  
AK3 Kebakaran

(.....)



**CONTROL PERALATAN HYDRANT**

Nomor : SMK3L-En/ISP/FR-22-08  
Revisi : 02  
Tanggal : 14 Maret 2019

BULAN **Maret 2023**

SL No	HYDRANT	LOKASI	PIPE HYDRANT	VALVE HYDRANT	MACHINO	HOSE HYDRANT	BOX HYDRANT	NOZZLE	PRESSURE	TANGGAL	PETUGAS
1	1	Rolling Mill Line B	✓	✓	✓	✓	✓	✓	SV4/12		
2	2	Rolling Mill Line B	✓	✓	✓	✓	✓	✓	SV4/12		
3	3	Rolling Mill Line B	✓	✓	✓	✓	✓	✓	SV4/12		
4	4	Rolling Mill Line A Atas	✓	✓	✓	✓	✓	✓	SV4/12		
5	5	Rolling Mill Line A	✓	✓	✓	✓	✓	✓	SV4/12		
6	6	Rolling Mill / BRF	✓	✓	✓	✓	✓	✓	SV4/12		
7	7	Billet Bay / Ido Tank	✓	✓	✓	✓	✓	✓	SV4/12		
8	8	Clay P House RML	✓	✓	✓	✓	✓	✓	SV4/12		
9	9	Clay P House RML	✓	✓	✓	✓	✓	✓	SV4/12		
10	10	LRF Atas	✓	✓	✓	✓	✓	✓	SV4/12		
11	11	SMS Ladle Burner	✓	✓	✓	✓	✓	✓	SV4/12		
12	12	CCM Bawah	✓	✓	✓	✓	✓	✓	SV4/12		
13	13	Charging Pit Sepelah Utara	✓	✓	✓	✓	✓	✓	SV4/12		
14	14	SMS Bawah	✓	✓	✓	✓	✓	✓	SV4/12		
15	15	Charging Pit Sepelah Selatan	✓	✓	✓	✓	✓	✓	SV4/12		
16	16	Gudang Kapur Sepelah Timur	✓	✓	✓	✓	✓	✓	SV4/12		
17	17	Store Permanent	✓	✓	✓	✓	✓	✓	SV4/12		
18	18	Store Permanent	✓	✓	✓	✓	✓	✓	SV4/12		
19	19	Store Permanent	✓	✓	✓	✓	✓	✓	SV4/12		
20	20	Lubricant Store	✓	✓	✓	✓	✓	✓	SV4/12		
21	21	Billet Bay	✓	✓	✓	✓	✓	✓	SV4/12		
22	22	Billet Bay	✓	✓	✓	✓	✓	✓	SV4/12		
23	23	Billet Bay	✓	✓	✓	✓	✓	✓	SV4/12		
24	24	Depan PLN Sub Station	✓	✓	✓	✓	✓	✓	SV4/12		
25	25	SMS Atas	✓	✓	✓	✓	✓	✓	SV4/12		
26	26	SMS/Pintu Masuk Hopper	✓	✓	✓	✓	✓	✓	SV4/12		
27	27	WTP RML	✓	✓	✓	✓	✓	✓	SV4/12		
28	28	Belakang Kantin	✓	✓	✓	✓	✓	✓	SV4/12		
29	29	Belakang Main Office	✓	✓	✓	✓	✓	✓	SV4/12		
30	30	Belakang Main Office	✓	✓	✓	✓	✓	✓	SV4/12		
31	31	Control Room SMS Atas	✓	✓	✓	✓	✓	✓	SV4/12		
32	32	Pupit CCM	✓	✓	✓	✓	✓	✓	SV4/12		
33	33	CCM Atas	✓	✓	✓	✓	✓	✓	SV4/12		
34	34	Motor Room IRML	✓	✓	✓	✓	✓	✓	SV4/12		
35	35	R.Mill Line A, St. 13-14	✓	✓	✓	✓	✓	✓	SV4/12		
36	36	Finishing Area RML	✓	✓	✓	✓	✓	✓	SV4/12		
37	37	Finishing / Depan PLN	✓	✓	✓	✓	✓	✓	SV4/12		
38	38	Finishing / Depan PLN	✓	✓	✓	✓	✓	✓	SV4/12		
39	39	Oxygen plant	✓	✓	✓	✓	✓	✓	SV4/12		
40	40	Oxygen plant	✓	✓	✓	✓	✓	✓	SV4/12		
41	41	Lubricant Store II	✓	✓	✓	✓	✓	✓	SV4/12		
42	42	Vehicle	✓	✓	✓	✓	✓	✓	SV4/12		
43	43	Building Press	✓	✓	✓	✓	✓	✓	SV4/12		
44	44	Daerah / Timbangan	✓	✓	✓	✓	✓	✓	SV4/12		
45	45	SMS New Building (depan)	✓	✓	✓	✓	✓	✓	SV4/12		
46	46	SMS New Building II (sisi timur)	✓	✓	✓	✓	✓	✓	SV4/12		
47	47	SMS New Building (belakang)	✓	✓	✓	✓	✓	✓	SV4/12		
48	48	SMS New Building (barat)	✓	✓	✓	✓	✓	✓	SV4/12		
49	49	Depan Work Office	✓	✓	✓	✓	✓	✓	SV4/12		
50	50	Depan Main Office	✓	✓	✓	✓	✓	✓	SV4/12		
51	51	Depan Substation PLN	✓	✓	✓	✓	✓	✓	SV4/12		
52	52	Depan Substation PLN	✓	✓	✓	✓	✓	✓	SV4/12		
53	53	Motor Room II RML	✓	✓	✓	✓	✓	✓	SV4/12		
54	54	RCS RML	✓	✓	✓	✓	✓	✓	SV4/12		
55	55	Rolling Mill Line B	✓	✓	✓	✓	✓	✓	SV4/12		
56	56	Depan Cooling Tower SMS	✓	✓	✓	✓	✓	✓	SV4/12		
57	57	Sambar Cooling Tower SMS	✓	✓	✓	✓	✓	✓	SV4/12		
58	58	Belakang Cooling Tower SMS	✓	✓	✓	✓	✓	✓	SV4/12		

No	EQUIPMENT	LOKASI	BENSIN		OLIE		TOTAL JAM PEMAKAIAN		PETUGAS	
			Week 2	Week 4	Week 2	Week 4	Week 2	Week 4	Week 2	Week 4
1	POMPA HONDA G200	Office SHE	Bank	Bank	Bank	Bank	6 jam		Wawan	

No	EQUIPMENT	LOKASI	VALVE IN LET		VALVE OUT LET		PETUGAS	
			Week 2	Week 4	Week 2	Week 4	Week 2	Week 4
1	POMPA 37 Kw	Pump House SMS	Bank	Bank	Bank	Bank	Wawan	Wawan
2	POMPA DISEL	Pump house SMS	"	"	"	"	"	"
3	POMPA 110 KW	Pump House SMS	"	"	"	"	"	"

Sidcaro,  
AK3 Kebakaran



## CONTROL PERALATAN HYDRANT

Nomor : SMK3L-En/ISP/FR-22-08  
 Revisi : 04  
 Tanggal : 01 Maret 2023

BULAN : April 2023

SL No.	HYDRANT	LOKASI	PIPE HYDRANT	VALVE HYDRANT	MACHINO	HOSE HYDRANT	BOX HYDRANT	NOZZLE	PRESSURE	TANGGAL	PETUGAS
1	1	Rolling Mill Line B	V	V	V	V	V	V	50psi/c2		
2	2	Rolling Mill Line B	V	V	V	V	V	V	50psi/c2		
3	3	Rolling Mill Line B	V	V	V	V	V	V	50psi/c2		
4	4	Rolling Mill Line A Atas	V	V	V	V	V	V	50psi/c2		
5	5	Rolling Mill Line A	V	V	V	V	V	V	50psi/c2		
6	6	Rolling Mill / BRF	V	V	V	V	V	V	50psi/c2		
7	7	Billet Bay / Ido Tank	V	V	V	V	V	V	50psi/c2		
8	8	Clary P.House RML	V	V	V	V	V	V	50psi/c2		
9	9	Clary P.House RML	V	V	V	V	V	V	50psi/c2		
10	10	LRF Atas	V	V	V	V	V	V	50psi/c2		
11	11	SMS Ladle Burner	V	V	V	V	V	V	50psi/c2		
12	12	CCM Bahawah	V	V	V	V	V	V	50psi/c2		
13	13	Charging Pit Sebelah Utara	V	V	V	V	V	V	50psi/c2		
14	14	SMS Bahawah	V	V	V	V	V	V	50psi/c2		
15	15	Charging Pit Sebelah Selatan	V	V	V	V	V	V	50psi/c2		
16	16	Gudang Kapur Sebelah Timur	V	V	V	V	V	V	50psi/c2		
17	17	Store Permanent	V	V	V	V	V	V	50psi/c2		
18	18	Store Permanent	V	V	V	V	V	V	50psi/c2		
19	19	Store Permanent	V	V	V	V	V	V	50psi/c2		
20	20	Lubricant Store	V	V	V	V	V	V	50psi/c2		
21	21	Billet Bay	V	V	V	V	V	V	50psi/c2		
22	22	Billet Bay	V	V	V	V	V	V	50psi/c2		
23	23	Billet Bay	V	V	V	V	V	V	50psi/c2		
24	24	Depan PLN. Sub Station	V	V	V	V	V	V	50psi/c2		
25	25	SMS Atas	V	V	V	V	V	V	50psi/c2		
26	26	SMS/Pintu Masuk Hopper	V	V	V	V	V	V	50psi/c2		
27	27	WTP RML	V	V	V	V	V	V	50psi/c2		
28	28	Belakang Kantin	V	V	V	V	V	V	50psi/c2		
29	29	Belakang Main Office	V	V	V	V	V	V	50psi/c2		
30	30	Belakang Main Office	V	V	V	V	V	V	50psi/c2		
31	31	Control Room SMS Atas	V	V	V	V	V	V	50psi/c2		
32	32	Pulpit CCM	V	V	V	V	V	V	50psi/c2		
33	33	CCM Atas	V	V	V	V	V	V	50psi/c2		
34	34	Motor Room I RML	V	V	V	V	V	V	50psi/c2		
35	35	R Mill Line A, St. 13-14	V	V	V	V	V	V	50psi/c2		
36	36	Finishing Area RML	V	V	V	V	V	V	50psi/c2		
37	37	Finishing / Depan PNL	V	V	V	V	V	V	50psi/c2		
38	38	Finishing / Depan PNL	V	V	V	V	V	V	50psi/c2		
39	39	Oxygen plant	V	V	V	V	V	V	50psi/c2		
40	40	Oxygen plant	V	V	V	V	V	V	50psi/c2		
41	41	lubricant Store II	V	V	V	V	V	V	50psi/c2		
42	42	Vehicle	V	V	V	V	V	V	50psi/c2		
43	43	Billing Press	V	V	V	V	V	V	50psi/c2		
44	44	Dispach / Timbangan	V	V	V	V	V	V	50psi/c2		
45	45	SMS New Building (depan)	V	V	V	V	V	V	50psi/c2		
46	46	SMS New Building It.2 (sblh timur)	V	V	V	V	V	V	50psi/c2		
47	47	SMS New Building (belakang)	V	V	V	V	V	V	50psi/c2		
48	48	SMS New Building (barat)	V	V	V	V	V	V	50psi/c2		
49	49	Depan Work Office	V	V	V	V	V	V	50psi/c2		
50	50	Depan Main Office	V	V	V	V	V	V	50psi/c2		
51	51	Depan Substation PLN	V	V	V	V	V	V	50psi/c2		
52	52	Depan Substation PLN	V	V	V	V	V	V	50psi/c2		
53	53	Motor Room II RML	V	V	V	V	V	V	50psi/c2		
54	54	RGS RML	V	V	V	V	V	V	50psi/c2		
55	55	Rolling Mill Line B	V	V	V	V	V	V	50psi/c2		
56	56	Depan Colling Tower SMS	V	V	V	V	V	V	50psi/c2		
57	57	Samping Colling Tower SMS	V	V	V	V	V	V	50psi/c2		
58	58	Belakang Colling Tower SMS	V	V	V	V	V	V	50psi/c2		

No.	EQUIPMENT	LOKASI	BENSIN		OLIE		TOTAL JAM PEMAKAIAN		PETUGAS	
			Week 2	Week 4	Week 2	Week 4	Week 2	Week 4	Week 2	Week 4
1	POMPA HONDA G200	Office SHE	Ada	Ada	Ada	Ada	6 jam		Wawan	

No.	EQUIPMENT	LOKASI	VALVE IN LET		VALVE OUT LET		PETUGAS			
			Week 2	Week 4	Week 2	Week 4	Week 2	PRESSURE	Week 4	PRESSURE
1	POMPA 37 Kw	Pump House SMS	BANK	BANK	BANK	BANK	Wawan			
2	POMPA DISEL	Pump House SMS	"	"	"	"	"	"		
3	POMPA 110 KW	Pump House SMS	"	"	"	"	"	"		

Sidoarjo, 28/4/2023

AK3 Kebakaran

(.....)



## CONTROL PERALATAN HYDRANT

Nomor : SMK3L-En/ISP/FR-22-08  
 Revisi : 04  
 Tanggal : 01 Maret 2023

BULAN : Mei 2023

SL No.	HYDRANT	LOKASI	PIPE HYDRANT	VALVE HYDRANT	MACHINO	HOSE HYDRANT	BOX HYDRANT	NOZZLE	PRESSURE	TANGGAL	PETUGAS
1	1	Rolling Mill Line B	V	V	V	V	V	V	SIV/C2		
2	2	Rolling Mill Line B	V	V	V	V	V	V	SIV/C2		
3	3	Rolling Mill Line B	V	V	V	V	V	V	SIV/C2		
4	4	Rolling Mill Line A Atas	V	V	V	V	V	V	SIV/C2		
5	5	Rolling Mill Line A	V	V	V	V	V	V	CIV/C2		
6	6	Rolling Mill / BRF	V	V	V	V	V	V	SIV/C1		
7	7	Billet Bay / Ido Tank	V	V	V	V	V	V	SIV/C2		
8	8	Clary P.House RML	V	V	V	V	V	V	SIV/C2		
9	9	Clary P.House RML	V	V	V	V	V	V	CIV/C2		
10	10	LRF Atas	V	V	V	V	V	V	SIV/C2		
11	11	SMS Ladle Burner	V	V	V	V	V	V	CIV/C2		
12	12	CCM Bawah	V	V	V	V	V	V	SIV/C2		
13	13	Charging Pit Sebelah Utara	V	V	V	V	V	V	SIV/C2		
14	14	SMS Bawah	V	V	V	V	V	V	SIV/C2		
15	15	Charging Pit Sebelah Selatan	V	V	V	V	V	V	SIV/C2		
16	16	Gudang Kapur Sebelah Timur	V	V	V	V	V	V	SIV/C2		
17	17	Store Permanent	V	V	V	V	V	V	SIV/C2		
18	18	Store Permanent	V	V	V	V	V	V	SIV/C2		
19	19	Store Permanent	V	V	V	V	V	V	SIV/C2		
20	20	Lubricant Store	V	V	V	V	V	V	SIV/C2		
21	21	Billet Bay	V	V	V	V	V	V	SIV/C2		
22	22	Billet Bay	V	V	V	V	V	V	SIV/C2		
23	23	Billet Bay	V	V	V	V	V	V	SIV/C2		
24	24	Depan PLN, Sub Station	V	V	V	V	V	V	SIV/C2		
25	25	SMS Atas	V	V	V	V	V	V	SIV/C2		
26	26	SMS/Pintu Masuk Hopper	V	V	V	V	V	V	SIV/C2		
27	27	WTP RML	V	V	V	V	V	V	SIV/C2		
28	28	Belakang Kantin	V	V	V	V	V	V	SIV/C2		
29	29	Belakang Main Office	V	V	V	V	V	V	SIV/C2		
30	30	Belakang Main Office	V	V	V	V	V	V	SIV/C2		
31	31	Control Room SMS Atas	V	V	V	V	V	V	SIV/C2		
32	32	Pulpit CCM	V	V	V	V	V	V	SIV/C2		
33	33	CCM Atas	V	V	V	V	V	V	SIV/C2		
34	34	Motor Room I RML	V	V	V	V	V	V	SIV/C2		
35	35	R.Mill Line A, St 13-14	V	V	V	V	V	V	SIV/C2		
36	36	Finishing Area RML	V	V	V	V	V	V	SIV/C2		
37	37	Finishing / Depan PNL	V	V	V	V	V	V	SIV/C2		
38	38	Finishing / Depan PNL	V	V	V	V	V	V	SIV/C2		
39	39	Oxygen plant	V	V	V	V	V	V	SIV/C2		
40	40	Oxygen plant	V	V	V	V	V	V	SIV/C2		
41	41	lubricant Store II	V	V	V	V	V	V	SIV/C2		
42	42	Vehicle	V	V	V	V	V	V	SIV/C2		
43	43	Billing Press	V	V	V	V	V	V	SIV/C2		
44	44	Dispach / Timbangan	V	V	V	V	V	V	SIV/C2		
45	45	SMS New Building (depan)	V	V	V	V	V	V	SIV/C2		
46	46	SMS New Building lt.2 (sblh timur)	V	V	V	V	V	V	SIV/C2		
47	47	SMS New Building (belakang)	V	V	V	V	V	V	SIV/C2		
48	48	SMS New Building (barat)	V	V	V	V	V	V	SIV/C2		
49	49	Depan Work Office	V	V	V	V	V	V	SIV/C2		
50	50	Depan Main Office	V	V	V	V	V	V	SIV/C2		
51	51	Depan Substation PLN	V	V	V	V	V	V	SIV/C2		
52	52	Depan Substation PLN	V	V	V	V	V	V	SIV/C2		
53	53	Motor Room II RML	V	V	V	V	V	V	SIV/C2		
54	54	RGS RML	V	V	V	V	V	V	SIV/C2		
55	55	Rolling Mill Line B	V	V	V	V	V	V	SIV/C2		
56	56	Depan Colling Tower SMS	V	V	V	V	V	V	SIV/C2		
57	57	Samping Colling Tower SMS	V	V	V	V	V	V	SIV/C2		
58	58	Belakang Colling Tower SMS	V	V	V	V	V	V	SIV/C2		

No.	EQUIPMENT	LOKASI	BENSIN		OLIE		TOTAL JAM PEMAKAIAN		PETUGAS	
			Week 2	Week 4	Week 2	Week 4	Week 2	Week 4	Week 2	Week 4
1	POMPA HONDA G200	Office SHE	Ada	Ada	Ada	Ada	6 jam		wawan.	

No.	EQUIPMENT	LOKASI	VALVE IN LET		VALVE OUTLET		PETUGAS			
			Week 2	Week 4	Week 2	Week 4	Week 2	Pressure	Week 4	Pressure
1	POMPA 37 Kw	Pump House SMS	Balk	Balk	Balk	Balk	wawan	wawan		
2	POMPA DISEL	Pump House SMS	"	"	"	"	"	"		
3	POMPA 110 KW	Pump House SMS	"	"	"	"	"	"		

Sidoarjo.... 31/5/2023

AK3 Kebakaran

A. ....

### CONTROL PERALATAN HYDRANT

Nomor : SMK3L-En/ISP/FR-22-08  
 Revisi : 04  
 Tanggal : 01 Maret 2023

BULAN : Juni 2023

SL No.	HYDRANT	LOKASI	PIPE HYDRANT	VALVE HYDRANT	MACHINO	HOSE HYDRANT	BOX HYDRANT	NOZZLE	PRESSURE	TANGGAL	PETUGAS
1	1	Rolling Mill Line B	V	V	V	V	V	V	Sky/L2		
2	2	Rolling Mill Line B	V	V	V	V	V	V	Sky/L2		
3	3	Rolling Mill Line B	V	V	V	V	V	V	Sky/L2		
4	4	Rolling Mill Line A Atas	V	V	V	V	V	V	Sky/L2		
5	5	Rolling Mill Line A	V	V	V	V	V	V	Sky/L2		
6	6	Rolling Mill / BRF	V	V	V	V	V	V	Sky/L2		
7	7	Billet Bay / Ido Tank	V	V	V	V	V	V	Sky/L2		
8	8	Clary P.House RML	V	V	V	V	V	V	Sky/L2		
9	9	Clary P.House RML	V	V	V	V	V	V	Sky/L2		
10	10	LRF Atas	V	V	V	V	V	V	Sky/L2		
11	11	SMS Ladle Burner	V	V	V	V	V	V	Sky/L2		
12	12	CCM Bahaw	V	V	V	V	V	V	Sky/L2		
13	13	Charging Pit Sebelah Utara	V	V	V	V	V	V	Sky/L2		
14	14	SMS Bahaw	V	V	V	V	V	V	Sky/L2		
15	15	Charging Pit Sebelah Selatan	V	V	V	V	V	V	Sky/L2		
16	16	Gudang Kapur Sebelah Timur	V	V	V	V	V	V	Sky/L2		
17	17	Store Permanent	V	V	V	V	V	V	Sky/L2		
18	18	Store Permanent	V	V	V	V	V	V	Sky/L2		
19	19	Store Permanent	V	V	V	V	V	V	Sky/L2		
20	20	Lubricant Store	V	V	V	V	V	V	Sky/L2		
21	21	Billet Bay	V	V	V	V	V	V	Sky/L2		
22	22	Billet Bay	V	V	V	V	V	V	Sky/L2		
23	23	Billet Bay	V	V	V	V	V	V	Sky/L2		
24	24	Depan PLN. Sub.Station	V	V	V	V	V	V	Sky/L2		
25	25	SMS Atas	V	V	V	V	V	V	Sky/L2		
26	26	SMS/Pintu Masuk Hopper	V	V	V	V	V	V	Sky/L2		
27	27	WTP RML	V	V	V	V	V	V	Sky/L2		
28	28	Belakang Kantin	V	V	V	V	V	V	Sky/L2		
29	29	Belakang Main Office	V	V	V	V	V	V	Sky/L2		
30	30	Belakang Main Office	V	V	V	V	V	V	Sky/L2		
31	31	Control Room SMS Atas	V	V	V	V	V	V	Sky/L2		
32	32	Pulpit CCM	V	V	V	V	V	V	Sky/L2		
33	33	CCM Atas	V	V	V	V	V	V	Sky/L2		
34	34	Motor Room I RML	V	V	V	V	V	V	Sky/L2		
35	35	R.Mill Line A, St. 13-14	V	V	V	V	V	V	Sky/L2		
36	36	Finishing Area RML	V	V	V	V	V	V	Sky/L2		
37	37	Finishing / Depan PNL	V	V	V	V	V	V	Sky/L2		
38	38	Finishing / Depan PNL	V	V	V	V	V	V	Sky/L2		
39	39	Oxygen plant	V	V	V	V	V	V	Sky/L2		
40	40	Oxygen plant	V	V	V	V	V	V	Sky/L2		
41	41	lubricant Store II	V	V	V	V	V	V	Sky/L2		
42	42	Vehicle	V	V	V	V	V	V	Sky/L2		
43	43	Billing Press	V	V	V	V	V	V	Sky/L2		
44	44	Dispach / Timbangan	V	V	V	V	V	V	Sky/L2		
45	45	SMS New Building (depan)	V	V	V	V	V	V	Sky/L2		
46	46	SMS New Building lt.2 (sblh timur)	V	V	V	V	V	V	Sky/L2		
47	47	SMS New Building (belakang)	V	V	V	V	V	V	Sky/L2		
48	48	SMS New Building (barat)	V	V	V	V	V	V	Sky/L2		
49	49	Depan Work Office	V	V	V	V	V	V	Sky/L2		
50	50	Depan Main Office	V	V	V	V	V	V	Sky/L2		
51	51	Depan Substation PLN	V	V	V	V	V	V	Sky/L2		
52	52	Depan Substation PLN	V	V	V	V	V	V	Sky/L2		
53	53	Motor Room II RML	V	V	V	V	V	V	Sky/L2		
54	54	RGS RML	V	V	V	V	V	V	Sky/L2		
55	55	Rolling Mill Line B	V	V	V	V	V	V	Sky/L2		
56	56	Depan Colling Tower SMS	V	V	V	V	V	V	Sky/L2		
57	57	Samping Colling Tower SMS	V	V	V	V	V	V	Sky/L2		
58	58	Belakang Colling Tower SMS	V	V	V	V	V	V	Sky/L2		

No	EQUIPMENT	LOKASI	BENSIN		OLIE		TOTAL JAM PEMAKAIAN		PETUGAS	
			Week 2	Week 4	Week 2	Week 4	Week 2	Week 4	Week 2	Week 4
1	POMPA HONDA G200	Office SHE	Ada	Ada	Ada	Ada	Glam		wawan	

No	EQUIPMENT	LOKASI	VALVE IN LET		VALVE OUT LET		PETUGAS			
			Week 2	Week 4	Week 2	Week 4	Week 2	Pressure	Week 4	Pressure
1	POMPA 37 Kw	Pump House SMS	BAWE	BAWE	BAWE	BAWE	wawan	wawan		
2	POMPA DISEL	Pump House SMS	"	"	"	"	"	"	"	
3	POMPA 110 KW	Pump House SMS	"	"	"	"	"	"	"	

Sidoarjo... 28/6/2023

AK3 Kebakaran

(.....)  
AHM

### CONTROL PERALATAN HYDRANT

Nomor : SMK3L-En/ISP/FR-22-08  
 Revisi : 04  
 Tanggal : 01 Maret 2023

BULAN : JULI 2023

SL No.	HYDRANT	LOKASI	PIPE HYDRANT	VALVE HYDRANT	MACHINO	HOSE HYDRANT	BOX HYDRANT	NOZZLE	PRESSURE	TANGGAL	PETUGAS
1	1	Rolling Mill Line B	V	V	V	V	V	V	Say/L2		
2	2	Rolling Mill Line B	V	V	V	V	V	V	Say/L2		
3	3	Rolling Mill Line B	V	V	V	V	V	V	Say/L2		
4	4	Rolling Mill Line A Atas	V	V	V	V	V	V	Say/L2		
5	5	Rolling Mill Line A	V	V	V	V	V	V	Say/L2		
6	6	Rolling Mill / BRF	V	V	V	V	V	V	Say/L2		
7	7	Billet Bay / Ido Tank	V	V	V	V	V	V	Say/L2		
8	8	Clary P.House RML	V	V	V	V	V	V	Say/L2		
9	9	Clary P.House RML	V	V	V	V	V	V	Say/L2		
10	10	LRF Atas	V	V	V	V	V	V	Say/L2		
11	11	SMS Ladle Burner	V	V	V	V	V	V	Say/L2		
12	12	CCM Bawah	V	V	V	V	V	V	Say/L2		
13	13	Charging Pit Sebelah Utara	V	V	V	V	V	V	Say/L2		
14	14	SMS Bawah	V	V	V	V	V	V	Say/L2		
15	15	Charging Pit Sebelah Selatan	V	V	V	V	V	V	Say/L2		
16	16	Gudang Kapur Sebelah Timur	V	V	V	V	V	V	Say/L2		
17	17	Store Permanent	V	V	V	V	V	V	Say/L2		
18	18	Store Permanent	V	V	V	V	V	V	Say/L2		
19	19	Store Permanent	V	V	V	V	V	V	Say/L2		
20	20	Lubricant Store	V	V	V	V	V	V	Say/L2		
21	21	Billet Bay	V	V	V	V	V	V	Say/L2		
22	22	Billet Bay	V	V	V	V	V	V	Say/L2		
23	23	Billet Bay	V	V	V	V	V	V	Say/L2		
24	24	Depan PLN. Sub.Station	V	V	V	V	V	V	Say/L2		
25	25	SMS Atas	V	V	V	V	V	V	Say/L2		
26	26	SMS/Pintu Masuk Hopper	V	V	V	V	V	V	Say/L2		
27	27	WTP RML	V	V	V	V	V	V	Say/L2		
28	28	Belakang Kantin	V	V	V	V	V	V	Say/L2		
29	29	Belakang Main Office	V	V	V	V	V	V	Say/L2		
30	30	Belakang Main Office	V	V	V	V	V	V	Say/L2		
31	31	Control Room SMS Atas	V	V	V	V	V	V	Say/L2		
32	32	Pulpit CCM	V	V	V	V	V	V	Say/L2		
33	33	CCM Atas	V	V	V	V	V	V	Say/L2		
34	34	Motor Room I RML	V	V	V	V	V	V	Say/L2		
35	35	R.Mill Line A, St. 13-14	V	V	V	V	V	V	Say/L2		
36	36	Finishing Area RML	V	V	V	V	V	V	Say/L2		
37	37	Finishing / Depan PNL	V	V	V	V	V	V	Say/L2		
38	38	Finishing / Depan PNL	V	V	V	V	V	V	Say/L2		
39	39	Oxygen plant	V	V	V	V	V	V	Say/L2		
40	40	Oxygen plant	V	V	V	V	V	V	Say/L2		
41	41	lubricant Store II	V	V	V	V	V	V	Say/L2		
42	42	Vehicle	V	V	V	V	V	V	Say/L2		
43	43	Billing Press	V	V	V	V	V	V	Say/L2		
44	44	Dispach / Timbangan	V	V	V	V	V	V	Say/L2		
45	45	SMS New Building (depan)	V	V	V	V	V	V	Say/L2		
46	46	SMS New Building lt.2 (sblh timur)	V	V	V	V	V	V	Say/L2		
47	47	SMS New Building (belakang)	V	V	V	V	V	V	Say/L2		
48	48	SMS New Building (barat)	V	V	V	V	V	V	Say/L2		
49	49	Depan Work Office	V	V	V	V	V	V	Say/L2		
50	50	Depan Main Office	V	V	V	V	V	V	Say/L2		
51	51	Depan Substation PLN	V	V	V	V	V	V	Say/L2		
52	52	Depan Substation PLN	V	V	V	V	V	V	Say/L2		
53	53	Motor Room II RML	V	V	V	V	V	V	Say/L2		
54	54	RGS RML	V	V	V	V	V	V	Say/L2		
55	55	Rolling Mill Line B	V	V	V	V	V	V	Say/L2		
56	56	Depan Colling Tower SMS	V	V	V	V	V	V	Say/L2		
57	57	Samping Colling Tower SMS	V	V	V	V	V	V	Say/L2		
58	58	Belakang Colling Tower SMS	V	V	V	V	V	V	Say/L2		

No.	EQUIPMENT	LOKASI	BENSIN		OLIE		TOTAL JAM PEMAKAIAN		PETUGAS	
			Week 2	Week 4	Week 2	Week 4	Week 2	Week 4	Week 2	Week 4
1	POMPA HONDA G200	Office SHE	Ada	Ada	Ada	Ada	6 jam		wawan	.

No.	EQUIPMENT	LOKASI	VALVE IN LET		VALVE OUT LET		PETUGAS			
			Week 2	Week 4	Week 2	Week 4	Week 2	Pressure	Week 4	Pressure
1	POMPA 37 Kw	Pump House SMS	Balir	Balir	Balir	Balir	wawan	wawan		
2	POMPA DISSEL	Pump House SMS	"	"	"	"	"	"	"	
3	POMPA 110 KW	Pump House SMS	"	"	"	"	"	"	"	

Sidoarjo 27/7/2023

AK3 Kebakaran

(.....)  
Ahy

### CONTROL PERALATAN HYDRANT

Nomor : SMK3L-En/ISP/FR-22-08  
 Revisi : 04  
 Tanggal : 01 Maret 2023

BULAN : Agustus 2023

SL No.	HYDRANT	LOKASI	PIPE HYDRANT	VALVE HYDRANT	MACHINO	HOSE HYDRANT	BOX HYDRANT	NOZZLE	PRESSURE	TANGGAL	PETUGAS
1	1	Rolling Mill Line B	V	V	V	V	V	V	5V/C		
2	2	Rolling Mill Line B	V	V	V	V	V	V	5V/C		
3	3	Rolling Mill Line B	V	V	V	V	V	V	5V/C		
4	4	Rolling Mill Line A Atas	V	V	V	V	V	V	5V/C		
5	5	Rolling Mill Line A	V	V	V	V	V	V	5V/C		
6	6	Rolling Mill / BRF	V	V	V	V	V	V	5V/C		
7	7	Billet Bay / Ido Tank	V	V	V	V	V	V	5V/C		
8	8	Clary P House RML	V	V	V	V	V	V	5V/C		
9	9	Clary P House RML	V	V	V	V	V	V	5V/C		
10	10	LRF Atas	V	V	V	V	V	V	5V/C		
11	11	SMS Ladle Burner	V	V	V	V	V	V	CV/C		
12	12	CCM Bawah	V	V	V	V	V	V	CV/C		
13	13	Charging Pit Sebelah Utara	V	V	V	V	V	V	CV/C		
14	14	SMS Bawah	V	V	V	V	V	V	CV/C		
15	15	Charging Pit Sebelah Selatan	V	V	V	V	V	V	CV/C		
16	16	Gudang Kapur Sebelah Timur	V	V	V	V	V	V	CV/C		
17	17	Store Permanent	V	V	V	V	V	V	CV/C		
18	18	Store Permanent	V	V	V	V	V	V	CV/C		
19	19	Store Permanent	V	V	V	V	V	V	CV/C		
20	20	Lubricant Store	V	V	V	V	V	V	SV/C		
21	21	Billet Bay	V	V	V	V	V	V	SV/C		
22	22	Billet Bay	V	V	V	V	V	V	SV/C		
23	23	Billet Bay	V	V	V	V	V	V	SV/C		
24	24	Depan PLN. Sub Station	V	V	V	V	V	V	SV/C		
25	25	SMS Atas	V	V	V	V	V	V	SV/C		
26	26	SMS/Pintu Masuk Hopper	V	V	V	V	V	V	SV/C		
27	27	WTP RML	V	V	V	V	V	V	SV/C		
28	28	Belakang Kantin	V	V	V	V	V	V	SV/C		
29	29	Belakang Main Office	V	V	V	V	V	V	SV/C		
30	30	Belakang Main Office	V	V	V	V	V	V	SV/C		
31	31	Control Room SMS Atas	V	V	V	V	V	V	SV/C		
32	32	Pulpit CCM	V	V	V	V	V	V	SV/C		
33	33	CCM Atas	V	V	V	V	V	V	SV/C		
34	34	Motor Room I RML	V	V	V	V	V	V	SV/C		
35	35	R Mill Line A. St. 13-14	V	V	V	V	V	V	SV/C		
36	36	Finishing Area RML	V	V	V	V	V	V	SV/C		
37	37	Finishing / Depan PNL	V	V	V	V	V	V	SV/C		
38	38	Finishing / Depan PNL	V	V	V	V	V	V	SV/C		
39	39	Oxygen plant	V	V	V	V	V	V	SV/C		
40	40	Oxygen plant	V	V	V	V	V	V	SV/C		
41	41	lubricant Store II	V	V	V	V	V	V	SV/C		
42	42	Vehicle	V	V	V	V	V	V	SV/C		
43	43	Billing Press	V	V	V	V	V	V	SV/C		
44	44	Dispach / Timbangan	V	V	V	V	V	V	SV/C		
45	45	SMS New Building (depan)	V	V	V	V	V	V	CV/C		
46	46	SMS New Building lt.2 (sblh timur)	V	V	V	V	V	V	SV/C		
47	47	SMS New Building (belakang)	V	V	V	V	V	V	SV/C		
48	48	SMS New Building (barat)	V	V	V	V	V	V	SV/C		
49	49	Depan Work Office	V	V	V	V	V	V	CV/C		
50	50	Depan Main Office	V	V	V	V	V	V	CV/C		
51	51	Depan Substation PLN	V	V	V	V	V	V	SV/C		
52	52	Depan Substation PLN	V	V	V	V	V	V	SV/C		
53	53	Motor Room II RML	V	V	V	V	V	V	SV/C		
54	54	RGS RML	V	V	V	V	V	V	SV/C		
55	55	Rolling Mill Line B	V	V	V	V	V	V	SV/C		
56	56	Depan Colling Tower SMS	V	V	V	V	V	V	SV/C		
57	57	Samping Colling Tower SMS	V	V	V	V	V	V	SV/C		
58	58	Belakang Colling Tower SMS	V	V	V	V	V	V	SV/C		

No.	EQUIPMENT	LOKASI	BENSIN		OLIE		TOTAL JAM PEMAKAIAN		PETUGAS	
			Week 2	Week 4	Week 2	Week 4	Week 2	Week 4	Week 2	Week 4
1	POMPA HONDA G200	Office SHE	Ada	Ada	Ada	Ada	6 jam		wawan.	

No.	EQUIPMENT	LOKASI	VALVE IN LET		VALVE OUTLET		PETUGAS			
			Week 2	Week 4	Week 2	Week 4	Week 2	Pressure	Week 4	Pressure
1	POMPA 37 Kw	Pump House SMS	BAIK	BAIK	BAIK	BAIK	Wawan	Wawan		
2	POMPA DISEL	Pump House SMS	II	II	II	II	II	II	II	
3	POMPA 110 KW	Pump House SMS	II	II	II	II	II	II	II	

Sidoarjo ... 30/8/2023

AK3 Kebakaran

(.....)  
Amby