

CONTROL FIRE HYDRANT PRESSURE TEST

Nomor : SMK3L-En/ISP/FR-22-09

Revisi : 04

Tanggal: 01 Maret 2023

BULAN:..... MINGGU KE:.....

No.	JENIS No. HYDRANT	LOKASI	PRESSURE	KETERANGAN	PETUGAS PARAF
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					

Note : Pressure Normal 4 Kg/Cm3 s/	d 7 Kg/Cm3.
Sidoarjo, AK3 Kebakaran	
()	