

1

2

3

4

5

A

B

C

D

E

F

G

H

POLE LIST:			RANGE OF PLANTING DEPTHS (M)				
			2.5/BELOW	3/BELOW	3.5/BELOW	4/BELOW	5
POLE SIZE	POLE TYPE	QTY	CORRESPONDING HEIGHT OF GOUGE FROM BASE ('Y')				
			3	3.75	4.25	4.75	5.75
13.0mx340mm (TOP 215mm) Single Sec Pole			1				
14.0mx335mm (TOP 210mm) Single Sec Pole			2				
15.0mx350mm (TOP 210mm) Single Sec Pole			2				

TO BE POPULATED ON CONSTRUCTION ISSUE DRAWINGS.

GOUGE MARK & POLE INFORMATION AS SPECIFIED IN BS 1990

15.0 S

SP GB

23 04

CCA

△

'Y'

POLE NUMBER PREFIXES WILL BE AVAILABLE ON CONSTRUCTION ISSUE DRAWINGS.

NOTES

ALL POLES TO COMPLY WITH THE REQUIREMENT OF BS1990 AND E.A.T.S. 43-50

REV	DATE	NAME	CHK'D	APP'D	REMARKS
0	5/12/06	MP	DJP	BF	ORIGINAL ISSUE

amec

AMEC POWER LIMITED, 143 BARKBY ROAD, LEICESTER, LE49LG

Telephone: 01161 2460900 Fax: 01161 2460 032

PROJECT

NIE- ENNISKILLEN TO DERRYLIN 110KV AP1 LINE

This drawing is confidential and the copyright of Amec Power Limited. It must not be copied or passed to a third party without written consent.

TITLE

SINGLE SECTION WOODPOLE GOUGE MARK HEIGHT DETAILS.

DRG. No.

16303696/2481 .0

SHT No.

2

No. of SHTS

5

Scale

N.T.S

\$FILE\$

A

B

C

D

E

F

G

H