


	A	B	C	D	E	F	G	H						
1									1					
2	POLE LIST:			RANGE OF PLANTING DEPTHS (M)										
				2.5/BELOW	3/BELOW	3.5/BELOW	4/BELOW	5						
	POLE SIZE	POLE TYPE	QTY	CORRESPONDING HEIGHT OF GOUGE FROM BASE ('Y')										
				3	3.75	4.25	4.75	5.75						
	13.0mx320mm (TOP 210mm) H-Pole (Pair) 1 14.0mx335mm (TOP 210mm) H-Pole (Pair) 1 15.0mx350mm (TOP 210mm) H-Pole (Pair) 3 16.0mx365mm (TOP 210mm) H-Pole (Pair) 1													
3	TO BE POPULATED ON CONSTRUCTION ISSUE DRAWINGS.								3					
4	POLE NUMBER PREFIXES WILL BE AVAILABLE ON CONSTRUCTION ISSUE DRAWINGS.								4					
5	NOTES ALL POLES TO COMPLY WITH THE REQUIREMENT OF BS1990 AND E.A.T.S. 43-50			REV	DATE	NAME	CHK'D	APP'D	REMARKS	 AMEC POWER LIMITED, 143 BARKBY ROAD, LEICESTER, LE4 9LG Telephone: 01161 2460900 Fax: 01161 2460 032 PROJECT NIE- ENNISKILLEN TO DERRYLIN 110kV AP1 LINE	This drawing is confidential and the copyright of Amec Power Limited. It must not be copied or passed to a third party without written consent.			
				0	5/12/06	MP	DJP	BF	ORIGINAL ISSUE		TITLE SECTION 'H' WOODPOLE GOUGE MARK HEIGHT DETAILS.			
				DRG. No.			SHT No.	No. of SHTS	Scale					
				16303696/2481 .0			3	5	N.T.S					
	A	B	C	D	E	F	G	H						

\$FILE\$



GOUGE MARK & POLE INFORMATION AS SPECIFIED IN BS 1990