

DESCRIPTION		FOR ISSUE			
REV	DATE	BY	CHKD	APPD	
8	03/03/08	JR	GS	PP	



ITEM	DESCRIPTION	BAR MARK	REFERENCE NUMBER	QTY REQ'D	WEIGHT EACH (kg)	REMARKS
1	Crossarm Assy		LSTC/STD/GNA/530	1	666	
2	Wood Pole	TE600	LSTC/STD/PAR/600	2	700	Weight Based on 15m Long Extra Stout Pole
3	Wood Pole Brace Assembly		LSTC/STD/GNA/556	1	64	
4	"H" Pole Foundation Brace	TE603	LSTC/STD/PAR/603	2	57.6	125x75x12 E.A. x 3235 long 4 holes
5	Timber Baulk	TE731	LSTC/STD/PAR/731	2	154	
6	Foundation Block	TE602	LSTC/STD/PAR/602	2	42	
7	Bolts Set M20 x Length to Suit Pole Diameter		LSTC/STD/GNA/555	6	0.5	
8	Square Curved Washer	TE620	LSTC/STD/PAR/620	4	0.2	
9	Square Flat Washer	TE619	LSTC/STD/PAR/619	6	0.1	
10	OPGW Support Assembly		LSTC/STD/GNA/750	1	N/A	
11	Bolts Set M20 x Length to Suit Pole Diameter		LSTC/STD/GNA/555	6	0.5	BS3692 GR8.8
12	Post Insulator		LSTC/STD/GNA/568	3	N/A	To Suit Project Specification
13	Pole Cap		REF:	2	N/A	
14	Anti-Split Bolt M20 Length to Suit Pole Diameter		LSTC/STD/GNA/555	4	0.5	
15	Helicopter / Pole Number Plate	TE687	LSTC/STD/PAR/687	2	N/A	Optional (Supply 8-off M16x45 Bolts, Flat Washers, Nuts & Palnuts)
16	Structure Earthing Assembly		LSTC/STD/GNA/580	1	N/A	
17	ACD Arrangement		M0005126	1	N/A	Powersystems Drawing
18	Pole Mounted Number Plate		M0005131	1	N/A	Powersystems Drawing
19	Property Plate		M0005170	1	N/A	Powersystems Drawing
20	Circuit Colour Plates		M0006434	1	N/A	Powersystems Drawing
21	Bolt Set M16 x 60		BS4190 8.8	12	0.5	c/w Pal-Nut
22	Bolt Set M16 x 30		BS4190 8.8	6	0.5	c/w 3mm Washer
23	Bolt Set M16 x 45		BS4190 8.8	2	0.5	c/w Pal-Nut
24	Step Iron			4		Power Systems drawing

NOTE:

ALL STEELWORK SHALL BE MARKED WITH DISTINGUISHING NUMBERS AND / OR LETTERS.

TO CREATE THE BAR MARK : REPLACE 'LSTC/STD/PAR' WITH 'TE'

I.E. 'LSTC/STD/PAR/610' BECOMES BAR MARK: 'TE610'

TOTAL CALCULATED WEIGHT = 2655kg

GENERAL NOTES:

1. FOR GENERAL ARRANGEMENT SEE LSTC/STD/GNA/500

2 TO BE SUPPLIED WITH ALL NECESSARY FASTENERS

GENERAL NOTES:	CLIENT	TITLE	SCALE	ORIGINAL SIZE			LSTC North: Yorkshire House York Road Little Driffield East Yorkshire YO25 5XA Tel 01377 253617 Fax 01377 259555 LSTC South: Bourne House Office 21 475 Godstone Road Whyteleafe Surrey CR3 0BL Tel 01883 621114
	PowerSystems		(UNLESS OTHERWISE STATED)	A3			
	PROJECT		DATE	CHECKED			
			23/07/07	GS			
			DRAWN	APPROVED			
	OHL -03-132		JR	PP			
			DRAWING NUMBER		REV		
			LSTC/STD/GNA/501		8		



LSTC North: Yorkshire House Yark Road Little Driffield East Yorkshire YO25 5XA Tel 01377 253617 Fax 01377 259555	LSTC South: Bourne House Office 21 475 Godstone Road Whyteleafe Surrey CR3 0BL Tel 01883 621114
---	--