


PLAN

NOMINAL POLE LENGTH



10.5/10.7m

FLAT SEATING ON POLE TO BE
580 LONG x 50 WITH 45° CHAMFER



ALL HOLES
22 DIA.



DETAIL 'A'



DETAIL 'A'



NOTE:
ALL DIMENSIONS ARE IN mm UNLESS
OTHERWISE STATED.

THIS DWG. SUPERSEDES DWG NO.
ESC/G/96-68

J	GENERAL REVISED	H	BAULK NO. AND POLE LENGTH CHANGED	G	GOUGE MARK UPDATED TO 3m
F	BAULK HOLE MOVED	E	2 POSITIONS FOR ADDING WOOD BAULKS INSTEAD OF 1	D	CHANGE TAPER CUT FACES FROM FOUR TO THREE



REVS.	28-1-03	27-4-04	8-10-04	30-09-15	DEC.,16	13.03.17	01.06.17	03.07.18	14.08.20		
INITIAL	A	B	C	D	E	F	G	H	J	K	L
	H.C.C	H.C.C	F.C.	S.K.LAU	WILSON	K.L.CHAN	K.L.CHAN	CHRIS C.	CHRIS C.		

TITLE :

11kV OHL WOOD POLE (10.5/10.7m)

DRAWN: S.C.TO	DATE: 17-3-99
CHECKED: Y.N.S	APPROVED: CHRIS CHEUNG
SCALE: N.T.S.	SHEET(S) IN SET: 3

PROJECT NO.	CONTRACT NO.
-------------	--------------

ASSET MANAGEMENT	DRG. NO. T	G	E	N	5	1	2	0	D	E	3	3	0	0	2	3	0	1	J	S
------------------	------------	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---