

DESCRIPTION		FIRST ISSUE			
REV	DATE	BY	CHKD	APPD	
A	04/08/15	JDH	OC	KM	

ITEM - DESCRIPTION	REFERENCE NUMBER	QTY REQ'D	WEIGHT EACH (kg)	REMARKS
36 Bolt Set M16x40	BS3692 GR8.8	12	0.2	C/W Nut, Palnut, & Flat Washer
37 Bolt Set M20 x Length to Suit Pole Diameter	LSTC/STD/GNA/555	3	0.5	attaching foundation braces to Aux wood poles
38 Bolt Set M20 x Length to Suit Pole Diameter	LSTC/STD/GNA/555	8	0.5	Attaching Cable Support Crossarms to wood poles
39 Bolt Set - TBA	BS3692 GR8.8	TBA	N/A	attaching Single Cable Cleats
40 Bolt Set - TBA	BS3692 GR8.8	TBA	N/A	attaching Trefoil Cable Cleats
41 Helicopter / Pole Number Plate	LSTC/STD/PAR/687	2	N/A	Optional (Supply 8-off M16x45 Bolts, Flat Washers, Nuts & Palnuts)
42 4 Pole Struct. Earthing Assy	LSTC/STD/GNA/574	1	N/A	To include non-conducting cable guard
43 Cable Terminal Support Channel	LSTC/STD/PAR/711	1	83.5	125x65x15 kg/m PFC x 4910 lg 12 holes & 4 x 12thk welded lugs
44 ACD Arrangement	M0005126	1	N/A	Powersystems Drawing
45 Pole Mounted Number Plate	M0005131	1	N/A	Powersystems Drawing
46 Property Plate	M0005170	1	N/A	Powersystems Drawing
47 Circuit Colour Plates	M0006434	1	N/A	Powersystems Drawing
48 Additional ACD Requirements	TBA			Design Subject to Cable Suppliers Cable Support & guarding details
49 Bolt Set M20x75 Long	BS3692 GR8.8	8	N/A	Comprising, Bolt, Nut, Locknut and Flat Washer - for use with Item 17
50 Step Irons	SP 4064873	4		Powersystems Drawing
51 OPGW Brace Bar	LSTC/STD/PAR/713	8		
52 Cable Terminal Support Channel	LSTC/STD/PAR/736	2		125x65x15 kg/m PFC x 4910 lg

ALL STEELWORK SHALL BE MARKED WITH DISTINGUISHING NUMBERS AND / OR LETTERS:

TO CREATE THE BAR MARK: REPLACE 'LSTC/STD/PAR' WITH 'TE'

I.E. 'LSTC/STD/PAR/610' BECOMES 'TE610'

1. TOTAL CALCULATED WEIGHT = 4800 kg APPROX.
2. FOR GENERAL ARRANGEMENT DRAWINGS SEE 15_ 15229_ 40, 41 & 42
3. POLES OF AVERAGE TOP DIAMETER OR ABOVE ARE SUITABLE ONLY. BELOW AVERAGE TOP DIAMETER POLES TO BE REJECTED.
4. ALL BOLTS SUPPLIED COMPLETE WITH NUTS, PALNUTS AND FLAT WASHERS. INCOMING LINE ATTACHMENT PLATE FASTENERS TO HAVE LOCKNUTS FITTED.
5. CABLE GUARDS AND SUPPORT MEMBERS SHOWN ARE TYPICAL ONLY. THESE ITEMS ARE TO BE SUPPLIED BY THE CABLE CONTRACTOR TO SUIT.

CLIENT 	TITLE MATERIAL LIST - 0° ENTRY / TERMINAL 4 POLE STRUCTURE (SHEET 2 OF 2)	SCALE N.T.S (UNLESS OTHERWISE STATED)	ORIGINAL SIZE A4	 LS TRANSMISSION CONSULTANCY LIMITED Yorkshire House York Road Little Driffield East Yorkshire YO25 5XA 01377 253617
		DATE 04/08/15	CHECKED OC	
		DRAWN JDH	APPROVED KM	
		DRAWING NUMBER 19_15229_43	REV A	
SPECIFICATION CUMNOCK - DERSALLOCH ROUTE				

