

						DESCRIPTION
						FIRST ISSUE
						REV A
						DATE 14/09/15
						BY JDH
						CHKD OC
						APPD KM
ITEM - DESCRIPTION		BAR MARK	REFERENCE NUMBER	QTY REQ'D	WEIGHT EACH (kg)	REMARKS
1	Crossarm Assy		LSTC/STD/GNA/532	1	850	
2	Wood Pole	TE666	18_15229_55	2	750	Weight Based on 15m Long Extra Stout Pole
3	Post Insulator		LSTC/STD/GNA/566	3	N/A	To Suit Project Specification
4	"H" Pole Foundation Brace	TE603	LSTC/STD/PAR/603	2	57.6	
5	Timber Baulk	TE601	LSTC/STD/PAR/601	1	135	
6	Foundation Block	TE602	LSTC/STD/PAR/602	2	42	
7	Bolt Set M20 x Length to Suit Pole Diameter		LSTC/STD/GNA/555	6	0.5	
8	Square Curved Washer	TE620	LSTC/STD/PAR/620	5	0.2	
9	Square Flat Washer	TE619	LSTC/STD/PAR/619	4	0.1	
10	Post Insulator Mounting Stool	TE663	LSTC/STD/PAR/663	3	6	
11	Insulated Stay Assembly		LSTC/STD/GNA/560	4	80	
12	Pole Cap		REF :	2	N/A	
13	Anti-Split Bolt M20 x Length to Suit Pole Diameter		LSTC/STD/GNA/555	4	0.5	
14	Bolt Set M20 x Length to Suit Pole Diameter		LSTC/STD/GNA/555	6	0.5	BS3692 GR8.8
15	Stay Attachment Plate	TE606	LSTC/STD/PAR/606	4	7.0	
16	OPGW Tension Assembly (or)		LSTC/STD/GNA/752	1	N/A	Standard - Through Line Assy
16	OPGW Tension Assembly		LSTC/STD/GNA/754	1	N/A	Alternative - Joint Box Assy
17	125kN Tension Insulator Set		LSTC/STD/GNA/564	6	N/A	
18	Helicopter / Pole Number Plate	TE687	LSTC/STD/PAR/687	2	N/A	Optional (Supply 8-off M16x45 Bolts, Flat Washers, Nuts & Palnuts)
19	Structure Earthing Assembly		LSTC/STD/GNA/584	1	N/A	To include non-conducting cable guard
20	ACD Arrangement		M0005126	1	N/A	Powersystems Drawing
21	Pole Mounted Number Plate		M0005131	1	N/A	Powersystems Drawing
22	Property Plate		M0005170	1	N/A	Powersystems Drawing
23	Circuit Colour Plates		M0006434	1	N/A	Powersystems Drawing
24	Bolt Set M20x75 Long		BS3692 GR8.8	16	N/A	Comprising, Bolt, Nut, Locknut and Flat Washer - USE WITH ITEM 15
25	Step Irons		SP 4064873	4		Powersystems Drawing

ALL STEELWORK SHALL BE MARKED WITH DISTINGUISHING NUMBERS AND / OR LETTERS.

TO CREATE THE BAR MARK : REPLACE 'LSTC/STD/PAR' WITH 'TE'
I.E. 'LSTC/STD/PAR/610' BECOMES 'TE610'

TOTAL CALCULATED WEIGHT = 2955kg

CLIENT		TITLE	SCALE	NTS	ORIGINAL SIZE	A4	LS TRANSMISSION CONSULTANCY LIMITED Yorkshire House York Road Little Driffield East Yorkshire YO25 5XA 01377 253617 
			(UNLESS OTHERWISE STATED)		CHECKED	OC	
SPECIFICATION	CUMNOCK - DERSALLOCH ROUTE	5-20° ANGLE STRUCTURE	DATE	14/09/2015	APPROVED	KM	
			DRAWN	JDH	DRAWING NUMBER	19_15229_54	

