

DESCRIPTION					
FIRST ISSUE					
REV	DATE	BY	CHKD	APPD	
A	15/09/15	JDH	OC	KM	

ITEM - DESCRIPTION		BAR MARK	REFERENCE NUMBER	QTY REQ'D	WEIGHT EACH (kg)	REMARKS
1	Crossarm Assy		LSTC/STD/GNA/532	1	851	
2	Wood Pole	TE667	18_15229_62	2	750	Weight Based on 15m Long Extra Stout Pole
3	Post Insulator		LSTC/STD/GNA/566	3	N/A	To Suit Project Spec.
4	"H" Pole Foundation Brace	TE603	LSTC/STD/PAR/603	2	53.4	125x75x12 U.E.A. x 3235 long 4 holes
5	Timber Baulk	TE601	LSTC/STD/PAR/601	1	135	
6	Foundation Block	TE602	LSTC/STD/PAR/602	2	40	
7	Bolt Set M20 x Length to Suit Pole Diameter		LSTC/STD/GNA/555	6	0.5	
8	Square Curved Washer	TE620	LSTC/STD/PAR/620	5	0.2	
9	Square Flat Washer	TE619	LSTC/STD/PAR/619	4	0.1	
10	Post Insulator Mounting Stool	TE667	LSTC/STD/PAR/663	3	6	
11	Insulated Stay Assembly		LSTC/STD/GNA/560	4	N/A	
12	Pole Cap		REF :	2	N/A	
13	Anti-Split Bolt M20 x Length to Suit Pole Diameter		LSTC/STD/GNA/555	4	0.5	
14	Bolt Set M20 x Length to Suit Pole Diameter		LSTC/STD/GNA/555	6	0.5	BS3692 GR8.8
15	Stay Attachment Plate	TE606	LSTC/STD/PAR/606	4	7.0	
16	OPGW Tension Assembly (or)		LSTC/STD/GNA/752	1	N/A	Standard - Through Line Assy
16	OPGW Tension Assembly		LSTC/STD/GNA/754	1	N/A	Alternative - Joint Box Assy
17	125kN Tension Insulator Set		LSTC/STD/GNA/564	6	N/A	
18	Helicopter / Pole Number Plate	TE687	LSTC/STD/PAR/687	2	N/A	Optional (Supply 8-off M16x45 Bolts, Flat Washers, Nuts & Painuts)
19	Structure Earthing Assembly		LSTC/STD/GNA/588	1	N/A	To include non-conducting cable guard
20	ACD Arrangement		M0005126	1	N/A	Powersystems Drawing
21	Pole Mounted Number Plate		M0005131	1	N/A	Powersystems Drawing
22	Property Plate		M0005170	1	N/A	Powersystems Drawing
23	Circuit Colour Plates		M0006434	1	N/A	Powersystems Drawing
24	Bolt Set M20x75 Long		BS3692 GR8.8	16	N/A	Comprising, Bolt, Nut, Locknut and Flat Washer - USE WITH ITEM 15
25	Bolt Set M16x30		BS3692 GR8.8	18	N/A	c/w 3mm washer
26	Bolt Set M16x50		BS3692 GR8.8	12	N/A	c/w pal nut
27	Step Irons		SP 4064873	4		Powersystems Drawing

ALL STEELWORK SHALL BE MARKED WITH DISTINGUISHING NUMBERS AND / OR LETTERS.

TO CREATE THE BAR MARK: REPLACE 'LSTC/STD/PAR' WITH 'TE'
I.E. 'LSTC/STD/PAR/610' BECOMES 'TE610'

TOTAL CALCULATED WEIGHT = 2614kg

CLIENT 	TITLE MATERIAL LIST - 20-35° ANGLE STRUCTURE	SCALE NTS (UNLESS OTHERWISE STATED)		ORIGINAL SIZE A4	LS TRANSMISSION CONSULTANCY LIMITED Yorkshire House York Road Little Driffield East Yorkshire YO25 5XA 01377 253617 
		DATE 15/09/2015	CHECKED OC		
DRAWN JDH		APPROVED KM			
DRAWING NUMBER 19_15229_61		REV A			
SPECIFICATION CUMNOCK - DERSALLOCH ROUTE					

