

DESCRIPTION		FIRST ISSUE			
REV	DATE	BY	CHKD	APPD	
A	15/09/2015	JDH	OC	KM	

ITEM - DESCRIPTION	BAR MARK	REFERENCE NUMBER	QTY REQ'D	WEIGHT EACH (kg)	REMARKS
1 Crossarm Assy		LSTC/STD/GNA/530	1	736	
2 Wood Pole	TE600	18_15229_68	2	750	Weight Based on 15m Long Extra Stout Pole
3 Wood Pole Brace Assembly		LSTC/STD/GNA/556	1	64	
4 "H" Pole Foundation Brace	TE603	LSTC/STD/PAR/603	2	57.6	125x75x12 E.A. x 3235 long 4 holes
5 Timber Baulk	TE731	LSTC/STD/PAR/731	2	154	
6 Foundation Block	TE602	LSTC/STD/PAR/602	2	42	
7 Bolts Set M20 x ^{Length to Suit} Pole Diameter		LSTC/STD/GNA/555	6	0.5	
8 Square Curved Washer	TE620	LSTC/STD/PAR/620	4	0.2	
9 Square Flat Washer	TE619	LSTC/STD/PAR/619	6	0.1	
10 OPGW Support Assembly		LSTC/STD/GNA/750	1	N/A	
11 Bolts Set M20 x ^{Length to Suit} Pole Diameter		LSTC/STD/GNA/555	6	0.5	BS3692 GR8.8
12 Post Insulator		LSTC/STD/GNA/568	3	N/A	To Suit Project Spec.
13 Pole Cap		REF:	2	N/A	
14 Anti-Split Bolt M20 x ^{Length to Suit} Pole Diameter		LSTC/STD/GNA/555	4	0.5	
15 Helicopter / Pole Number Plate	TE687	LSTC/STD/PAR/687	2	N/A	Optional (Supply 8-off M16x45 Bolts, Flat Washers, Nuts & Painuts)
16 Structure Earthing Assembly		LSTC/STD/GNA/580	1	N/A	To include non conducting cable guard
17 ACD Arrangement		M0005126	1	N/A	Powersystems Drawing
18 Pole Mounted Number Plate		M0005131	1	N/A	Powersystems Drawing
19 Property Plate		M0005170	1	N/A	Powersystems Drawing
20 Circuit Colour Plates		M0006434	1	N/A	Powersystems Drawing
21 Bolt Set M16 x 60		BS4190 8.8	12	0.5	c/w Pal-Nut
22 Bolt Set M16 x 30		BS4190 8.8	6	0.5	c/w 3mm Washer
23 Bolt Set M16 x 45		BS4190 8.8	2	0.5	c/w Pal-Nut
24 Step Iron		SP 4064873	4		Power Systems drawing

NOTE:

ALL STEELWORK SHALL BE MARKED WITH DISTINGUISHING NUMBERS AND / OR LETTERS.

TO CREATE THE BAR MARK : REPLACE 'LSTC/STD/PAR' WITH 'TE'

I.E. 'LSTC/STD/PAR/610' BECOMES BAR MARK: 'TE610'

TOTAL CALCULATED WEIGHT = 2655kg

GENERAL NOTES:

- FOR GENERAL ARRANGEMENT SEE 15_15229_66
- TO BE SUPPLIED WITH ALL NECESSARY FASTENERS

GENERAL NOTES:	CLIENT	TITLE	SCALE		ORIGINAL SIZE		 LSTC North: Yorkshire House York Road Little Driffield East Yorkshire YO25 5XA Tel 01377 253617 Fax 01377 259555 LSTC South: Bourne House Office 21 475 Godstone Road Whyteleafe Surrey CR3 0BL Tel 01883 621114
	PROJECT		(UNLESS OTHERWISE STATED)		A3		
			DATE	15/09/2015	CHECKED	OC	
			DRAWN	JDH	APPROVED	KM	
			DRAWING NUMBER		19_15229_67	REV	A