

POLE SCARFED (FOR PFC)
ON BOTH SIDES TO GIVE
50mm FLAT FACE

*PFC SCARFING PARALLEL
WITHIN THE LIMITS OF
200mm - 240mm

DESCRIPTION						
FIRST ISSUE						
REV	DATE	BY	CHKD	APPD		
A	02/05/06	RF	JG	GS		

POLE MARKING REFERENCE

14 - POLE LENGTH
335 - POLE DIA 1.5m FROM BUTT
IF - IMPORTED REDFIR
75 - YEAR OF CREOSOTING
XYZ - SUPPLIERS NAME / MARK

ARROW DIRECTION TOWARDS C/L
OF STRUCTURES (SEE GA DRAWING
FOR DETAILS)

45 DEG

GENERAL NOTES

1. ALL DIMENSIONS ARE IN MILLIMETRES (mm)
2. ALL DRILLINGS TO BE 22mm DIAMETER UNLESS STATED OTHERWISE.
3. USE IN CONJUNCTION WITH THE FOLLOWING:
15_06093_11 : GENERAL ARRANGEMENT DRAWING
19_06093_12 : MATERIAL LIST
4. POLE SIZE BASED ON BS1990 EXTRA STOUT POLES.
5. *SCARF BY REMOVING MINIMAL MATERIAL TO GIVE FINISHED ACROSS FLATS DIMENSION AS CLOSE AS POSSIBLE TO THE REQUIRED POLE TOP SIZE FOR EACH LOCATION.

FOR ACTUAL POLE SIZES REQUIRED AT EACH
LOCATION REFER TO OHL POLE SCHEDULE
DRAWING No. 02_06093_23

6mm DEEP GOUGE MARK

14 335
IF 75
XYZ

297 MIN

100 MIN
FLAT FACE

100 MIN
FLAT FACE

1444

2997

615
450

297 MIN

IMPRESS POLE
SIZE ON BUTT

CLIENT
Enterprise Power Services

TITLE
WOOD POLE SCARFING

SCALE
1:40

ORIGINAL SIZE
A4

DATE
02/05/06

CHECKED
JG

DRAWN
RFisk

APPROVED
GS

DRAWING NUMBER

18_06093_13_SHT 1

REV

A

PROJECT
M1 WIDENING

SHEET 1 OF 4



Yorkshire House
York Road
Little Driffield
East Yorkshire
YO25 5XA
Tel 01377 253617
Fax 01377 259555