

STAY INSULATORS SHALL BE INSTALLED IN SUCH A MANNER THAT, IN THE EVENT OF A FAILURE OF THE STAY BELOW THE INSULATOR POSITION, THE INSULATOR OR ASSEMBLY SHALL HAVE A MINIMUM VERTICAL GROUND CLEARANCE OF 3m UNDER ALL CONDITIONS.

NO SINGLE INSULATOR OR INSULATOR ASSEMBLY SHALL BE MOUNTED HIGHER THAN ANY LIVE EQUIPMENT ON THE SUPPORTING POLE

Technical drawing of a 15m high wood pole assembly, showing components and dimensions. The drawing includes labels for various parts and their dimensions:

- 15mm THK BENT SECTION STRAP (MS) BD004
- 15mm THK BENT PLATE (MS) BD001
- 150 x 75 x 18 PFC (MS) BD002
- TM WOOD POLE LT OUTER
- TM WOOD POLE LT INNER
- TM WOOD POLE RT OUTER
- TM WOOD POLE RT INNER

Dimensions and specifications are provided for each component:

- BD004: 15mm THK BENT SECTION STRAP (MS), 2x M20x75 LUG
- BD001: 10mm THK BENT PLATE (MS), 4x M16x45 LUG
- BD002: 150 x 75 x 18 PFC (MS), 2x M20x75 LUG

The drawing also shows the overall dimensions of the pole assembly, including the height of 15m and the diameter of the pole (150mm).

REV A	DATE 10/02/2022	BY RL	CHKD RL	APPO SG
DESCRIPTION FIRST ISSUE				

[illegible][illegible]

This technical drawing shows a 10 kV line support structure (LST) with two vertical poles. The structure includes cross-arms with insulators for three phases of power lines. A transformer is mounted on a platform between the poles. The drawing is a detailed 3D perspective view.

 CDM RESIDUAL RISK			
❑ DESIGN BASED HAZARDS ARE ACTIVELY ELIMINATED WHERE PRACTICAL. WHERE HAZARDS ARE NOT ELIMINATED THEY ARE IDENTIFIED BY THIS SYMBOL. ❑ HAZARDS / RISKS THAT SHOULD BE CONSIDERED BY A COMPETENT CONTRACTOR ARE NOT IDENTIFIED			
IF IN DOUBT ASK EMPLOYER / DESIGN OFFICE			
	 VIEW CONSTRUCTION THREAT ANALYSIS		
THIS DRAWING IS THE EXCLUSIVE PROPERTY OF THE CLIENT. THE CONTENTS OF THIS DRAWING MUST BE READ IN STRICTLY CONFIDENTIAL MANNER AND MUST NOT BE DISCLOSED TO ANY THIRD PARTY WITHOUT THE CLIENTS WRITTEN CONSENT. USE ONLY FOR THE PURPOSE FOR WHICH IT WAS ISSUED. NO COPYING OR REPRODUCING RETURN ON REQUEST L5 TRANSMISSION CONSULTANCY LIMITED MAKES NO WARRANTIES, EXPRESS OR IMPLIED, THAT COMPLY WITH THIS DRAWING, OR ANY OTHER DOCUMENT ISSUED BY L5C. WITHOUT IT BEING NECESSARY TO ENSURE SAFE SYSTEMS OF WORK OR OPERATION, USERS ARE ADVISED OF THEIR OWN DUTIES UNDER HEALTH AND SAFETY LEGISLATION.			
CLIENT			
PROJECT	BRAINTREE - DUNMOW		
TITLE	GENERAL ARRANGEMENT DRAWING FOR 33kV 1H TERMINAL POLE ARRANGEMENT		
SCALE	1:35	DESIGNED	SG/RL
DATE	10/02/22	CHECKED	RF
DRAWN	RL	APPROVED	SG
 L5C GROUP		http://www.l5c.co.uk Tel : 01377 253617	
ORIGINAL SIZE	DRAWING NUMBER	REV	
A1	15_210521_07	A	