

DESCRIPTION					
DRAFT ISSUE					
REV	DATE	BY	CHKD	APPD	PP
B	22/07/04	JN	GS		PP
DESCRIPTION					
DRAFT ISSUE - REDESIGN OF FOUNDATIONS					
REV	DATE	BY	CHKD	APPD	PP
C	29/07/04	JN	GS		PP

ITEM - DESCRIPTION		REFERENCE NUMBER	QTY REQ'D	WEIGHT EACH (kg)	REMARKS
1	Post Insulator	N/A	3	N/A	To Suit Project Specification
2	Insulator Angled Bracket Support	LSTC/STD/PAR/26	4	6.6	
3	Crossarm Support Channel	LSTC/STD/PAR/35	4	27.9	
4	Intermediate Crossarm	LSTC/STD/PAR/41	2	98.3	
5	Insulator Mounting Plate	LSTC/STD/PAR/24	3	10	
6	Wood Pole	LSTC/STD/PAR/33	2	700	Weight Based on 14m Long Extra Stout Pole
7	Pole Cap	REF:	2	N/A	
8	Farap	EN 975-A1	2	1	DKN Powerline Ltd
9	Coach Screw		2	0.25	10 x 75 Long
10	Anti-Split-Bolt M20x Length to Suit Pole Diameter	LSTC/STD/GNA/23	2	0.5	
11	Bolts M20 x Length to Suit Pole Diameter	LSTC/STD/GNA/23	4	0.5	Attaching 260 PFC to Wood Pole
12	Bolts M20 x 60	EATS. 43 - 96	20	0.25	
13	Foundation Block	EATS-439103	4	40	Type 3
14	"H" Pole Foundation Brace	LSTC/STD/PAR/197	2	53.4	
15	Timber Baulk	EATS-439112	1	115	Type 2
16	Square Curved Washer	EATS-439605	13	0.2	
17	Square Flat Washer	EATS-439604	6	0.1	
18	Bolts M20 x Length to Suit Pole Diameter	LSTC/STD/GNA/23	4	0.5	attaching foundation block to wood pole
19	Bolts M20 x Length to Suit Pole Diameter	LSTC/STD/GNA/23	2	0.5	attaching timber baulk to wood pole
20	Bolts M20 x Length to Suit Pole Diameter	LSTC/STD/GNA/23	2	0.5	attaching foundation brace to wood pole
	Safety Sign	SSE DRG - HO/38/001	2	N/A	1 sign on each pole SSE to Identify Areas of High Risk
	Earthing Attachment Nut	EATS-439554	1	N/A	
	Circuit Identification (Colour Plates)	SSE DRG - HO/39/007		N/A	On One Leg of Structure
	Phase Colour Plates	SSE DRG - HO/38/302		N/A	On One Leg of Structure
	Pole Number Plate	SSE DRG - HO/39/001		N/A	On One Leg of Structure
	Anti Climbing Device	EATS. 43 - 90	2	5	

- 1.TOTAL CALCULATED WEIGHT = 2100 kg APPROX.
- 2.FOR GENERAL ARRANGEMENT DRAWING SEE LSTC/STD/GNA/01
- 3.POLES OF AVERAGE TOP DIAMETER OR ABOVE ARE SUITABLE ONLY.
- BELOW AVERAGE TOP DIAMETER POLES TO BE REJECTED.

CLIENT		TITLE	SCALE	NTS	ORIGINAL SIZE	LS TRANSMISSION CONSULTANCY LIMITED PADDOCK HOUSE 10 MIDDLE STREET SOUTH DRIFFIELD EAST YORKSHIRE YO25 6PT TEL: 01377 240047	
PROJECT 132kV SINGLE CIRCUIT UNEARTHED OVERHEAD LINE			(UNLESS OTHERWISE STATED)		A4		
			DATE	29/07/04	CHECKED		GS
			DRAWN	JN	APPROVED		PP
			DRAWING NUMBER		REV		
			LSTC/STD/GNA/02		C		