

					DESCRIPTION				
					DRAFT ISSUE				
REV	DATE	BY	CHKD	APPD					
B	22/07/04	JN	GS	PP					
DESCRIPTION									
DRAFT ISSUE - REDESIGN OF FOUNDATIONS									
REV	DATE	BY	CHKD	APPD					
C	02/08/04	JN	GS	PP					

ITEM - DESCRIPTION		REFERENCE NUMBER	QTY REQ'D	WEIGHT EACH (kg)	REMARKS
1	Post Insulator	N/A	3	N/A	To Suit Project Specification
2	Stay Strap	LSTC/STD/PAR/43	4	3.6	
3	Crossarm Support Channel	LSTC/STD/PAR/29	4	40.9	
4	Crossarm	LSTC/STD/PAR/44	2	115	
5	Insulator Mounting Plate	LSTC/STD/PAR/24	1	10	
6	Wood Pole	LSTC/STD/PAR/50	2	700	Weight Based on 14m Long Extra Stout Pole
7	Crossarm Bracing Bar	LSTC/STD/PAR/46	4	3.8	
8	Crossarm Bracing Bar	LSTC/STD/PAR/47	1	3	
9	I/L Attachment Strap	LSTC/STD/PAR/27	1	6.6	
10	Erection Strap	LSTC/STD/PAR/40	2	5.7	
11	I/L Attachment Strap	LSTC/STD/PAR/25	2	4.2	
12	Spacers (70x70x50)	LSTC/STD/PAR/28	4	2	
13	ChannelBrace Angle	LSTC/STD/PAR/39	4	2.87	
14	Packing Washer M20 Form 'A'	BS4320	AS REQ'D	N/A	Use As Required to Pack out ChannelBrace Angle.
15	Insulator Assembly	LSTC/STD/GNA/68(bolt) LSTC/STD/GNA/178(int)	6	TBA	125kN Tension Insulator Set Bolted or IntegralDead End to suit project specification
16	Insulated Stay Assembly	LSTC/STD/GNA/72	4	110	
17	Pole Cap	REF:	2	0.5	
18	Farap	EN 795-A1	2	1	DKN Powerline Ltd
19	Coach Screw		2	0.25	10 x 75 Long
20	Anti-Split Bolt M20 Length to Suit Pole Diameter	LSTC/STD/GNA/23	4	0.5	
21	Bolts M20 x 60	EATS. 43 - 96	48	0.25	
22	Bolts M20 x Length to Suit Pole Diameter	LSTC/STD/GNA/23	6	0.5	Attaching 260 PFC to Wood Pole
23	Bolts M20 x 120	EATS. 43 - 96	4	0.5	
24	Foundation Block	EATS - 439103	4	40	Type 3
25	Timber Baulk	EATS. 439112	2	115	Type 2
26	"H" Pole Foundation Brace	LSTC/STD/PAR/197	2	53.4	
27	Square Curved Washer	EATS - 439605	12	0.2	
28	Square Flat Washer	EATS - 439604	8	0.1	
29	Bolts M20 x Length to Suit Pole Diameter	LSTC/STD/GNA/23	4	0.5	attaching foundation blocks to wood poles
30	Bolts M20 x Length to Suit Pole Diameter	LSTC/STD/GNA/23	2	0.5	attaching timber baulk to wood poles
31	Bolts M20 x Length to Suit Pole Diameter	LSTC/STD/GNA/23	2	0.5	attaching foundation braces to wood poles
	Earthing Attachment Nut	EATS-439554	1	N/A	
	Circuit ID (Colour Plates)	SSE DRG - H0/39/007		N/A	On One Leg of Structure
	Phase Colour Plates	SSE DRG - H0/38/302		N/A	On One Leg of Structure
	Pole Number Plate	SSE DRG - H0/39/001		N/A	On One Leg of Structure
	Anti Climbing Device	EATS. 43 - 90	2	5	
	Safety Sign	SSE DRG - H0/38/001		N/A	One Sign on Each Pole SSE to Identify Areas of High Risk

- 1.TOTAL CALCULATED WEIGHT = 2900 kg APPROX.
- 2.FOR GENERAL ARRANGEMENT DRAWINGS SEE LSTC/STD/GNA/15 & 16
- 3.POLES OF AVERAGE TOP DIAMETER OR ABOVE ARE SUITABLE ONLY. BELOW AVERAGE TOP DIAMETER POLES TO BE REJECTED.

CLIENT		TITLE	SCALE		ORIGINAL SIZE		LS TRANSMISSION CONSULTANCY LIMITED PADDOCK HOUSE 10 MIDDLE STREET SOUTH DRIFFIELD EAST YORKSHIRE YO25 6PT TEL: 01377 240047
SSE POWER DISTRIBUTION			(UNLESS OTHERWISE STATED)		A4		
PROJECT 132kV SINGLE CIRCUIT UNEARTHED OVERHEAD LINE			DATE		CHECKED		
			02/08/04		GS		
			DRAWN		APPROVED		
			JN		PP		
			DRAWING NUMBER			REV	
			LSTC/STD/GNA/17			C	