

						DESCRIPTION	FOR ISSUE			
						REV 8	DATE 31/07/07	BY JR	CHKD GS	APPD PP
ITEM - DESCRIPTION		BAR MARK	REFERENCE NUMBER	QTY REQ'D	WEIGHT EACH (kg)	REMARKS				
1	Crossarm Assy		LSTC/STD/GNA/532	1	850					
2	Wood Pole	TE666	LSTC/STD/PAR/666	2	700	Weight Based on 14m Long Extra Stout Pole				
3	Post Insulator		LSTC/STD/GNA/566	3	N/A	To Suit Project Specification				
4	"H" Pole Foundation Brace	TE603	LSTC/STD/PAR/603	2	57.6					
5	Timber Baulk	TE601	LSTC/STD/PAR/601	1	135					
6	Foundation Block	TE602	LSTC/STD/PAR/602	2	42					
7	Bolt Set M20 x Length to Suit Pole Diameter		LSTC/STD/GNA/555	6	0.5					
8	Square Curved Washer	TE620	LSTC/STD/PAR/620	5	0.2					
9	Square Flat Washer	TE619	LSTC/STD/PAR/619	4	0.1					
10	Post Insulator Mounting Stool	TE663	LSTC/STD/PAR/663	3	6					
11	Insulated Stay Assembly		LSTC/STD/GNA/560	4	80					
12	Pole Cap		REF:	2	N/A					
13	Anti-Split Bolt M20 Length to Suit Pole Diameter		LSTC/STD/GNA/555	4	0.5					
14	Bolt Set M20 x Length to Suit Pole Diameter		LSTC/STD/GNA/555	6	0.5	BS3692 GR8.8				
15	Stay Attachment Plate	TE606	LSTC/STD/PAR/606	4	7.0					
16	OPGW Tension Assembly (or)		LSTC/STD/GNA/752	1	N/A	Standard - Through Line Assy				
16	OPGW Tension Assembly		LSTC/STD/GNA/754	1	N/A	Alternative - Joint Box Assy				
17	125kN Tension Insulator Set		LSTC/STD/GNA/564	6	N/A					
18	Helicopter / Pole Number Plate	TE687	LSTC/STD/PAR/687	2	N/A	Optional (Supply 8-off M16x45 Bolts, Flat Washers, Nuts & Painuts)				
19	Structure Earthing Assembly		LSTC/STD/GNA/584	1	N/A					
20	ACD Arrangement		M0005126	1	N/A	Powersystems Drawing				
21	Pole Mounted Number Plate		M0005131	1	N/A	Powersystems Drawing				
22	Property Plate		M0005170	1	N/A	Powersystems Drawing				
23	Circuit Colour Plates		M0006434	1	N/A	Powersystems Drawing				
24	Bolt Set M20x75 Long		BS3692 GR8.8	16	N/A	Comprising, Bolt, Nut, Locknut and Flat Washer - for use with Item 15				
25	Step Irons			4		Powersystems Drawing				
ALL STEELWORK SHALL BE MARKED WITH DISTINGUISHING NUMBERS AND / OR LETTERS. TO CREATE THE BAR MARK : REPLACE 'LSTC/STD/PAR' WITH 'TE' I.E. 'LSTC/STD/PAR/610' BECOMES 'TE610'										
TOTAL CALCULATED WEIGHT = 2955kg										
CLIENT PowerSystems		TITLE MATERIAL LIST - 5-20° ANGLE STRUCTURE		SCALE NTS (UNLESS OTHERWISE STATED) DATE 28/10/04		ORIGINAL SIZE A4 CHECKED GS		LS TRANSMISSION CONSULTANCY LIMITED Yorkshire House York Road Little Driffield East Yorkshire YO25 5XA 01377 253617		
SPECIFICATION OHL-03-132				DRAWN R.T.J		APPROVED PP				
				DRAWING NUMBER LSTC/STD/GNA/507		REV 8				