

						DESCRIPTION FOR ISSUE				
						REV	DATE	BY	CHKD	APPD
						8	01/08/07	JR	CS	PP
ITEM - DESCRIPTION		BAR MARK	REFERENCE NUMBER	QTY REQ'D	WEIGHT EACH (kg)	REMARKS				
1	Crossarm Assy		LSTC/STD/GNA/532	1	851					
2	Wood Pole	TE667	LSTC/STD/PAR/667	2	700	Weight Based on 14m Long Extra Stout Pole				
3	Post Insulator		LSTC/STD/GNA/566	3	N/A	To Suit Project Specification				
4	"H" Pole Foundation Brace	TE603	LSTC/STD/PAR/603	2	53.4	125x75x12 U.E.A. x 3235 long 4 holes				
5	Timber Baulk	TE601	LSTC/STD/PAR/601	1	135					
6	Foundation Block	TE602	LSTC/STD/PAR/602	2	40					
7	Bolt Set M20 x Length to Suit Pole Diameter		LSTC/STD/GNA/555	6	0.5					
8	Square Curved Washer	TE620	LSTC/STD/PAR/620	5	0.2					
9	Square Flat Washer	TE619	LSTC/STD/PAR/619	4	0.1					
10	Post Insulator Mounting Stool	TE667	LSTC/STD/PAR/663	3	6					
11	Insulated Stay Assembly		LSTC/STD/GNA/560	4	N/A					
12	Pole Cap		REF:	2	N/A					
13	Anti-Split Bolt M20 Length to Suit Pole Diameter		LSTC/STD/GNA/555	4	0.5					
14	Bolt Set M20 x Length to Suit Pole Diameter		LSTC/STD/GNA/555	6	0.5	BS3692 GR8.8				
15	Stay Attachment Plate	TE606	LSTC/STD/PAR/606	4	7.0					
16	OPGW Tension Assembly (or)		LSTC/STD/GNA/752	1	N/A	Standard - Through Line Assy				
16	OPGW Tension Assembly		LSTC/STD/GNA/754	1	N/A	Alternative - Joint Box Assy				
17	125kN Tension Insulator Set		LSTC/STD/GNA/564	6	N/A					
18	Helicopter / Pole Number Plate	TE687	LSTC/STD/PAR/687	2	N/A	Optional (Supply 8-off M16x45 Bolts, Flat Washers, Nuts & Palnuts)				
19	Structure Earthing Assembly		LSTC/STD/GNA/588	1	N/A					
20	ACD Arrangement		M0005126	1	N/A	Powersystems Drawing				
21	Pole Mounted Number Plate		M0005131	1	N/A	Powersystems Drawing				
22	Property Plate		M0005170	1	N/A	Powersystems Drawing				
23	Circuit Colour Plates		M0006434	1	N/A	Powersystems Drawing				
24	Bolt Set M20x75 Long		BS3692 GR8.8	16	N/A	Comprising, Bolt, Nut, Locknut and Flat Washer - for use with Item 15				
25	Bolt Set M16x30		BS3692 GR8.8	18	N/A	c/w 3mm washer				
26	Bolt Set M16x50		BS3692 GR8.8	12	N/A	c/w palnut				
27	Step Irons			4		Powersystems Drawing				

ALL STEELWORK SHALL BE MARKED WITH DISTINGUISHING NUMBERS AND / OR LETTERS.

TO CREATE THE BAR MARK: REPLACE 'LSTC/STD/PAR' WITH 'TE'

I.E. 'LSTC/STD/PAR/610' BECOMES 'TE610'

TOTAL CALCULATED WEIGHT = 2614kg

CLIENT PowerSystems SPECIFICATION OHL-03-132	TITLE MATERIAL LIST - 20-35° ANGLE STRUCTURE	SCALE NTS	ORIGINAL SIZE A4	LS TRANSMISSION CONSULTANCY LIMITED Yorkshire House York Road Little Driffield East Yorkshire YO25 5XA 01377 253617
		(UNLESS OTHERWISE STATED)		
		DATE 28/10/04	CHECKED GS	
		DRAWN R.T.J	APPROVED PP	
		DRAWING NUMBER LSTC/STD/GNA/510		REV 8