

						DESCRIPTION
						FOR ISSUE
						REV 9 DATE 27/07/07 BY JR CHKD GS APPD PP
ITEM - DESCRIPTION		BAR MARK	REFERENCE NUMBER	QTY REQ'D	WEIGHT EACH (kg)	REMARKS
1	Crossarm Assy		LSTC/STD/GNA/540	1	1124	
2	Wood Pole	TE640	LSTC/STD/PAR/640	2	700	Weight Based on 14m Long Extra Stout Pole
3	Post Insulator		LSTC/STD/GNA/566	3	N/A	To Suit Project Specification
4	"H" Pole Foundation Brace	TE618	LSTC/STD/PAR/618	2	53.4	125x75x8 U.E.A x 6153 Long 4 holes
5	Timber Baulk	TE617	LSTC/STD/PAR/617	2	115	
6	Foundation Block	TE602	LSTC/STD/PAR/602	2	40	
7	Bolt Set M20 x Length to Suit Pole Diameter		LSTC/STD/GNA/555	6	0.5	
8	Square Curved Washer	TE620	LSTC/STD/PAR/620	4	0.2	
9	Square Flat Washer	TE619	LSTC/STD/PAR/619	6	0.1	
10	125kN Tension Insulator Set		LSTC/STD/GNA/564	6	N/A	
11	Stay Attachment Plate	TE606	LSTC/STD/PAR/606	4	7.0	
12	Pole Cap		REF:	2	N/A	
13	Anti-Split Bolt M20 Length to Suit Pole Diameter		LSTC/STD/GNA/555	4	0.5	
14	Bolt Set M20 x Length to Suit Pole Diameter		LSTC/STD/GNA/555	6	0.5	BS3692 GR8.8
15	Post Insulator Mounting Stool	TE663	LSTC/STD/PAR/663	3	6	
16	OPGW Tension Assy (or)		LSTC/STD/GNA/752	1	N/A	Standard - Through Line Assy
16	OPGW Tension Assy		LSTC/STD/GNA/748	1	N/A	Alternative - Joint Box Assy
17	Insulated Stay Assembly		LSTC/STD/GNA/560	4	80	
18	Helicopter / Pole Number Plate	TE687	LSTC/STD/PAR/687	2	N/A	Optional (Supply 8-off M16x45 Bolts, Flat Washers, Nuts & Palnuts)
19	Structure Earthing Assembly		LSTC/STD/GNA/570	1	N/A	
20	ACD Arrangement		M0005126	1	N/A	Powersystems Drawing
21	Pole Mounted Number Plate		M0005131	1	N/A	Powersystems Drawing
22	Property Plate		M0005170	1	N/A	Powersystems Drawing
23	Circuit Colour Plates		M0006434	1	N/A	Powersystems Drawing
24	Bolt Set M20x75 Long		BS3692 GR8.8	16	N/A	Comprising, Bolt, Nut, Locknut and Flat Washer - for use with Item 11
25	Step Irons			4		Powersystems Drawing

ALL STEELWORK SHALL BE MARKED WITH DISTINGUISHING NUMBERS AND / OR LETTERS.

TO CREATE THE BAR MARK: REPLACE 'LSTC/STD/PAR' WITH 'TE'

I.E. 'LSTC/STD/PAR/610' BECOMES 'TE610'

TOTAL CALCULATED WEIGHT = 3303kg

CLIENT	PowerSystems	TITLE MATERIAL LIST - 0 DEG FAILURE CONTAINMENT STRUCTURE	SCALE (UNLESS OTHERWISE STATED)	NTS	ORIGINAL SIZE	A4	LS TRANSMISSION CONSULTANCY LIMITED Yorkshire House York Road Little Driffield East Yorkshire YO25 5XA 01377 253617	
SPECIFICATION	OHL-03-132		DATE	10/11/04	CHECKED	GS		
			DRAWN	R.T.J	APPROVED	PP		
			DRAWING NUMBER		LSTC/STD/GNA/529	REV		9