

DESCRIPTION		FOR ISSUE			
REV	DATE	BY	CHKD	APPO	
4	13/08/07	JR	JG	PP	

	STRUCTURE TYPE	UNFACTORED WORKING LOADS					FOUNDATION TYPES																			
							FOR FOUNDATION DETAILS REFER TO DRAWING NUMBER LSTC/STD/GNA/779 (SHEET 4 OF 4)					FOR FOUNDATION DETAILS REFER TO DRAWING NUMBER LSTC/STD/GNA/779 (SHEET 1 OF 4)														
		POLE OVERTURNING MOMENT ABOUT FULCRUM (kNm)	Hz POLE LOAD (kN)	VERTICAL POLE LOADS		STAY LOADS (kN)	VERY POOR SOIL					POOR SOIL					AVERAGE SOIL					GOOD SOIL				
				DOWN (kN)	UPLIFT (kN)		A	B	C	D	E	A	B	C	D	E	A	B	C	D	E	A	B	C	D	E
11.5 - 14m H - POLE WITH X-BRACING (GNA 500)	H - POLE INTERMEDIATE	58	13	93	66	N/A	1.5	1.5	1.5	2x4m		1.5			2x4m		1.5			3x4m		1.5			2x4m	
13 - 14m H - POLE STAYED WITH DOUBLE X-BRACING (GNA 502)	0-5° ANGLE	54	17	144	88	15	1.5		1.5	3x5m		1.5			3x5m		1.5			4x5m		1.5			2x5m	
MG13 SPECIAL 15m H-POLE STAYED WITH DOUBLE X-BRACING (GNA 847)	0-5° ANGLE	54	17	144	88	15	1.5		1.5	3x5m		1.5			3x5m		1.5			4x5m		1.5			2x5m	
13 - 14m H - POLE STAYED NO X-BRACING (GNA 505)	5-20° ANGLE	28	5	116	0	38	1.5		1.5	2 x 3.5m		1.5			2 x 3.5m		1.5			1 x 3.5m		1.5			1 x 3.5m	
12 - 14m H- POLE STAYED NO X-BRACING (GNA 508)	20-35° ANGLE	42	6	137	0	45	1.5		1.5	2 x 3.5m		1.5			2 x 3.5m		1.5			1 x 3.5m		1.5			1 x 3.5m	
13 - 15m H - POLE STAYED NO X-BRACING (GNA 511)	2 POLE TERMINAL	36	5	153	0	57	1.5		1.5	3 x 3.5m		1.5			3 x 3.5m		1.5			1 x 3.5m		1.5			1 x 3.5m	
MG53 SPECIAL 15m H-POLE STAYED WITH DOUBLE X-BRACING (GNA 837)	2 POLE TERMINAL/SECTION	50	14	153	90	57	1.5		1.5	3x5m		1.5			3x5m		1.5			4x5m		1.5			2x5m	
13 - 16m H - POLE STAYED WITH DOUBLE X-BRACING (GNA 514)	0° SECTION UPTO 120m	50	14	123	90	15	1.5		1.5	3x5m		1.5			3x5m		1.5			4x5m		1.5			2x5m	
15 - 16m H - POLE STAYED WITH DOUBLE X-BRACING (GNA 517)	0° SECTION 120 - 150m	62	14	122	79	15	1.5	1.5	1.5	2x5m		1.5			2x5m		1.5			3x5m		1.5			2x5m	
13 - 15m H - POLE UNSTAYED WITH X-BRACING (GNA 542)	0° SECTION UNSTAYED	54	13	105	57	N/A	1.5		1.5	2 x 3.5m		1.5			2 x 3.5m		1.5			4 x 3.5m		1.5			1 x 3.5m	
10.5 - 12m POLE (GNA 520)	SINGLE POLE INTERMEDIATE	160	14	63	6	N/A	1.5		1.5	N/A	1.5	1.5		1.5	N/A		1.5		1.5	N/A		1.5		1.5	N/A	
14 - 16m H - POLE STAYED KNEE BRACED 6m SPACING (GNA 527)	FAILURE CONTAINMENT WOOD POLE	53	7	91	0	42	1.5		1.5	2 x 6.5m		1.5			2 x 6.5m		1.5			2 x 6.5m		1.5			2 x 6.5m	
10m & 14m 4 - POLE STAYED STRUCTURE (GNA 545)	4 POLE TERMINAL	36	5	153	0	57	1.5		1.5	3 x 3.5m		1.5			3 x 3.5m		1.5			1 x 3.5m		1.5			1 x 3.5m	
14.25m STEEL POLE WITH DOUBLE X-BRACING (GNA 524)	SELF SUPPORTING STEEL STRUCTURE	631 (1021)	57 (92)	431 (682)	286 (460)	N/A	VALUES IN () ARE ULTIMATE LIMIT STATE FOUNDATIONS TO BE DESIGNED AND DETAILED BY CONTRACTOR																			
10.7m STEEL POLE WITH X-BRACING (GNA 522)	SELF SUPPORTING TERMINAL STEEL STRUCTURE	1145 (1831)	89 (142)	91 (127)	14 (19)	N/A																				

- GENERAL NOTES:
1. FOR TYPICAL SOIL TYPES APPLICABLE TO SOIL CLASSIFICATIONS REFER TO TABLE ON LSTC/STD/GNA/779 SHEET 1
2. SEE GENERAL NOTES ON DRAWING NUMBER LSTC/STD/GNA/779 SHEET 1

GENERAL NOTES:	CLIENT	TITLE	SCALE	ORIGINAL SIZE	LS TRANSMISSION CONSULTANCY LIMITED Yorkshire House York Road Little Drifffield East Yorkshire YO25 5XA 01377 253617
	PowerSystems		(UNLESS OTHERWISE STATED)	A4	
			DATE	CHECKED	
			06/04/05	JG	
			DRAWN	APPROVED	
			JN	PP	
			DRAWING NUMBER	REV	
			LSTC/STD/GNA/779	4	
	SPECIFICATION				
	OHL-03-132				