

DESCRIPTION				FOR ISSUE		
REV	DATE	BY	CHKD	APPD		
4	13/08/07	JR	JG	PP		

FOUNDATIONS FOR VERY POOR GROUND CONDITIONS AS DETAILED ON DRAWING NUMBER LSTC/STD/GNA/779 (SHEET 4 OF 4)																		
STRUCTURE TYPE	FACTORS OF SAFETY FOR VERY POOR SOIL CONDITIONS WITH MINIMUM POLE EMBEDMENT OF 2.5m HORIZONTAL GROUND				FACTORS OF SAFETY FOR POOR SOIL CONDITIONS WITH MINIMUM POLE EMBEDMENT OF 2.5m HORIZONTAL GROUND				FACTORS OF SAFETY FOR AVERAGE SOIL CONDITIONS WITH MINIMUM SAFE POLE EMBEDMENT				FACTORS OF SAFETY FOR GOOD SOIL CONDITIONS WITH MINIMUM SAFE POLE EMBEDMENT				* MINIMUM SAFE POLE EMBEDMENT FOR AVERAGE & GOOD SOILS ONLY DEPTH (m)	* MAXIMUM PERMITTED SLOPE GRADIENT ACROSS POLES FOR AVERAGE & GOOD SOILS ONLY (SEE NOTE 3)
	POLE O/T MOMENT	POLE Hz STABILITY	POLE UPLIFT STABILITY	POLE AXIAL LOAD STABILITY	POLE O/T MOMENT	POLE Hz STABILITY	POLE UPLIFT STABILITY	POLE AXIAL LOAD STABILITY	POLE O/T MOMENT	POLE Hz STABILITY	POLE UPLIFT STABILITY	POLE AXIAL LOAD STABILITY	POLE O/T MOMENT	POLE Hz STABILITY	POLE UPLIFT STABILITY	POLE AXIAL LOAD STABILITY		
H - POLE INTERMEDIATE	1.9	> 3.0	1.4	1.4	2.7	> 3.0	1.5	2.1	1.8	> 3.0	1.4	> 3.0	2.4	> 3.0	1.7	> 3.0	1.9	1 in 5
0-5° ANGLE	1.6	> 3.0	1.5	1.5	2.9	> 3.0	1.5	2.1	1.9	> 3.0	1.4	> 3.0	2.6	> 3.0	1.5	> 3.0	1.9	1 in 5
5-20° ANGLE	3.0	> 3.0	> 3.0	1.6	> 3.0	> 3.0	> 3.0	1.5	> 3.0	> 3.0	> 3.0	2.0	> 3.0	> 3.0	> 3.0	2.8	1.9	1 in 5
20-35° ANGLE	2.0	> 3.0	> 3.0	1.5	> 3.0	> 3.0	> 3.0	1.6	2.5	> 3.0	> 3.0	1.7	> 3.0	> 3.0	> 3.0	2.3	1.9	1 in 5
2 POLE TERMINAL	2.4	> 3.0	> 3.0	1.4	> 3.0	> 3.0	> 3.0	1.4	2.8	> 3.0	> 3.0	1.6	> 3.0	> 3.0	> 3.0	2.1	1.9	1 in 5
0° SECTION UPTO 120m	1.8	> 3.0	1.5	1.4	> 3.0	> 3.0	1.5	2.5	2.2	> 3.0	1.4	> 3.0	2.8	> 3.0	1.5	> 3.0	1.9	1 in 5
0° SECTION 120 - 150m	1.8	> 3.0	1.6	1.6	2.5	> 3.0	1.5	1.9	1.7	> 3.0	1.4	> 3.0	2.3	> 3.0	1.6	> 3.0	1.9	1 in 5
0° SECTION UNSTAYED	1.6	> 3.0	1.6	1.5	2.8	> 3.0	1.6	2.0	1.9	> 3.0	1.4	> 3.0	2.5	> 3.0	1.4	2.9	1.9	1 in 5
SINGLE POLE INTERMEDIATE	> 3.0	> 3.0	> 3.0	2.5	> 3.0	> 3.0	> 3.0	2.7	> 3.0	> 3.0	> 3.0	> 3.0	> 3.0	> 3.0	3.0	> 3.0	1.9	N/A
FAILURE CONTAINMENT WOOD POLE	1.6	> 3.0	> 3.0	1.6	3.0	> 3.0	> 3.0	1.9	2.0	> 3.0	> 3.0	> 3.0	2.7	> 3.0	> 3.0	> 3.0	1.9	1 in 10
4 POLE TERMINAL	2.4	> 3.0	> 3.0	1.4	> 3.0	> 3.0	> 3.0	1.4	2.8	> 3.0	> 3.0	1.6	> 3.0	> 3.0	> 3.0	2.1	1.9	1 in 5
SELF SUPPORTING STEEL STRUCTURE	FOUNDATIONS TO BE DESIGNED AND DETAILED BY CONTRACTOR																	
SELF SUPPORTING TERMINAL STEEL STRUCTURE	REFER TO DRAWING NUMBER LSTC/STD/GNA/779 (SHEET 2 OF 4) FOR LOADINGS OF FOUNDATIONS																	

GENERAL NOTES:

1. FOR TYPICAL SOIL TYPES APPLICABLE TO SOIL CLASSIFICATIONS REFER TO TABLE ON LSTC/STD/GNA/779 SHEET 1
2. SEE GENERAL NOTES ON DRAWING NUMBER LSTC/STD/GNA/779 SHEET 1
3. FOR GRADIENTS GREATER THAN SPECIFIED REFER TO ENGINEER TO VERIFY STRUCTURE STABILITY

GENERAL NOTES:	CLIENT	TITLE	SCALE	ORIGINAL SIZE	LS TRANSMISSION CONSULTANCY LIMITED Yorkshire House York Road Little Driffield East Yorkshire YO25 5XA 01377 253617		
	PowerSystems		(UNLESS OTHERWISE STATED)	A4			
			DATE	06/04/05		CHECKED	JG
			DRAWN	JN		APPROVED	PP
SPECIFICATION	OHL-03-132		DRAWING NUMBER	REV			
			LSTC/STD/GNA/779	4			