




DESCRIPTION		FOR ISSUE				
REV	DATE	BY	RF	CHKD	SP	APPD
7	27/11/07					GS



USE PROPRIETARY
JIG FOR PARALLEL
SCARFING &
DRILLINGS
TO ENSURE
ACCURACY

POLES SUPPLIED IN PAIRS
OPGW HOLES REQUIRED IN
1 POLE ONLY.

REFERENCE (typical only)
ACTUAL POLE VALUES TO BE USED
14 - POLE LENGTH
305 - POLE DIA. 1.5m FROM BUTT
IF - IMPORTED REDFIR
75 - YEAR OF CREOSOTING
XYZ - SUPPLIERS NAME OR MARK
GOUGE MARK 6 WIDE x 6 DEEP
3m FROM POLE BUTT



GENERAL NOTES:

1. ALL DIMENSIONS ARE IN mm, UNLESS NOTED
2. ALL DRILLINGS TO BE 24mm DIAMETER HOLES UNO.
3. POLE SIZES BASED ON BS1990, EXTRA STOUT POLES RANGE

LENGTH = 13m - 16m & PARALLEL WITHIN LIMITS.

*—MINIMUM TOP DIST BETWEEN FLATS = 200mm

*—MAXIMUM TOP DIST BETWEEN FLATS = 265mm

MINIMUM DIAMETER 1.5m FROM BUTT = 305mm

SUPPLIER TO NOTE THESE DIMENSIONS ARE FOR GENERIC
POLE DRILLING AND SCARFING ONLY TO SUIT A RANGE OF
POLE SIZES, ACTUAL POLE MINIMUM DIMENSIONS TO BE
SPECIFIED AT TIME OF ORDERING. ORDER VALUES WILL
SUPERSEDE THESE STATED VALUES. MAXIMUM VALUE NOT
TO BE EXCEEDED

BAR MARK / ITEM NUMBER
TE626

CLIENT	PowerSystems
SPECIFICATION	OHL-03-132

TITLE	PART - WOOD POLE SCARFING DETAILS
-------	---

SCALE	1 : 35	ORIGINAL SIZE	A4
DATE	17/01/05	CHECKED	GS
DRAWN	JN	APPROVED	PP
DRAWING NUMBER	LSTC/STD/PAR/626	REV	7

LS TRANSMISSION CONSULTANCY LIMITED
Yorkshire House
York Road
Little Driffield
East Yorkshire
YO25 5XA
01377 253617

