


USED ON LSTC/STD/GNA/517


POLE SCARFED PARALLEL ON BOTH SIDES TO GIVE 50mm WIDE FLAT FACE

DESCRIPTION		FOR ISSUE				
REV	DATE	BY	CHKD	SP	APPD	GS
7	27/11/07	RF				






POLES SUPPLIED IN PAIRS
OPGW HOLES REQUIRED IN 1 POLE ONLY.

REFERENCE (typical only)
ACTUAL POLE VALUES TO BE USED
14 - POLE LENGTH
305 - POLE DIA. 1.5m FROM BUTT
IF - IMPORTED REDFIR
75 - YEAR OF CREOSOTING
XYZ - SUPPLIERS NAME OR MARK
GOUGE MARK 6 WIDE x 6 DEEP
3m FROM POLE BUTT



GENERAL NOTES:

- ALL DIMENSIONS ARE IN mm, UNLESS NOTED
- ALL DRILLINGS TO BE 24mm DIAMETER HOLES UNO.
- POLE SIZES BASED ON BS1990, EXTRA STOUT POLES RANGE
LENGTH = 15m - 16m & PARALLEL WITHIN LIMITS
* MINIMUM TOP DIST BETWEEN FLATS = 200mm
* MAXIMUM TOP DIST BETWEEN FLATS = 265mm
MINIMUM DIAMETER 1.5m FROM BUTT = 305mm



POLE SIZE TO BE IMPRESSED ON THE BOTTOM

BAR MARK / ITEM NUMBER
TE656

SUPPLIER TO NOTE THESE DIMENSIONS ARE FOR GENERIC POLE DRILLING AND SCARFING ONLY TO SUIT A RANGE OF POLE SIZES, ACTUAL POLE MINIMUM DIMENSIONS TO BE SPECIFIED AT TIME OF ORDERING. ORDER VALUES WILL SUPERSEDE THESE STATED VALUES. MAXIMUM VALUE NOT TO BE EXCEEDED.

CLIENT	PowerSystems
SPECIFICATION	OHL-03-132

TITLE	PART - WOOD POLE SCARFING DETAILS 0° SECTION 120-150m SPAN
-------	--

SCALE	1 : 30 (UNLESS OTHERWISE STATED)
DATE	17/01/05
DRAWN	JN
DRAWING NUMBER	LSTC/STD/PAR/656
ORIGINAL SIZE	A4
CHECKED	GS
APPROVED	PP
REV	7

LS TRANSMISSION CONSULTANCY LIMITED
Yorkshire House
York Road
Little Driffield
East Yorkshire
YO25 5XA
01377 253617