





FOR
INFORMATION

POLE SCARFED ON BOTH SIDES TO GIVE 50mm FLAT FACE



POLE SCARFED ON BOTH SIDES TO GIVE 50mm FLAT FACE

REFERENCE (typical only)
 ACTUAL POLE VALUES TO BE USED
 14 - POLE LENGTH
 365 - POLE DIA. 1.5m FROM BUTT
 IF - IMPORTED REDFIR
 75 - YEAR OF CREOSOTING
 XYZ - SUPPLIERS NAME OR MARK
 GOUGE MARK 6 WIDE x 6 DEEP
 3m FROM POLE BUTT



POLE SIZE TO BE IMPRESSED ON THE BUTT

GENERAL NOTES:

- ALL DIMENSIONS ARE IN mm, UNLESS NOTED
- ALL DRILLINGS TO BE 24mm DIAMETER HOLES
- POLE SIZES BASED ON BS1990, EXTRA STOUT POLES RANGE

LENGTH = 14m & PARALLEL WITHIN LIMITS
 * MINIMUM TOP DIST BETWEEN FLATS = 200mm
 * MAXIMUM TOP DIST BETWEEN FLATS = 265mm
 MINIMUM DIAMETER 1.5m FROM BUTT = 305mm

SUPPLIER TO NOTE THESE DIMENSIONS ARE FOR GENERIC POLE DRILLING AND SCARFING ONLY TO SUIT A RANGE OF POLE SIZES, ACTUAL POLE MINIMUM DIMENSIONS TO BE SPECIFIED AT TIME OF ORDERING. ORDER VALUES WILL SUPERSEDE THESE STATED VALUES. MAXIMUM VALUE NOT TO BE EXCEEDED

BAR MARK / ITEM NUMBER
TE710

CLIENT	PowerSystems
SPECIFICATION	OHL-03-132

TITLE	PART - WOOD POLE SCARFING 4 POLE ENTRY TERMINAL STRUCTURES 14m POLE
-------	---

SCALE	1:30 (UNLESS OTHERWISE STATED)	ORIGINAL SIZE	A4
DATE	27/01/05	CHECKED	GS
DRAWN	R.T.J	APPROVED	PP
DRAWING NUMBER	LSTC/STD/PAR/710	REV	4

LS TRANSMISSION CONSULTANCY LIMITED
 Yorkshire House
 York Road
 Little Driffield
 East Yorkshire
 YO25 5XA
 01377 253617

