

NOTES:

- POLE LEGS TO BE MATCHED, POLE TOP MINIMUM DIAMETER BEFORE FABRICATION STOUT - 250mm
- ALL HOLES TO BE 22mm DIA. DRILLED AT RIGHT ANGLES TO VERTICAL CENTRE LINE OF POLE. ALL DRILLING AND CUTTING TO BE DONE STRICTLY TO TEMPLATE PRIOR TO CREASOTING.
- POLE BUTTS TO CUT AT RIGHT ANGLES TO AXIS OF POLE.
- POLE LEGS TO BE NOTCHED AND DRILLED FOR 230 X 125 WOOD BAULKS AS SHOWN
- POLE TO BE SUPPLIED WITH 4 - 1300 X 230 X 125 BAULKS TO DRG NO 1 00 043 9130 TYPE 2 CUT FROM THE SQUARE AND 4 - M20 GALVANISED BOLTS EACH WITH 1 FLAT AND 1 CURVED GALVANISED WASHER TO DRG NOS 1 00 043 9804 AND 9805 RESPECTIVELY.
- HOLES NOT REQUIRED FOR PARTICULAR APPLICATIONS WILL BE PLUGGED ON SITE

POLE LENGTH	DIM Y
10.0m	1700
13.0m	1700
14.0m	1700
15.0m	1700
16.0m	1800

ALL DIMENSIONS SHOWN ARE IN MILLIMETRES UNLESS OTHERWISE STATED

CE Electric UK
 Manufacture Details
 Sheet No. 10 Scale 1:200
 Prepared By B. GORDON
 Revised 01/07/03 GMD Reference
 Date Issued 24/08/03 Checked By S. SAUNDERS
 Lloyds Court, 78 Grey Street, Newcastle Upon Tyne, NE1 6AF
 66KV SINGLE CIRCUIT LINES
 DRILLING SCARFING AND MARKING FOR TERMINAL SUPPORT WITH SURGE ARRESTORS AND HEAT SHRINK TERMINATION AS SHOWN ON 1.09.123.1173 SHEET 9
 Type OVERHEAD POLES
 Ref No. C975718
 Revision
 Historic Drg. No. 1091231173