

Document reference	NSP/004/046				
Version:-	2.0	Date of Issue:-	Sept 2009	Page	47 of 117

MATERIAL LIST FOR 1 09 139 0013 SHEET No.1 (0° - 20° Deviation)

Pole fabrication Details

233999	12m Extra Stout Pole	1 09 139 0003 Sht2 Item 'A'
234000	13m Extra Stout Pole	1 09 101 0003 Sht2 Item 'B'
234001	14m Extra Stout Pole	1 09 101 0003 Sht2 Item 'C'
234002	15m Extra Stout Pole	1 09 101 0003 Sht2 Item 'D'
234003	16m Extra Stout Pole	1 09 101 0003 Sht2 Item 'E'
234004	17m Extra Stout Pole	1 09 101 0003 Sht2 Item 'F'

Poles supplied complete with foundation blocks and fixings

2 235124 439103 Type 2 Blocks Or 1 X 1000 Dia. X 150 Thk. C25 Concrete Pad.

Materials Not supplied with Poles

<u>QTY</u>	<u>CAT. No.</u>	<u>DESCRIPTION</u>	<u>CE DETAIL DRG.</u>	
2	251550	Pilot Post Insulator + (support stool)	1 09 101 0487 sht 18	
2	inc above	Pilot Insulator Support Stool (See above)	1 09 101 0487 sht 34	
6	251553	120kn Ten. Ins. Assembly 132kV Approach)	1 09 101 0487 sht 31	or
6	251554	120kn Ten. Ins. Assembly 33 & 66kV Approach)	1 09 101 0487 sht 31	or
6	251552	120kn Ten. Ins. Assembly (33-132kV Normal)	1 09 101 0487 sht 30	
6	243240	Poplar Comp. dead end c/w straight lug	1 09 101 0653 sht 3	
5	346474	Insulator/ Tension Plate	1 09 101 0675 Sht1	
2	346478	0-40° Crossarm	1 09 101 0675 Sht6	
4	346502	Crossarm Strut	1 09 101 0675 Sht40 Item 40	
4	346476	Crossarm Brace	1 09 101 0675 Sht4	
2	346477	Crossarm Support	1 09 101 0675 Sht5	
1	To Suit	Pole Number Plate	1 09 101 0228 Sht 3	
1	363318	Pole Safety Sign	1 09 101 0229 Sht1	
1	251362	Enhanced Anti-Climbing Device	1 09 101 0408 Sht 8 (If Required)	
1	346487	M20 Tie Rod (360 Lg)	1 09 101 0675 Sht29 Item 4 (Anti-	
Split)				
1	36 8059	Eye Bolt Type 2	1 09 043 9603 Sht1	
4	368078	Square Curved Washer	1 00 043 9605 Sht1	
1	370504	Earthing Fastenings	1 09 101 0162 Sht1	
36	378703	Bolt Ms Hex Galv M20 X 60 Lg		
60	375616	Plain Washer Ms Galv M20		
2	346493	M20 Tie Rod (700 Lg)	1 09 101 0675 Sht29 item 5	
8	337630	Nut Ms Hex Galv M16		
8	378987	Plain Washer Ms Galv M16		
20m	220146	70mm HD Green PVC Insulated earthing Conductor –		Earthed Poles
1	075234	70mm compression Lug (m20 clearance hole	1091010237	Earthed Poles

For details on stay requirements see the following detailed stay drawings:

* For 1 To 3 Stays (1 Per Stay) Refer To Drawing 1 09 101 0429 Sht8