



- 1. CLASS OF POLE TO BE 'STOUT' OR EXTRA STOUT IN ACCORDANCE WITH 1.09.101.0238**
- 2. POLE BUTT TO BE CUT AT RIGHT ANGLES TO AXIS OF POLE**
- 3. ALL HOLES TO BE 22mm DIA. DRILLED AT RIGHT ANGLES TO VERTICAL CENTRE LINE OF POLE. ALL DRILLING AND CUTTING TO BE DONE STRICTLY TO TEMPLATE PRIOR TO CREOSOTING**
- 4. POLE TO BE NOTCHED AND DRILLED FOR 250 x 125 x 1300 LONG BAULKS**
- 5. STOUT POLES TO BE NORMALLY FITTED WITH DOUBLE BAULKS, LOWER BAULKS MAY BE OMITTED WHERE GOOD GROUND CONDITIONS PERTAIN. (eg K=4000lb ft/ft) ²**
- 6. EXTRA STOUT POLES TO BE NORMALLY FITTED WITH DOUBLE BAULKS. EXTRA STOUT POLES DESIGNED TO INCREASE WIND SPANS MAY BE UNSUITABLE FOR POOR GROUND CONDITIONS. SEE SPECIFICATION.**

POLE LENGTH	DIM. 'S'
8.5m - 12m INCLUSIVE	1.5
13.0m - 15.0m INCLUSIVE	1.7
16.0m - 18.0m INCLUSIVE	1.9
20.0m - 24m INCLUSIVE	2.5

ALL DIMENSIONS SHOWN ARE IN MILLIMETRES UNLESS OTHERWISE STATED

 NORTHERN POWERGRID		Lloyds Court, 78 Grey Street, Newcastle Upon Tyne, NE1 6AF			
		66KV SINGLE CIRCUIT OVERHEAD LINES DRILLING, SCARFING AND MARKINGS FOR SINGLE POLE ARRANGEMENT			
Manufacturer Details					
Sheet No. 1	Scale 1:20 & 1:10				
Prepared By Joan.Oakley		Type OVERHEAD	POLES		
Revised 10/04/14	Grid Reference	Ref No.	C1034394	Historic Drg.No.	1091231186
Date Issued 10/04/14	Checked By G HAMMEL	Revision	Notes		