


VOLTAGE	DIM 'X'	DESCRIPTION	CAT. No.
66KV	440mm	APPROACH/EARTHED	251539
66KV	540mm	NORMAL/UNEARTHED	251536
33KV	NOT APP.	ALL SITUATIONS	251546



NOTES

- 1.COMPOSITE INSULATOR ASSEMBLY SUPPLIED COMPLETE WITH END FITTING AND ARCING HORNS.
2. WHERE IT IS REQUIRED TO REPLACE EXISTING HISTORICAL INSULATOR ASSEMBLIES THAT UTILISE SMALLER CONDUCTORS THAN 175mm ACSR, THIS MAY BE ACHIEVED BY REPLACING THIS ASSEMBLY WITH 70KN ASSEMBLIES AS SHOWN ON 1 09 101 0488 SHT8
3. ARRANGEMENT 2 TO BE USED AT 33KV, ARCING HORNS NOT REQUIRED.

ALL DIMENSIONS ARE SHOWN IN MILLIMETERES UNLESS OTHERWISE STATED

		Lloyds Court, 78 Grey Street, Newcastle Upon Tyne, NE1 6AF	
Manufacturer Details		33/66KV SINGLE CIRCUIT OVERHEAD LINES TENSION INSULATOR SETS M.F.L. 125KN COMPOSITE INSULATOR ASSEMBLY	
Sheet No. 9	Scale 1:5	Type OVERHEAD	
Prepared By Joan Oakley	Grid Reference	Ref No. C990229	Historic Drg.No. 1091010488
Revised 23/08/10	Checked By G HAMMEL	Revision	Notes
Date Issued 19/08/10			